



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS



BELGE KAPSAMI (SCOPE OF THE CERTIFICATE) : GERSAN ELEKTRİK TİC.VE SAN. A.Ş.
İLGİLİ TÜRK STANDARDI/RELATED TURKISH STANDARD : TS EN 61439-6 / 18.03.2015

SECTIONS: 1254 mm²

MODEL : GS-C COMPACT 1250 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 1250 A Icu: 50 kA (1 SC)/150 kA Iimp: 8 kV CU BRAID SECTIONS: 450 mm² , E SECTIONS: 225 mm² , PE SECTIONS: 1450 mm²

MODEL : GS-C COMPACT 1600 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 1600 A Icu: 65 kA (1 SC)/150 kA Uimp: 8 kV CU BRAID SECTIONS: 660 mm² , E SECTIONS: 330 mm² , PE SECTIONS: 2265 mm²

MODEL : GS-C COMPACT 2000 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 2000 A Icu: 80 kA (1 SC)/175 kA

Uimp: 8 kV CU BRAID SECTIONS: 1040 mm² , E SECTIONS: 520 mm² , PE SECTIONS: 2344 mm²

MODEL : GS-C COMPACT 2500 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 2500 A Icu: 80 kA (1 SC)/175 kA Uimp: 8 kV CU BRAID SECTIONS: 1080 mm² , E SECTIONS: 540 mm² , PE SECTIONS: 2660 mm²

MODEL : GS-C COMPACT 3200 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 3200 A Icu: 120 (1 SC) kA/264 kA Uimp: 8 kV CU BRAID SECTIONS: 1320 mm² , E SECTIONS: 660 mm² , PE SECTIONS: 4590 mm²

MODEL : GS-C COMPACT 4000 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 4000 A Icu: 150 kA (1 SC)/330 kA Uimp: 8 kV CU BRAID SECTIONS: 2160 mm² , E SECTIONS: 1080 mm² , PE SECTIONS: 5205 mm²

MODEL : GS-C COMPACT 5000 A Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 / XB (WITH RESIN) PHASE: 3P+N+E+PE In: 5000 A Icu: 150 kA (1 SC)/330 kA Uimp: 8 kV CU BRAID SECTIONS: 3120 mm² , E SECTIONS: 1560 mm² , PE SECTIONS: 7030 mm²

MODEL : GGDH5 COMPACT PLUG IN 160 A , GGDH5 COMPACT PLUG IN 250 A , GGDH5 COMPACT PLUG IN 400 A , GGDH5 COMPACT PLUG IN 630 A - WITH BREAKERS/MINI CIRCUIT BREAKER Ue: 1000 V U_i: 1000 V FREQUENCY: 50 HZ IP: 55 PHASE: 3P+N+E+PE In: 160 A , 250 A , 400 A , 630 A Icu: 150 kA/330 kA (1 SC) Uimp: 8 kV

NOTE: REFERRING TO TS EN 61439-6 CLAUSE 10.10.2.1 MODELS IN 3 PHASE BUSBARS ARE VALID FOR 3 WIRE, 4 WIRE AND 5 WIRE

(e-mailed signed)

29.09.2022

On Behalf Of The Head Of Certification Center
SOYDAN CERAN

ELECTROTECHNICAL SECTOR MANAGER

*This certificate was issued after the production place of the notified product meets the requirements of Institute.

*This certificate could only be cancelled or changed by the notified party in 15 days from issued date without a valid and signed request to close.

*TSE ELECTRONICS SECTOR (SEKTÖR YÖNETİMİ) Address: Beşiktaş Cad No: 112/1000 Beşiktaş/İSTANBUL Telephone: 0212 444 00 00 Fax: 0212 444 00 07

*TSE SECTOR FOR CERTIFICATION (SEKTÖR YÖNETİMİ) Address: Beşiktaş Cad No: 112/1000 Beşiktaş/İSTANBUL Telephone: 0212 444 00 00 Fax: 0212 444 00 07 E-mail: iletisim@tse.org.tr , iletisim@tse.org.tr

