

Certificate of Compliance

Item Tested: Medium Duty Cable Tray

Type: GKT-A7.5 (75mm wide, 1.0mm thick, 25mm deep)
GKT-A10 (100mm wide, 1.0mm thick, 25mm deep)
GKT-A15 (150mm wide, 1.0mm thick, 25mm deep)
GKT-A22.5 (225mm wide, 1.0mm thick, 25mm deep)
GKT-A30 (300mm wide, 1.0mm thick, 25mm deep)

No. of Samples Tested: 3 samples of each size

Relevant Specification used as Basis of Tests: BSEN 61537:2002 / IEC 61537:2001

This is to certify that, on the basis of the tests undertaken, the samples of the above items are considered to meet the requirements of the above Standards.

Signed: N A Jones
N A Jones
Certifying Officer

Date of test: 2 February 2006
Date of issue: 2 February 2006

Gersan Elektrik Tic Ve San A.S.
Tem Yan Yol Cad
No.6 P.K.57
Istanbul
Turkey

Serial No: 06 5121
Report No: 05018619A/Issue 2