TEST CONFIRMATION

on the given range of performed tests

[illegible]	[illegible]
[illegible]	[illegible]
[illegible]	[illegible]
[illegible]	[illegible]
[illegible]	[illegible]
[illegible]	[illegible]

Rated operational voltage	U_e	400	V AC
Rated insulation voltage	U_i	1000	V AC
Rated current	I_n	1250	A
Rated short-time withstand current	I_{cw}	1500	kA, 1 s
Rated peak withstand current	I_{pk}	3300	kA
Rated frequency	f	50	Hz
Degree of protection		IP55	

[illegible]	[illegible]
[illegible]	[illegible]

verification of
- temperature-rise limits,
- the dielectric properties,
- the short-circuit withstand strength,
- the effectiveness of protective circuit,
- clearances and creepage distances,
- the degree of protection,
- EMC tests,
- the resistance of insulating materials to abnormal heat and fire,
- the electrical characteristics of the busbar trunking system,
- structural strength,
- insulating materials,
- resistance to flame propagation,
- the resistance to insulating penetration

15 September to 14 October 2009	[illegible]

The performance of the apparatus was considered satisfactory and subject to final analysis of the test results verification of the assembly to drawings and routine by internal testing a Certificate can on IEVA Certificate will be issued with regard to these tests. The test results are documented in the IEVA Certificate No. 17248 Subcontractor Ref. No. IEVA 2009-PA037-NH

[illegible]

[illegible]

[illegible]