

independent, accredited testing centre - member laboratory of UK and CENET

TEST CONFIRMATION

on the given range of performed tests

Client Name (s), or Ref. & C Trade Name/Manufacturer Contact with Ref. & C TEST NUMBER/CLASS EUREP			DATE
Client Name (s), or Ref. & C 1000 A / 400 V / 1000 V L/N / 100 V L/N / 100 V L/L / 100 V L/L (three-phase main busbar system - 4 and 10 busbars)			CONTRACT NUMBER REFERENCE
IS 1000A			YES
Test sample			DATE, NO
Rated operational voltage	UL	400 V L/N	DATE
Rated insulation voltage	UL	1000 V L/N	CHARACTERISTICS
Rated current	UL	1000 A	DATE ON THE
Rated short-circuit withstand current	UL	50 kA 1 s	DATE
Rated peak withstand current	UL	100 kA	
Rated frequency	UL	50 Hz	
Degree of protection		IP20	
EC DIRECTIVE 2006/95			MANUFACTURER ADDRESS
Verification of - compliance for tests - the relevant properties - the short-circuit withstand strength - the effectiveness of protection circuit - mechanical and chemical resistance - the degree of protection - EMC tests - the resistance of insulating materials to electrical stress and fire - the electrical characteristics of the busbar trailing system - structural strength - crushing resistance - resistance to flame propagation - the resistance to building penetration			NAME OF TEST REFERENCE
11 September to 14 October 2006			DATE OF TEST
The performance of the apparatus was confirmed satisfactory and subject to final opinion of the test results, verification of the assembly to drawing, and signing by owner, issuing a Certificate (or a little Certificate will be issued with respect to these tests. The test results are documented in the JCTM Certificate (or JCTM Certificate) (or no. 1000/2006/0001/00)			REFERENCE


 Test Engineer
 IPH (UK) Ltd
 Date: 14 November 2006


 Technical Manager
 Test Engineer in Charge