LOVAG

Low Voltage Agreement Group

Test Report No. 7273/VNL

Test Laboratory	:	VEIKI-VNL Electric Large Laboratories Ltd. H-1158 Budapest, Vasgyár u. 2-4 HUNGARY Telephone: +36 141 73187 Fax: +36 141 73183 www.vnl.hu
Client	:	GERSAN ELEKTRIK Tic. ve San. A.Ş. Anadolu Yakası Organize Sanayi Bölgesi Gazi Bulvarı No:39-41 34953 Tuzla-İstanbul TURKEY
Manufacturer	:	GERSAN ELEKTRIK Tic. ve San. A.Ş. Anadolu Yakası Organize Sanayi Bölgesi Gazi Bulvarı No:39-41 34953 Tuzla-İstanbul TURKEY
Test object	:	Busbar Trunking System
Type designation	:	GS-A COMPACT 5000A
Date(s) of test(s)	:	22.03.2013 - 10.04.2013
Date of receipt	:	18.02.2013
Test specifications	:	IEC/EN 60439-2: Ed.3.0 (2000) + A1 (2005) IEC 61439-6: Ed.1.0 (2012)
Test results	:	The tested busbar trunking system met the relevant requirements of the standard. 8.2.1 Verification of temperature-rise limits – PASSED 8.2.2 Verification of dielectric properties – PASSED 8.2.13 Verification of the electrical characteristics – PASSED

The Record of Proving Test consists of :

13 pages LOVAG test report forms	- oscillograms
2 other pages	4 drawings
- diagrams	- photographs

Date of issue : 14.05.2013

Responsible Test Laboratory

Signatures:

/ Lajos Tóth / Responsible for the test	/ Norbert Menyhért / Supervised by	/ Tibor Tóth / Responsible observer	/ Dr. László Varga / Managing director

Note:
The test results apply only to the items tested.
The test report shall not be reproduced except in full without the written approval of the test laboratory.

[illegible]