

Test Report No. 7282/VNL

Test Laboratory : VEIK-VNL Electric Large Laboratories Ltd.
H-1158 Budapest, Vaszgolyó u. 2-4
HUNGARY
Telephone: +36 141 73157
Fax: +36 141 73163
www.vel.hu

Client : GERSAN ELEKTRIK Tic. ve San. A.Ş.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvarı
No:39-41 34953
Tuzla-Istanbul
TURKEY

Manufacturer : GERSAN ELEKTRIK Tic. ve San. A.Ş.
Anadolu Yakasi Organize Sanayi Bölgesi Gazi Bulvarı
No:39-41 34953
Tuzla-Istanbul
TURKEY

Test object : Busbar Trunking System Tap-Off Unit

Type designation : GS COMPACT BASO-MCCCB1000

Date(s) of test(s) : 10.05.2013

Date of receipt : 18.02.2013

Test specifications : IEC/EN 60439-2: Ed.3.0 (2000) + A1 (2005)
IEC 61439-6: Ed.1.0 (2012)

Test results : The test object fulfilled the requirements of the relevant sub-clause of the standard.
8.2.4 Effectiveness of the protective circuit **-PASSED**

The Record of Proving Test consists of :



9 pages LOVAG test report forms - oscillograms
- other pages - 4 drawings
- diagrams - photographs

Date of issue : 14.05.2013

Responsible Test Laboratory

Signatures:

/ Gábor Huszti /
Responsible for the test

/ Norbert Menyhért /
Supervised by

/ Tibor Tóth /
Responsible observer

/ Dr. László Varga /
Managing director

Note:

The test results relate only to the items tested.
The test report shall not be reproduced except in full
without the written approval of the test laboratory.

