

Test Report No. 7273/VNL

Test Laboratory	VEIRS-VNL, Electric Large Laboratories Ltd. H-1158 Budapest, Városliget u. 2-4 HUNGARY Telephone: +36 141 73187 Fax: +36 141 73183 www.vel.hu
Client	GERSAN ELEKTRIK Tsz. ve. Szm. A.Ş. Anadolü Yakam Organize Sanayi Bölgesi Gazı Bulvarı No:39-41 34053 Tuzla-İstanbul TURKEY
Manufacturer	GERSAN ELEKTRIK Tsz. ve Szm. A.Ş. Anadolü Yakam Organize Sanayi Bölgesi Gazı Bulvarı No:39-41 34053 Tuzla-İstanbul TURKEY
Test object	Busbar Trunking System
Type designation	GS-A COMPACT 8000A
Date(s) of test(s)	22.03.2013 - 10.04.2013
Date of receipt	18.03.2013
Test specifications	IEC/EN 60439-2 Ed.3.0 (2006) + A1 (2008) IEC 61439-4 Ed.1.0 (2012)
Test results	The tested busbar trunking system met the relevant requirements of the standard. 8.2.1 Verification of temperature-rise limits - PASSED 8.2.2 Verification of dielectric properties - PASSED 8.2.13 Verification of the electrical characteristics - PASSED

The Record of Proving Test consists of :

13 pages LOVAG test report forms	- oscillograms
3 other pages	4 drawings
- diagrams	- photographs

Date of issue: 14.05.2013

Responsible Test Laboratory

Signatures:


/ Lajos Tóth /
Responsible for the test


/ Norbert Marinyasi /
Supervised by


/ Tibor Tóth /
Responsible observer


/ Dr. László Varga /
Managing director

NOTE:
The test results relate only to the items tested.
The test report shall not be reproduced except in full
without the written approval of the test laboratory.

