

Test Report No. 7280/VNL

Test Laboratory	VEIKO-VNA, Electric Large Laboratories Ltd. H-1158 Budapest, Vasgyári u. 2-4 HUNGARY Telephone: +36 141 73157 Fax: +36 141 73163 www.vni.hu
Client	GERSAN ELEKTRIK Tí. és Sz. A.É. Anadolı Yıkıcı Organize Sanayi Bölgesi Gazı Bulvarı No:38-41 34953 Tuzla-İstanbul TURKEY
Manufacturer	GERSAN ELEKTRIK Tí. ve San. A.Ş. Anadolı Yıkıcı Organize Sanayi Bölgesi Gazı Bulvarı No:38-41 34953 Tuzla-İstanbul TURKEY
Test object	Busbar Trunking System
Type designation	GS-A COMPACT 1000A
Date(s) of test(s)	28-04-2013
Date of receipt	18-02-2013
Test specifications	IEC/EN 60439-2: Ed 3.0 (2000) + A1 (2006) IEC 61439-4: Ed 1.0 (2012)
Test results	The tested busbar trunking system met the relevant requirements of the standard. 8.2.3 Verification of short-circuit strength - PASSED 8.2.4 Effectiveness of the protective circuit - PASSED

The Record of Proving Test consists of:

12 pages LOVAG test report forms

- oscillograms

other pages

2 drawings

- diagrams

- photographs

Date of issue: 14.05.2013

Responsible Test Laboratory

Signatures



/ Gabor Huszti /
Responsible for the test



/ Herbert Mayrhofer /
Supervised by



/ Tibor Tóth /
Responsible observer



/ Dr. László Varga /
Managing director

Note:

The test results relate only to the items tested.
The test report shall not be reproduced except in full
without the written approval of the test laboratory.

