Design Review — Issues

Greenfield Residences — landscape package · review meeting 2026-09-10 · drawings reviewed: previous issue (before Rev A) · reviewer: sample reviewer

No.	Sheet	Issue	Action
1	L-1, L-6	Trees on the podium: confirm the tree pit size and the soil depth on the basement slab against the greening standard before the permit set.	Designer, Rev A
2	L-1	Fire-truck access lane along the west boundary: keep the lane clear of planting; show its extent on the planting plan.	Designer, Rev A
3	L-4, bill	Plant schedule and bill quantities must agree with the planting plan; the plan governs.	Developer

Please respond in writing with the next issue of the drawings.