



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate No: EEA – 1800 – 0105

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratory** on **29.11.2018** in accordance with EN 1634-1:2014+A1:2018 standard for the product as described below:

“ ER-PWR-1001 ” SINGLE LEAF TIMBER DOOR

Single Leaf

FIRE RESISTANCE CLASSIFICATION	
Direction: Opening away from the fire	E 30, EI ₂ 30, EI ₁ 30
Direction: Opening into the fire	E 30, EI ₂ 30, EI ₁ 30

Placed on the market by

ERGÜN YAPI SİST. PLAST. DEMİR DOĞRAMA İMA. SAN. VE TİC. LTD. ŞTİ.
E-5 Çevre Yolu Üzeri Kırıkkhan/Hatay

And Produced In the Factory

ERGÜN YAPI SİST. PLAST. DEMİR DOĞRAMA İMA. SAN. VE TİC. LTD. ŞTİ.
E-5 Çevre Yolu Üzeri Kırıkkhan/Hatay

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18– 121**.

This certificate is initially valid until **5th January 2020** providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
05.01.2019

