

Fire Safety Inspection Report

Cedar Falls Fire Prevention Bureau - 220 Division St

Report no.
Occupancy
Date of inspection
Inspector

FM-26-0425
Little Acorn Early Learning - Maple Street (E occupancy, day care)
August 6, 2026
Capt. R. Delgado

Item	Violation	Classification	Correction required
1	Kitchen fire extinguisher past its annual inspection tag	Serious	within 14 days
2	Exit sign over the rear door not illuminated	Serious	within 5 days
3	Extension cord used as permanent wiring in Toddler Room 2	Minor	within 30 days
4	Storage within 18 inches of sprinkler heads in the supply closet	Minor	Corrected on site
5	Fire alarm control panel showing a trouble signal	Imminent hazard	immediately

Correction periods run from the date of inspection. A re-inspection will be scheduled after the longest correction period.
Classifications: Imminent hazard - correct immediately; Serious; Minor.