

JOB SITE INSTRUCTION - JSI

Project Name: MOEG Plaza Redevelopment

Project No: 23-0641-CM-HT-MPR

Employer: ENOVA

Project Manager: N/A

Supervision Engineer: RMC Shaker

Contractor: PCP

From:	RMC/ SCG	Date:	Monday, January 13, 2025
To:	PCP	Time:	11:30 AM
Ref.:	MOEG-JSI-MEP-0021	Subject:	MOEG Plaza - IDF Locations

Reference:

MOEG Plaza - IDF Locations

Topic:

- As per MAF request ,PCP follow the mentioned locations in attached link for the new racks of IDF , PCP should Study these locations to achieve the required Cat 6 length of less than 90m.
- The rack will be provided by MA F as well as the fiber connectivity to the main server room. The Contractor's scope will be the 1st and 2nd fix in addition to providing a secure room/enclosure for the outdoor rack.

Attachments:

Consultant:

Name: Tarek Lotfy

Signature:



THIS JOB SITE INSTRUCTION (J.S.I.) DOES NOT ENTAIL ANY ADDITIONAL TIME.