etana Biotech **PT ETANA BIOTECHNOLOGIES INDONESIA**	**LOGBOOK / *LOGBOOK*** **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items		Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
				07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves		No Leaks							
2	Compressed Air Pressure		0.6-0.8 MPa							
3	Availability of cooling water		Available							
4	NaCLO		> 20 L							
5	NaOH		> 20 L							
6	Plant Steam Pressure (on the header)		3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On		≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby		Monitoring Only							
8	UV Lamp Hour Meter		< 8500 h							
9	PW Temp. On the PW Tank		≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor		Monitoring Only							
11	PW Temp. On the looping return 2nd floor		Monitoring Only							
12	PW Conductivity after EDI Circulation On		< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby		Monitoring Only							
13	PW Cond. On the looping return 1st floor		< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor		< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity		> 1 m/s							
16	PW Loop 2 Flow Velocity		> 1 m/s							

17	pH		7-9							
18	Soft Water total hardnees (once a day)		< 10 ppm							
19	Differential Pressure MMF		< 0.2 MPa							
20	Differential Pressure ACF		< 0.2 MPa							
21	Cleanliness of machine and room		Clean							

	Operator : Shift 1	Shift 2	Shift 3	Checked By :
	( )	( )	( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech **PT ETANA BIOTECHNOLOGIES INDONESIA**	**LOGBOOK / *LOGBOOK*** **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK*	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech **PT ETANA BIOTECHNOLOGIES INDONESIA**	**LOGBOOK / *LOGBOOK*** **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech **PT ETANA BIOTECHNOLOGIES INDONESIA**	**LOGBOOK / *LOGBOOK*** **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech **PT ETANA BIOTECHNOLOGIES INDONESIA**	**LOGBOOK / *LOGBOOK*** **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK*	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK*	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK*	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	LOGBOOK / *LOGBOOK* **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK***	Document No. : SOP/EBI/EN-015-F01H
	PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 Shift 2 Shift 3 ( ) ( ) ( )	( )

etana Biotech PT ETANA BIOTECHNOLOGIES INDONESIA	**LOGBOOK / *LOGBOOK*** **PEMANTAUAN HARIAN TERHADAP GENERATOR AIR MURNI DAN DISTRIBUSI SKIDNYA** ***DAILY MONITORING OF PW GENERATOR AND THE DISTRIBUTION SKID***	Document No. : SOP/EBI/EN-015-F01H

Date :

No	Checklist Items	Standard Value	Time : (Shift 1, Shift 2 dan Shift 3)						Remark
			07:30	11:30	15:30	19:30	23:30	03:30	
1	Piping, Pneumatic hose, Valves	No Leaks							
2	Compressed Air Pressure	0.6-0.8 MPa							
3	Availability of cooling water	Available							
4	NaCLO	> 20 L							
5	NaOH	> 20 L							
6	Plant Steam Pressure (on the header)	3-4 Bar							
7	Press. Diff. of 5 Micron Filter Circulation On	≤ 7 psi							
	Press. Diff. of 5 Micron Filter Idle/Standby	Monitoring Only							
8	UV Lamp Hour Meter	< 8500 h							
9	PW Temp. On the PW Tank	≤ 40 ^{0}C							
10	PW Temp. On the looping return 1st floor	Monitoring Only							
11	PW Temp. On the looping return 2nd floor	Monitoring Only							
12	PW Conductivity after EDI Circulation On	< 1.2 μ/cm							
	PW Conductivity after EDI Idle/Stanby	Monitoring Only							
13	PW Cond. On the looping return 1st floor	< 1.2 μ/cm							
14	PW Cond. On the looping return 2nd floor	< 1.2 μ/cm							
15	PW Loop 1 Flow Velocity	> 1 m/s							
16	PW Loop 2 Flow Velocity	> 1 m/s							
17	pH	7-9							
18	Soft Water total hardnees (once a day)	< 10 ppm							
19	Differential Pressure MMF	< 0.2 MPa							
20	Differential Pressure ACF	< 0.2 MPa							
21	Cleanliness of machine and room	Clean							

Notes :	Operator :	Checked By :
PW Conductivity dan PW Conductivity action limit : Sesuai Lampiran SOP/EBI/EN-015-L07 UV Lamp hour meter alert limit : 8000 h, UV Lamp hour meter action limit : 8500 h PW Loop Flow Velocity alert limit : 1.1 m/s, PW Loop Flow Velocity action limit : 1 m/s Pressure Diff. of 5 micron filter alert limit : 6 psi Pressure Diff. of 5 micron filter action limit : 7 psi Pembuatan NaOH dan NaClO mengacu pada SOP/EBI/EN-015. point 7.1.1.2 dan 7.1.1.3.	Shift 1 ( ) Shift 2 ( ) Shift 3 ( )	( )