

18 hours. The de-energization occurred in the High Fire Threat District (HFTD) classifications and communities listed below.

**Table 1 – Time, Place, and Duration of PSPS Event by Circuit - Amended 2.28.2020**

Impacted Circuit	HFTD Tier(s)	Start Date and Time	Key Communities	Restoration Date and Time
BIG BEND 1101	TIER 3, TIER 2	10/05/2019 22:08	OROVILLE	10/06/2019 11:37
BIG BEND 1102	TIER 3, PARTIALLY OUTSIDE HFTD	10/05/2019 22:08	BERRY CREEK, BRUSH CREEK	10/06/2019 13:16
BUCKS CREEK 1101	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:11	STORRIE	10/06/2019 12:54
BUTTE 1105*	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:05	CHICO	10/06/2019 10:24
CLARK ROAD 1101	TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:18	OROVILLE	10/06/2019 10:43
CLARK ROAD 1102	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:18	OROVILLE, PARADISE	10/06/2019 13:30
KANAKA 1101	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:04	OROVILLE, FORBESTOWN, FEATHER FALLS	10/06/2019 15:41
NOTRE DAME 1104*	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:06	FOREST RANCH, CHICO	10/06/2019 10:33
ORO FINO 1101	TIER 3	10/05/2019 22:11	MAGALIA	10/06/2019 12:56
ORO FINO 1102	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:11	FOREST RANCH, MAGALIA, BUTTE MEADOWS, STIRLING CITY	10/06/2019 14:27
PARADISE 1103	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:36	PARADISE	10/06/2019 12:41
PARADISE 1104	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:04	PARADISE	10/06/2019 12:29
PARADISE 1105	TIER 3, PARTIALLY OUTSIDE HFTD	10/05/2019 22:05	MAGALIA, PARADISE	10/06/2019 13:09
PARADISE 1106	TIER 3, PARTIALLY	10/05/2019 22:06	PARADISE	10/06/2019 10:31

Impacted Circuit	HFTD Tier(s)	Start Date and Time	Key Communities	Restoration Date and Time
	OUTSIDE HFTD			
SYCAMORE CREEK 1111*	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:07	COHASSET, CHICO	10/06/2019 12:20
WYANDOTTE 1103*	TIER 3, TIER 2	10/05/2019 22:08	BERRY CREEK, OROVILLE	10/06/2019 14:20
WYANDOTTE 1105	TIER 3, TIER 2, PARTIALLY OUTSIDE HFTD	10/05/2019 22:09	OROVILLE	10/06/2019 10:22
Centerville – Table Mtn 60kV	Tier 2, Tier 3	10/05/2019 22:15	Transmission Line	10/06/2019 11:13
Centerville – Table Mtn – Oroville 60kV	Tier 2, Tier 3	10/05/2019 22:18	Transmission Line	10/06/2019 10:39
DeSabra – Centerville 60kV	Tier 3	10/05/2019 22:11	Transmission Line	10/06/2019 11:03
Forks of the Butte Tap 60kV	Tier 3	10/05/2019 22:11	Transmission Line	10/06/2019 11:03
Kanaka 115 kV TAP	Tier 2 Tier 3	10/05/2019 De-energized prior to beginning of event for schedule maintenance	Transmission Line	10/06/2019 14:21
Oro Fino Tap 60kV	Tier 3	10/05/2019 22:11	Transmission Line	10/06/2019 11:03
Woodleaf – Palermo 115kV	Tier 2, Tier 3	10/05/2019 De-energized prior to beginning of event for scheduled maintenance.	Transmission Line	10/06/2019 14:21

\* Circuits that had only certain higher risk sections de-energized rather than the entire circuit (i.e., circuits that were sectionalized to limit the impact of de-energization) are marked with a single asterisk. Section 12, *Sectionalization*, refers to the asterisks in the table in Section 3.

## **Section 4 – Customers Impacted**

There were approximately ~~11,300~~ **11,600** customers whose power was turned off for public safety during the PSPS event. The table below shows each circuit involved, the total number of customers impacted on each circuit, and the number of customers impacted on each circuit by customer type.

***Table 2 – Customers by Circuit - Amended 1.27.2020***

<b>Impacted Circuit</b>	<b>Total Number Out</b>	<b>Residential</b>	<b>Commercial/Industrial</b>	<b>Medical Baseline</b>	<b>Other</b>
BIG BEND 1101	191	168	21	10	2
BIG BEND 1102	368	326	36	16	6
BUCKS CREEK 1101	4	0	3	0	1
BUTTE 1105	230	209	19	10	2
CLARK ROAD 1101	15	0	15	0	0
CLARK ROAD 1102 <sup>4</sup>	1,053	910	121	64	22
KANAKA 1101	609	552	50	33	7
NOTRE DAME 1104	303	264	36	11	3
ORO FINO 1101	2,277	2,204	71	223	2
ORO FINO 1102	1,948	1,813	123	102	12
PARADISE 1103	833	592	240	35	1
PARADISE 1104	791	653	138	53	0
PARADISE 1105	1,020	797	222	54	1
PARADISE 1106	289	229	60	9	0
SYCAMORE CREEK 1111	578	516	55	20	7
WYANDOTTE 1103	770	698	66	51	6
WYANDOTTE 1105	330	319	10	39	1
<b>Grand Total</b>	<b>11,609</b>	<b>10,250</b>	<b>1,286</b>	<b>730</b>	<b>73</b>

## **Section 5 – Damage to Overhead Facilities**

PG&E personnel patrolled all sections of de-energized PSPS circuits for safety prior to re-energizing. During those patrols, PG&E discovered two cases of wind-related hazards across the impacted divisions which required remediation prior to re-energizing. In the first case, the top branches of a fallen tree had made contact with one phase of an overhead conductor. In the second case, vegetation debris was found ensnared on an overhead conductor. In both instances, PG&E crews removed the vegetation from contact with the overhead conductors with no repairs needed to any PG&E equipment.

---

<sup>4</sup> One Customer on Clark Road 1102 was incorrectly mapped to Loyola 1102 and is included in the Clark Road 1102 customer count.