

Detection fo Attacks

Securing critical information infrastructures

Jonathan Jogenfors

Leonardo Iwaya

2016-09-26


- About us



- Model of information security: Prevention, Detection, Reaction (PRD)
 - Prevention: Difficult because attacker has the advantage.
Large attack surface.
 - Reaction: Too late!
 - Detection: What our papers are all about

When prevention fails


Intrusion Detection Systems & Honeypots



Source: <http://www.computerworld.com/article/2592425/lan-wan/intrusion-detection.html>

Control Theory & Cybernetics

Control systems: measure, compare, compute and correct.



Feedback loop to control the behavior of a system by comparing its output to a desired value, and applying the difference as an error signal to dynamically change the output so it is closer to the desired output.

Motivation

- Papers [2] and [1] were **selected** based on their **relevance** to the theme of “*attack detection methods*” for “*critical infrastructures*”.
- Paper [3] was in the course’s reading list.

Paper	Year	CI Sub-area	Citations	Journal IF
Pasqualetti et al [2]	2013	Attack Detection	210	2.777
Genge et al [1]	2015	Attack Prevention & Detection	12	1.351
Vasilomanolakis et al [3]	2016	Attack Detection	1	n.a

Attack detection and identification in cyberphysical systems (2013)


A system dynamics approach for assessing the impact of cyber attacks on CI (2015)

Aim & Contribution

- To **identify** and **rank** assets in complex, large-scale and heterogeneous CIs.
- **Cyber Attack Impact Assessment** (CAIA) methodology that helps system admins to understand:
 1. How cyber attacks affect the normal functioning of physical processes?
 2. What cyber assets would cause the most negative impact if compromised?

A system dynamics approach for assessing the impact of cyber attacks on CI (2015)

CAIA Methodology



A system dynamics approach for assessing the impact of cyber attacks on CI (2015)

Experiments & Comparisons

- First, the **basic functioning** of CAIA is demonstrated using IEEE 14-bus electric grid model.
- Second, CAIA's **scalability** is proven by using attack scenarios in the context of IEEE 300-bus electric grid model.
- Third, CAIA's **cross-sector applicability** is evaluated using Tennessee Eastman chemical process system.
- The methodology was also **compared** with other approaches (i.e., graph-theoretic and electrical centrality metric techniques).

A system dynamics approach for assessing the impact of cyber attacks on CI (2015)




Fig. 5 – IEEE 14-bus model and its associated controllers.




Fig. 7 – Effects of observed variable weights on the impact matrix for the IEEE 14-bus model. (a) Equal weights for all observed variables and (b) increased weights for observed variables (bus line voltage levels) 10, 12 and 14.

A system dynamics approach for assessing the impact of cyber attacks on CI (2015)




Fig. 5 – IEEE 14-bus model and its associated controllers.




Fig. 8 – Effects of observed variable weights on impact rankings for the IEEE 14-bus model. (a) Impacts on control variables and (b) impacts on observed variables.

A system dynamics approach for assessing the impact of cyber attacks on CI (2015)




Fig. 20 – Stealthy cyber attack sequence that disconnects substation lines.

A system dynamics approach for assessing the impact of cyber attacks on CI (2015)




Fig. 19 – Stealthy cyber attack on the IEEE 14-bus model line breakers. (a) CAIA impact matrix and (b) ordered impact ranking of breakers.




Fig. 21 – Operator's view of the stealthy attack sequence.

A system dynamics approach for assessing the impact of cyber attacks on CI (2015)

Limitations

- CAIA helps to identify and rank assets given specific interventions (e.g., an attack)
- Which interventions are relevant to test (?), and, how to protect the assets after generating the impact matrix (?) are open questions; out of the paper's scope.
- Obvious Note: the knowledge of impact matrices would be definitely valuable to attackers(!); as any risk assessment information.
- Seems hard to reproduce since no detailed information is given about the simulations; plus, no source code.

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Aim & Contribution

- HosTaGe: honeypot for detecting **multi-stage attacks** in ICS networks.
- Honeypot extension with capabilities of ICS protocols, i.e., Modbus, S7, SNMP, HTTP, Telnet, SMB and SMTP.
- Basic functions:
 1. notify the network administrators;
 2. produce an attack signature;
 3. forward the signature to the internal IDSs.

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Experiments & Comparisons

- HosTaGe was **compared** with “CONPOT ICS/SCADA Honeypot” ¹
- Criteria:
 1. ability to not be evade (i.e., be perceived by attackers);
 2. ability to detect multi-stage attacks;
 3. ability to generate valid signatures for Bro IDS ².

¹<http://conpot.org/>

²<https://www.bro.org/>

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Formal Model - Extended Finite State Machine (EFSM)




Fig. 1. EFSM of the attack detection and signature generation mechanism.

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Formal Model - Extended Finite State Machine (EFSM)

- Detection Mechanism
 1. Single-Protocol Level Detection (SPLD)
 2. Multi-Stage Level Detection (MSLD)
 3. Payload Level Detection (PLD)
- **Time window** (tw) determines whether an attack should be mapped as SPLD or MSLD

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Example - Signature Generation

- Automatically generate signature for well-known Metasploit script³ for Modbus services identification.

Listing 1. Modbus attack signature generated by *HosTaGe*

```
signature modbus-signature{  
  ip-proto == tcp  
  dst-port == 502  
  payload  
    /\x21\x00\x00\x00\x00\x06\x01\x04\x00  
  event "Modbus attack"  
}
```

³No further information given by the authors...

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Comparison - Honeypot x CONPOT

- Controlled environment, no firewalls, 8 to 12 weeks, probing by Shodan⁴.




Fig. 3. Comparison of attacks on *HosTaGe* and Conpot for HTTP, Modbus, S7 and Telnet. Note, that Conpot does not support the Telnet protocol.




Fig. 4. Comparison of unique and common malicious IP addresses targeting *HosTaGe* and Conpot

⁴<https://www.shodan.io/>

Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)

Limitations

- The evaluation of multi-stage signature generation was rather shallow.
- Shodan's probes were not explained in details, i.e., how Shodan detect a honeypot?

More info about HosTaGe can be found at Darmstad's research group website⁵.

⁵<https://www.tk.informatik.tu-darmstadt.de/de/research/secure-smart-infrastructures/hostage/>

Debate Suggestions

- **Attacker models** [2, 1] – strong assumptions; absolute knowledge and control.
- **Study validation** – enough tests; data sources; experiment description.
- **Reproducibility** – enough information; open source; plant models.
- **Overall critics** about the papers – readability; depth; contribution.

Question for paper “Attack detection and identification in cyberphysical systems (Vasilomanolakis et al, 2013)”

- (a)
- (b)
- (c)
- (d)

Question for paper “Attack detection and identification in cyberphysical systems (Vasilomanolakis et al, 2013)”

- (a)
- (b)
- (c)
- (d)

Question for paper “A system dynamics approach for assessing the impact of cyber attacks on critical infrastructures (Pasqualetti et al, 2015)”.

Regarding the Cyber Attack Impact Assessment (CAIA) methodology proposed in the paper, which of the following statements is FALSE:

- (a) CAIA helps system administrators to analyze how cyber attacks affect the normal functioning of physical processes.
- (b) The proposed approach computes the covariances of observable variables before and after a specific intervention in control variables.
- (c) CAIA methodology is mainly inspired in graph-theoretical and electric centrality metric approaches.
- (d) CAIA helps to identify and rank assets in the context of critical infrastructures.

Question for paper “A system dynamics approach for assessing the impact of cyber attacks on critical infrastructures (Pasqualetti et al, 2015)”.

The proposed methodology (CAIA) was validated by various experiments. Which of the following statements is FALSE:

- (a) The conducted experiments were able to demonstrate CAIA's efficiency, scalability and cross-sector applicability.
- (b) Final results demonstrate that CAIA methodology is only suitable for electric grid models, such as IEEE 14-bus and 300-bus.
- (c) To demonstrate CAIA's cross-sector applicability, the authors used the Tennessee Eastman chemical plant model.
- (d) The authors described how an attacker can use CAIA results to plan and execute a stealthy cyber attack, in which multiple low-impact variables are affected simultaneously to cause severe infrastructure degradation.

Question for paper “Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)”

Regarding the concept of honeypot addressed in the paper, which of the following statements is **FALSE**:

- (a) Honeypots exhibit a high rate of false positives.
- (b) Honeypots are systems whose only value is to be probed, attacked and compromised.
- (c) Honeypots are used to attract malicious users and study their activities.
- (d) One essential requirement for honeypots is their ability to remain undetected.

Question for paper “Multi-stage Attack Detection and Signature Generation with ICS Honeypots (2016)”

Regarding the comparative study between HosTaGe and Conpot, which of the following statements is FALSE:

- (a) Overall, HosTage was able to detect more attacks than Conpot.
- (b) The analysis of multi-stage attacks was performed only for HosTaGe.
- (c) HosTaGe honeypot presented better evasion (ability to remain undetected) capabilities than CONPOT.
- (d) Conpot is not an ICS-specific honeypot and therefore it supports a smaller number of protocols.



Béla Genge, István Kiss, and Piroska Haller.

A system dynamics approach for assessing the impact of cyber attacks on critical infrastructures.

International Journal of Critical Infrastructure Protection,
10:3–17, 2015.



Fabio Pasqualetti, Florian Dörfler, and Francesco Bullo.

Attack detection and identification in cyber-physical systems.

IEEE Transactions on Automatic Control, 58(11):2715–2729,
2013.



E. Vasilomanolakis, S. Srinivasa, C. G. Cordero, and M. Mühlhäuser.

Multi-stage attack detection and signature generation with ics honeypots.

In *NOMS 2016 - 2016 IEEE/IFIP Network Operations and Management Symposium*, pages 1227–1232, April 2016.