

Arizona Department of Environmental Quality
Drinking Water Lead and Copper Analysis Reporting Form
 >>>> SYSTEM INFORMATION <<<<

PWS ID#: AZ0408-082
T. Christopherson
 Owner/Contact Person

PWS Name: Ranch Water Service, Inc.
928-757-9027
 Owner/Contact Phone Number

928-757-4839
 Owner/Contact Fax Number

SAMPLE COLLECTION POINT/ID*

- ☒ Zone/Distribution
☐ Other - Direct from source
 ☐ Surface
 ☐ Well

Contaminant: Lead Copper
 Action Level: 0.015 mg/L 1.3 mg/L
 Analysis Method: EPA 200.9 SM3111B
 Sample Type: DW DW

- Sample Type:
☐ Triannual (3 YR) Compliance
☐ Annual Compliance
☐ 6 Month Initial Compliance

Specimen #	Collection Point	Sample Date	Analysis Completion Date	Lead mg/L (1030) Result	Analysis Completion Date	Copper mg/L (1022) Result
29554-01	Commerical Standpipe (T)	08/04/11	09/07/11	<0.0010	09/08/11	<0.020
29554-02	Coin op Standpipe	08/04/11	09/07/11	<0.0010	09/08/11	<0.020
29554-03	RV Park Ladies Room	08/04/11	09/07/11	<0.0010	09/08/11	0.063
29554-04	Coin op Standpipe	08/04/11	09/07/11	<0.0010	09/08/11	<0.020
29554-05	Commerical Standpipe (T)	08/04/11	09/07/11	<0.0010	09/08/11	<0.020

Lab ID# AZ0037 90th % Calc: <0.0010 0.0315

I hereby certify that the information provided in this report is accurate and correct to the best of my knowledge:

Printed Name and Phone Number of Lab Contact: Sheila Poff

Phone#: 928-754-8101

Signature: 

Mail completed form to: ADEQ Water Quality Compliance Data Units (MC 5415B-1), 1110 W. Washington St., Phoenix, AZ 85007.

For questions call: (602)771-4513 or within AZ 1-800-234-5677 Ext. 4513. Fax: (602)771-4505.

Copies of this form are available at <http://www.azdeq.gov/function/forms/appswater.html#sdw>, scroll down to laboratory reporting forms and click on DWAR 8: DW Lead & Copper Analysis Report.

Revised 8/2008