

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 1

3.3 PLUMBING ROUGH-IN LOG

Project Information

Property Address: _____
 Permit Number: _____ Inspection Date: _____
 Inspector: _____ Plumber: _____
 License #: _____ Phone: _____

WATER SUPPLY SYSTEM

✓	Item	Specification	Notes
☐	Main water service line size	Typically 3/4" or 1"	
☐	Main shut-off valve accessible	Location: _____	
☐	Water pressure regulator (if required)	☐ Installed ☐ Not required	
☐	Water meter/pit (municipal)	☐ Installed ☐ Well system	
☐	Main distribution lines sized correctly	Per fixture unit calculation	
☐	Hot water trunk line size	Typically 3/4"	
☐	Cold water trunk line size	Typically 3/4"	
☐	Branch lines sized per code	1/2" typical to fixtures	
☐	Pipe material type	☐ PEX ☐ Copper ☐ CPVC	
☐	Pipes properly supported/strapped	Per code spacing	
☐	Pipes protected from freezing	Exterior walls, crawlspace	
☐	Nail plates over pipes in framing	Where within 1.25" of edge	

Water Supply System Notes:

MASTER BATHROOM

✓	Fixture/Location	Rough-In Height/Spec	Spacing	Notes
☐	Toilet - cold supply stub	6"-8" AFF, left side	12" from wall	
☐	Toilet - drain rough-in	Correct distance from wall	12" or 10" per spec	
☐	Toilet - vent connection	Per code requirements	Within 6' typical	
☐	Vanity sink - hot supply	21" AFF typical	4" right of center	
☐	Vanity sink - cold supply	21" AFF typical	4" left of center	
☐	Vanity sink - drain rough-in	16" AFF typical	Centered on sink	
☐	Shower valve rough-in	48" AFF typical (adjust)	Centered in shower	
☐	Shower head stub-out	78"-80" AFF	Centered	
☐	Shower drain location	Proper slope to drain	Per shower pan spec	
☐	Handheld shower outlet (if appl.)	Per preference		
☐	Body spray outlets (if appl.)	Per plan/preference		
☐	Tub spout rough-in (if appl.)	4" above tub rim	Centered or per plan	
☐	Tub drain/overflow assembly	Access panel required	Per tub specs	
☐	Tub/shower valve type	☐ Single ☐ Thermo ☐ Press-bal		

Master Bathroom Notes:

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 3
BATHROOM #2

✓	Fixture/Location	Rough-In Height/Spec	Spacing	Notes
☐	Toilet - cold supply stub	6"-8" AFF, left side	12" from wall	
☐	Toilet - drain rough-in	Per toilet spec	12" or 10"	
☐	Vanity sink - hot supply	21" AFF	8" centers	
☐	Vanity sink - cold supply	21" AFF	8" centers	
☐	Vanity sink - drain	16" AFF	Centered	
☐	Shower/tub valve	48" AFF typical	Centered	
☐	Shower head stub-out	78"-80" AFF	Centered	
☐	Tub drain/overflow	Per tub specifications	Access provided	

BATHROOM #3 (if applicable)

✓	Fixture/Location	Rough-In Height/Spec	Spacing	Notes
☐	Toilet - cold supply stub	6"-8" AFF, left side	12" from wall	
☐	Toilet - drain rough-in	Per toilet spec	12" or 10"	
☐	Vanity sink - hot supply	21" AFF	8" centers	
☐	Vanity sink - cold supply	21" AFF	8" centers	
☐	Vanity sink - drain	16" AFF	Centered	
☐	Shower valve	48" AFF typical	Centered	
☐	Shower head stub-out	78"-80" AFF	Centered	

KITCHEN

✓	Fixture/Location	Rough-In Height/Spec	Spacing	Notes
☐	Kitchen sink - hot supply	18"-22" AFF	8" centers typical	
☐	Kitchen sink - cold supply	18"-22" AFF	8" centers typical	
☐	Kitchen sink - drain	16" AFF typical	Centered on sink	
☐	Kitchen sink - vent connection	Per code requirements		
☐	Dishwasher - hot supply	12" AFF, behind kickplate	Near sink connection	
☐	Dishwasher - drain connection	High loop or air gap	Connect to disposal/sink	
☐	Dishwasher shut-off valve location	Accessible under sink		
☐	Garbage disposal - drain	Connection to sink drain	Per disposal specs	
☐	Ice maker supply line	To refrigerator location	1/4" copper or PEX	
☐	Pot filler supply (if appl.)	Height per range specs	Hot water supply	
☐	Instant hot water dispenser (if appl.)	Supply and mounting		
☐	Gas line for range/cooktop (if appl.)	Proper size and shutoff	Per appliance specs	

Kitchen Notes:

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 5
LAUNDRY ROOM

✓	Fixture/Location	Rough-In Height/Spec	Spacing	Notes
☐	Washer - hot supply	42" AFF typical	6" apart	
☐	Washer - cold supply	42" AFF typical	6" apart	
☐	Washer - drain standpipe	42"-48" AFF	2" diameter minimum	
☐	Washer drain - P-trap installed	Below floor/wall	Accessible	
☐	Washer drain - vent connection	Per code requirements		
☐	Washer box recessed (if appl.)	Flush with finished wall	Between studs	
☐	Gas line for dryer (if appl.)	Behind dryer location	1/2" line with shutoff	
☐	Utility sink - hot supply	18" AFF	8" centers	
☐	Utility sink - cold supply	18" AFF	8" centers	
☐	Utility sink - drain	16" AFF	Centered	
☐	Floor drain (if required)	Proper slope to drain	Per code	

POWDER ROOM / HALF BATH

✓	Fixture/Location	Rough-In Height/Spec	Spacing	Notes
☐	Toilet - cold supply stub	6"-8" AFF, left side	12" from wall	
☐	Toilet - drain rough-in	Per toilet spec	12" typical	
☐	Sink - hot supply	21" AFF	8" centers	
☐	Sink - cold supply	21" AFF	8" centers	
☐	Sink - drain	16" AFF	Centered	

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 6
EXTERIOR PLUMBING

✓	Item/Location	Specification	Notes
☐	Front hose bib	☐ Standard ☐ Frost-proof	
☐	Back hose bib	☐ Standard ☐ Frost-proof	
☐	Side yard hose bib(s) - count: ____	☐ Standard ☐ Frost-proof	
☐	Hose bibs have shutoff valves inside	Required for winterization	
☐	Hose bibs slope down for drainage	Prevent freezing	
☐	HVAC condensate drain line	3/4" PVC typical	
☐	Condensate drain terminates properly	Away from foundation	
☐	Gas meter location (if applicable)	Accessible, proper clearances	
☐	Gas line sizing adequate	Per appliance load calculation	
☐	Irrigation system connection (if appl.)	Location: _____	

WATER HEATER ROUGH-IN

✓	Item	Specification	Notes
☐	Cold water supply to heater	3/4" minimum	
☐	Hot water outlet from heater	3/4" minimum	
☐	Shut-off valve on cold supply	Required	
☐	TPR valve discharge pipe rough-in	3/4" to within 6" of floor	
☐	Drain pan drain (if required)	To approved location	
☐	Gas line for gas WH (if appl.)	Proper size per BTU rating	
☐	Combustion air provisions (gas)	Per code requirements	
☐	Water heater location accessible 	Service clearances maintained	© 2024 Build Your House

☐	Expansion tank provision (if req.)	On cold supply side	
--------------------------	------------------------------------	---------------------	--

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 7
DWV (DRAIN-WASTE-VENT) SYSTEM

✓	Item	Specification	Notes
☐	Main drain line size	3" or 4" per code	
☐	Main drain slope adequate	1/4" per foot minimum	
☐	Main stack vent size	3" or 4" to roof	
☐	Stack vent extends through roof	Flashed and sealed	
☐	Branch drain sizes adequate	Per fixture unit load	
☐	Toilet drain line size	3" minimum	
☐	Shower drain line size	2" minimum	
☐	Sink drain line size	1.5" minimum	
☐	Washing machine drain size	2" minimum	
☐	All fixtures have proper trap	P-traps correctly installed	
☐	Traps accessible for service	Not buried in concrete	
☐	All fixtures properly vented	Per code requirements	
☐	Vent pipe sizing adequate	1.5" or 2" typical	
☐	Vent penetrations through roof flashed	Watertight	
☐	Vent terminals above roof surface	6" minimum, 12" in snow areas	
☐	AAVs (Air Admittance Valves) if used	☐ Used ☐ Not used	
☐	AAVs accessible if used	Not sealed in walls	
☐	Cleanout(s) installed	Accessible locations	
☐	Cleanout at base of stack	Required	
☐	Cleanout(s) at direction changes	If required by code	

DWV SYSTEM (CONTINUED)

✓	Item	Specification	Notes
☐	No improper fittings used in drains	DWV fittings only	
☐	All joints properly glued/assembled	No dry fits	
☐	All drain lines properly supported	Per code spacing	
☐	Pipe penetrations through framing adequate	Not weakening structure	
☐	Underground drains properly bedded	Sand or approved material	
☐	Connection to septic/sewer verified	Proper slope and connection	

DWV System Notes:

PRESSURE TEST RECORD

Water Supply System Pressure Test

Test Date: _____ Time: _____

Test Pressure: _____ PSI

Test Duration: _____ hours/minutes

Test Medium: ☐ Water ☐ Air

Test Results:

☐ PASSED - No leaks detected, pressure maintained

☐ FAILED - Leaks found (describe below)

Leak Locations (if any):

Repairs Made:

Date: _____ Plumber: _____

Re-Test Results (if applicable):

Re-Test Date: _____ PSI: _____

Result: ☐ PASSED ☐ FAILED

GENERAL PLUMBING QUALITY CHECKS

✓	Item	Notes
☐	All supply lines properly supported/strapped	
☐	Strapping/support spacing per code	
☐	No pipes in exterior walls (if possible)	
☐	Pipes in exterior walls insulated/protected	
☐	Pipes through penetrations protected	
☐	Nail plates over pipes within 1.25" of framing edge	
☐	All penetrations will be fire-stopped	
☐	Proper clearance from electrical	
☐	All connections tight and secure	
☐	Correct materials used throughout	
☐	Transitions between materials proper	
☐	Shower valves backing/blocking installed	
☐	Tub/shower valve access provided	
☐	Water hammer arrestors installed if needed	
☐	Stub-outs capped/protected during construction	
☐	Rough-in dimensions verified with fixtures	
☐	All required shut-off valves planned	

Additional Plumbing Notes:

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 10

INSPECTION RESULTS & CORRECTIONS**Initial Plumbing Rough-In Inspection**

Inspection Date: _____ Time: _____

Inspector Name: _____

Inspector Badge/ID: _____

Result: ☐ PASSED ☐ FAILED - Corrections Required**Deficiencies/Code Violations Found:****Corrections Made**

Date Corrections Completed: _____

Licensed Plumber: _____ License #: _____

Description of Corrections:**Re-Inspection (if required)**

Re-Inspection Date: _____ Time: _____

Inspector Name: _____

Result: ☐ PASSED ☐ FAILED - Additional Corrections Required**Additional Comments:**

Final Sign-Off

Owner/Builder Signature: _____ Date: _____

Licensed Plumber Signature: _____ Date: _____

Inspector Signature: _____ Date: _____

Permit Number: _____ Final Approval: ☐ YES