

3.5 INSULATION & AIR SEALING GUIDE

Project Information

Property Address: _____

Permit Number: _____ Inspection Date: _____

Insulation Contractor: _____

Phone: _____ License #: _____

INSULATION SCHEDULE

Location	Insulation Type	R-Value Required	R-Value Installed	Notes
Exterior Walls	☐ Fiberglass ☐ Spray Foam ☐ Cellulose ☐ Mineral Wool			
Ceiling/Attic	☐ Blown-in ☐ Batt ☐ Spray Foam ☐ Rigid Board			
Cathedral Ceiling	☐ Spray Foam ☐ Batt + Rigid ☐ Other: _____			
Floor (over uncond. space)	☐ Fiberglass ☐ Spray Foam ☐ Rigid Board			
Basement Walls	☐ Rigid Board ☐ Spray Foam ☐ Batt ☐ N/A			
Crawlspace Walls	☐ Rigid Board ☐ Spray Foam ☐ N/A			
Crawlspace Floor (if vented)	☐ Batt ☐ Spray Foam ☐ N/A			
Rim Joist	☐ Spray Foam ☐ Rigid + Caulk ☐ Batt (not recommended)			
Garage Ceiling (if cond. above)	☐ Batt ☐ Blown-in ☐ N/A			© 2024 Build Your House

Knee Walls	☐ Batt ☐ Spray Foam ☐ N/A			
------------	--	--	--	--

Climate Zone & Code Requirements

Climate Zone: _____ (IECC Climate Zone Map)

Minimum R-Values per Code:
Walls: R-_____ Ceiling: R-_____ Floor: R-

Energy Code Version: _____

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 2

AIR SEALING CHECKLIST**Top Plates & Framing Penetrations**

✓	Item	Notes
☐	Top plates of exterior walls sealed to drywall/sheathing	
☐	Top plates of interior walls sealed (if attic above)	
☐	Bottom plates sealed to subfloor	
☐	Rim joist sealed to sill plate	
☐	Rim joist sealed to subfloor	
☐	Band joist/rim joist fully insulated and sealed	
☐	All wall-to-floor intersections sealed	
☐	All wall-to-ceiling intersections sealed	

Electrical Penetrations

✓	Item	Notes
☐	Electrical boxes in exterior walls sealed to drywall	
☐	Airtight electrical box gaskets installed (if applicable)	
☐	Wire penetrations through plates sealed with foam/caulk	
☐	Service panel penetrations sealed	
☐	Recessed lights IC-rated for contact with insulation	
☐	Non-IC recessed lights have airtight cover box	
☐	Recessed lights sealed to drywall	

Plumbing Penetrations

✓	Item	Notes
☐	Plumbing pipes through plates sealed with foam	
☐	Plumbing stack penetrations through attic sealed	
☐	Bathtub/shower plumbing wall sealed at access	
☐	Under-sink cabinet backs sealed (exterior walls)	
☐	Basement/crawlspace plumbing penetrations sealed	

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 3
AIR SEALING CHECKLIST (CONTINUED)
HVAC Penetrations

✓	Item	Notes
☐	HVAC duct boots sealed to drywall/subfloor	
☐	Supply register boots sealed airtight	
☐	Return air grille boots sealed airtight	
☐	Ductwork penetrations through top plates sealed	
☐	Bathroom exhaust fan housing sealed to drywall	
☐	Kitchen range hood duct sealed at penetrations	
☐	Dryer vent sealed at all penetrations	
☐	Combustion appliance vents sealed at penetrations	

Window & Door Rough Openings

✓	Item	Notes
☐	Window rough openings sealed with foam before install	
☐	Door rough openings sealed with foam before install	
☐	Window/door frames caulked to rough opening	
☐	Window/door frames sealed to exterior sheathing	
☐	Windows/doors shimmed and spaces foamed (not overfilled)	

Attic & Ceiling Penetrations

✓	Item	Notes
☐	Attic access door/hatch weatherstripped	
☐	Attic access door/hatch insulated on top	
☐	Pull-down attic stairs insulated cover installed	
☐	Chimney chase sealed and insulated at attic floor	
☐	Chimney clearances to combustibles maintained	
☐	Dropped ceilings/soffits sealed at top	
☐	Knee wall access doors weatherstripped/insulated	© 2024 Build Your House
☐	All ceiling penetrations (wires, pipes) sealed	

Owner-Builder Job Site Binder | Section 3: Rough-In Phase | Page 4

AIR SEALING & INSULATION QUALITY**General Air Sealing**

✓	Item	Notes
☐	Garage walls/ceiling to house sealed (fire barrier)	
☐	Cantilever floors sealed and insulated	
☐	Stairwell walls to unconditioned space sealed	
☐	Behind tubs/showers on exterior walls sealed	
☐	Fireplace firebox sealed to framing	

Vapor Barrier

✓	Item	Notes
☐	Vapor barrier required per climate zone	☐ Yes ☐ No
☐	Vapor barrier type used	☐ Poly ☐ Kraft-faced ☐ N/A
☐	Vapor barrier on warm side of insulation	
☐	Vapor barrier overlapped at seams (6" minimum)	
☐	Vapor barrier sealed at penetrations	
☐	No double vapor barriers created	

Insulation Installation Quality

✓	Item	Notes
☐	Batt insulation completely fills cavities (no gaps)	
☐	Batt insulation not compressed (reduces R-value)	
☐	Insulation split around wires/pipes (not behind)	
☐	Insulation tight to electrical boxes	
☐	Blown insulation to proper depth/density	
☐	Spray foam properly expanded (not overspray)	
☐	Proper ventilation maintained (if vented attic)	
☐	Soffit vents not blocked by insulation	
☐	Attic ventilation baffles installed	
☐	Attic insulation depth markers/rulers installed	© 2024 Build Your House

Final Notes:

Inspection Sign-Off

Owner/Builder: _____ Date: _____

Insulation Contractor: _____ Date:

Inspector: _____ Date: _____

Result: ☐ PASSED ☐ Corrections Required