



Certificate of Compliance

This certificate is issued for the following:

Angle Hose Valves

Model No	Description	Valve Size, in (mm)		Rated Working Pressure, psi (kPa)	
J282-121	Pressure Restricting Hose Valve Female NPT x Male NH, Female NPT x Female NPT	1 1/2	(38)	300	(2070)
J282-221	Pressure Restricting Hose Valve Female NPT x Male NH, Female NPT x Female NPT, Rc x M78x2	2 1/2	(64)	300	(2070)

Prepared for:

Beijing Synergy Technology Co Ltd
B-5 Floor, 06B06, Tianyuangang
Dongsanhuan North, Beijing,
China

FM Approvals Class: 1521

Approval Identification: PR455534

Approval Granted: November 1, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

February 20, 2023

Date

