



Chengxia Sun
BEIJING SYNERGY TECHNOLOGY CO LTD
2-309 NO16 NANSANHUAN AVE FENGTAI DIST
BEIJING CHINA

Date: 2016/08/03
Subscriber: 1620997
PartySite:
File No:
Order No: 11371236
Project Number: 16OR11371236
PD No: 16029537
PO Number:

Subject: Multiple Listing Correlation Sheet

Dear Chengxia Sun,

Enclosed is a copy of your completed Multiple Listing Correlation Sheet covering the Basic File listed below. The following documents were added (new) or revised on 08/03/2016.

<u>Basic File</u>	<u>Vol</u>	<u>ML File</u>	<u>Pages</u>	<u>Revised</u>	<u>New</u>
EX16364	1	EX27225	New ML Correlation Page(s)		

Please review this material and report any inaccuracies to GUANG YA ZHANG (EXT. 67132) referring to the above Order number.

This material is provided on behalf of UL LLC(UL) or any authorized licensee of UL.

NBK File



Multiple Listing Correlation Sheet

ML FILE NO. EX27225

Issued: 2016-08-03

MULTIPLE LISTING
of
HOSE VALVES
(VTSR)
for

[1620997]

BEIJING SYNERGY TECHNOLOGY CO LTD

Basically Listed products covered by Procedure and/or Reports under File No. EX16364, Volume 1

Products Covered	Report Date	Basic Applicant's (Supplier's) Product Designation	Multiple Listee's Product Designation
Angle types, 1-1/2 and 2-1/2 in., with a maximum working pressure of 300 psi, for use on a fire hose rack assembly, or as a fire department outlet connection	2014-01-08	J281	Female x male SNG115 Female x female: SNG116

MARKING: Same as that described in Follow-Up Service Procedure and/or Report except for Multiple Listee's name, file number, Trademark / Tradename, when applicable, and product designation. The Control Number remains [5EE7].

LITERATURE: If literature is packaged with the Multiple Listed product(s) it shall be in compliance with the requirements outlined in the appropriate UL Standard(s).