

VNIV.EX27834 - Sprinklers, Automatic and Open

Sprinklers, Automatic and Open

[See General Information for Sprinklers, Automatic and Open](#)

ZHEJIANG KSFCO FIRE FIGHTING EQUIPMENT CO., LTD.
MIAOPU, DIANKOU TOWN,
ZHUJI, ZHEJIANG 201204 CHINA
Sprinkler Identification Number (SIN) KS801, KS802, KS803, KS804, KS805 and KS806 Glass Bulb Type.

EX27834

PENDENT AND UPRIGHT STANDARD-SPRAY SPRINKLERS
NOMINAL 5.6 K-FACTOR

SIN	Response Type	Type	System Working Pressure, psig	Temp Rating, °F
KS801	SR	Pendent	175	135, 155, 175, 200, 286
KS802	QR	Pendent	175	135, 155, 175, 200, 286
KS803	SR	Upright	175	135, 155, 175, 200, 286
KS804	QR	Upright	175	135, 155, 175, 200, 286

STANDARD SIDEWALL-SPRAY SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	System Working Pressure, psig	Temp Rating, °F
KS805*	SR	Horizontal	5.6	175	135, 155, 175, 200, 286
KS806*	QR	Horizontal	5.6	175	135, 155, 175, 200, 286

+ For installation 4 to 12 in. below ceiling.

Trademark and/or Tradename: **KSFCO®**

[Last Updated](#) on 2021-02-02

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."