



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, inch	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 10 ^{a, c, d, e, g, m, n, s}	China	1, 1-1/4, 1-1/2, 2	175	1205	FM Approved
Schedule 10 ^{a, c, d, e, m, n, s, t}	China	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10	175	1205	FM Approved

Notes:

- a - FM Approved for use with FM Approved pipe couplings on rolled grooves.
- c - FM Approved for use in welded systems when supplied with standard bevel on ends.
- d - When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems.
- e - Any FM Approved pipe coupling or fitting suitable for use with Schedule 10 pipe may be used with this product at the lower rated pressure of the pipe or the fitting.
- g - FM Approved for use with plain-end fittings.
- m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe.
- n - FM Approved for use in hybrid sprinkler systems composed of uncoated steel and plastic piping.
- s - Manufactured out of ASTM A795 / A795M Grade A or B steel.
- t - Pipe 8 in. or larger is FM Approved with a wall thickness of 0.188 in., which is above ASME B36.10 specifications for Sch 10 pipe.

Prepared for:

Tianjin City Baolai Industrial and Trade Co Ltd
NO.6, Haihe Road, Daquzhuang Town, Jinghai District, Tianjin
China

FM Approvals Class: 1630 (June 2021) – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: PR462212

Approval Granted: 20 February 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062





Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, inch	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 40 ^{a, b, c, d, e, g, m, n, p, s}	China	1, 1-1/4, 1-1/2, 2	175	1205	FM Approved
Schedule 40 ^{a, b, c, d, e, g, m, n, p, s}	China	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10	200	1375	FM Approved

Notes:

- a - FM Approved for use with FM Approved pipe couplings on rolled grooves.
- b - FM Approved for use with FM Approved pipe fittings when threaded
- c - FM Approved for use in welded systems when supplied with standard bevel on ends.
- d - When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems.
- e - Any FM Approved pipe coupling or fitting suitable for use with Schedule 10 pipe may be used with this product at the lower rated pressure of the pipe or the fitting.
- g - FM Approved for use with plain-end fittings.
- m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe.
- n - FM Approved for use in hybrid sprinkler systems composed of uncoated steel and plastic piping.
- p - Manufactured out of ASTM A53 / A53M Grade A or B steel.
- s - Manufactured out of ASTM A795 / A795M Grade A or B steel.

Prepared for:

Tianjin City Baolai Industrial and Trade Co Ltd
NO.6, Haihe Road, Daqiu Zhuang Town, Jinghai District, Tianjin
China

FM Approvals Class: 1630 (June 2021) – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: PR462212

Approval Granted: 20 February 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062



Member of the FM Global Group

