Company Name	LoremIpsum	Project Title	Fossee
Group/Team Name	LoremIpsum	Subtitle	
Designer	LoremIpsum	Job Number	123
Date	29 /04 /2020	Client	LoremIpsum

1 Input Parameters

Module		Fin Plate	
MainModule		Shear Connection	
Connectivity		Column flange-Beam web	
Shear(kN)*		1.0	
Supporting Section			
	Supporting Section	HB 200	
	Material *	E 250 (Fe 410 W)A	
	Ultimate strength, fu (MPa)	410	
	Yield Strength , fy (MPa)	230	
	Mass 37.3	Iz(cm4)	36000000.0
	Area(cm2) - A 4750.0	Iy(cm4)	9670000.0
	D(mm) 200.0	rz(cm)	87.10000000000001
	B(mm) 200.0	ry(cm)	45.099999999999994
	t(mm) 6.1	Zz(cm3)	361000.0
	T(mm) 9	Zy(cm3)	96700.0
	FlangeSlope 94	Zpz(cm3)	361000.0
	R1(mm) 9.0	Zpy(cm3)	96700.0
	R2(mm) 4.5		
Supported Section			
	Supported Section	JB 225	
	Material *	E 250 (Fe 410 W)A	
	Ultimate strength, fu (MPa)	410	
	Yield Strength , fy (MPa)	230	
	Mass 12.8	Iz(cm4)	13100000.0
	Area(cm2) - A 1630.0	Iy(cm4)	405000.0
	D(mm) 225.0	rz(cm)	89.7
	B(mm) 80.0	ry(cm)	15.8
	t(mm) 3.7	Zz(cm3)	116000.0
	T(mm) 5.0	Zy(cm3)	10100.0
	FlangeSlope 91.5	Zpz(cm3)	116000.0
	R1(mm) 6.5	Zpy(cm3)	10100.0
	R2(mm) 1.5		
Bolt Details			
Diameter(mm)*		[12.0, 16.0, 20.0, 24.0, 30.0, 36.0]	
Grade *		[3.6, 4.6, 4.8, 5.6, 5.8, 6.8, 8.8, 9.8, 10.9, 12.9]	
Type *		Bearing Bolt	
Bolt hole type		Standard	
Slip factor (μ_f)		0.3	
Type of edges		a - Sheared or hand flame cut	

Company Name	LoremIpsum	Project Title	Fossee
Group/Team Name	LoremIpsum	Subtitle	
Designer	LoremIpsum	Job Number	123
Date	29 /04 /2020	Client	LoremIpsum

Gap between beam and support (mm)	10.0
Are the members exposed to corrosive influences	False
Weld Details	
Weld Type	Fillet
Type of weld fabrication	Shop Weld
Material grade overwrite (MPa) Fu	410.0

2 Design Checks

2.1 Bolt Design Checks

Check	Required	Provided	Remarks
Shear Capacity (kN)		$V_{dsb} = \frac{f_u b\ n_n\ A_{nb}}{\sqrt{3}\ \gamma_{mb}}$ $= \frac{410 * 1 * 84.3}{\sqrt{3}\ *\ 1.25}$ $= 11.68$	
Bearing Capacity (kN)		$V_{dpb} = \frac{2.5\ k_b\ d\ t\ f_u}{\gamma_{mb}}$ $= \frac{2.5\ * 0.52 * 12.0 * 3.7 * 410}{1.25}$ $= 11.68$	
Capacity (KN)		$V_{db} = min\ (V_{dsb}, V_{dpb})$ $= min\ (11.68, 11.68)$ $= 11.68$	
No of Bolts	$R_u = \sqrt{V_u^2 + A_u^2}$ $n_{trial} = R_u / V_{bolt}$ $R_u = \frac{\sqrt{1.0^2 + 1.0^2}}{11.68}$ $= 1$	2	
No of Columns		1	
No of Rows		2	
Min. Pitch (mm)	$p/g_{min} = 2.5\ d$ $=2.5 * 12.0 \quad = 30.0$	0.0	N/A
Max. Pitch (mm)	$p/g_{max} = \min(32\ t,\ 300\ mm)$ $= \min(32 *\ 3.7,\ 300\ mm)$ $= 300$	0.0	N/A
Min. Gauge (mm)	$p/g_{min} = 2.5\ d$ $=2.5 * 12.0 \quad = 30.0$	85	Pass
Max. Gauge (mm)	$p/g_{max} = \min(32\ t,\ 300\ mm)$ $= \min(32 *\ 3.7,\ 300\ mm)$ $= 300$	85	Pass
Min. End Distance (mm)	$e/e`_{min} = [1.5\ or\ 1.7] * d_0$ $= 1.7 * 13.0 = 22.1$	25	Pass

Company Name	LoremIpsum	Project Title	Fossee
Group/Team Name	LoremIpsum	Subtitle	
Designer	LoremIpsum	Job Number	123
Date	29 /04 /2020	Client	LoremIpsum

Check	Required	Provided	Remarks
Max. End Distance (mm)	$e/e`_{max} = 12\ t\ \varepsilon$ $\varepsilon = \sqrt{\frac{250}{f_y}}$ $e/e`_{max} = 12\ * 4.0 * \sqrt{\frac{250}{230}}$ $= 49.92$	25	Pass
Min. Edge Distance (mm)	$e/e`_{min} = [1.5\ or\ 1.7] * d_0$ $= 1.7 * 13.0 = 22.1$	25	Pass
Max. Edge Distance (mm)	$e/e`_{max} = 12\ t\ \varepsilon$ $\varepsilon = \sqrt{\frac{250}{f_y}}$ $e/e`_{max} = 12\ * 4.0 * \sqrt{\frac{250}{230}}$ $= 49.92$	25	Pass
Capacity (KN)	1039.86	11680.95	Pass

2.2 Plate Design Checks

Check	Required	Provided	Remarks
Min. Plate Height (mm)	$0.6 * d_b = 0.6 * 225.0 = 135.0$	135	Pass
Max. Plate Height (mm)	$d_b - 2(t_{bf} + r_{b1} + gap)$ $= 225.0 - 2 * (5.0 + 6.5 + 10)$ $= 202.0$	135	Pass
Min. Plate Length (mm)	$2 * e_{min} + (n\ c - 1) * p_{min})$ $= 2 * 22.1 + (1 - 1) * 30.0$ $= 54.2$	60.0	Pass
Min.Plate Thickness (mm)	$t_w = 3.7$	4.0	Pass
Shear yielding Capacity (V_dy) (kN)		$V_{dg} = \frac{A_v * f_y}{\sqrt{3} * \gamma_{mo}}$ $= \frac{135 * 4.0 * 230}{\sqrt{3} * 1.1}$ $= 39.11$	
Shear Rupture Capacity (V_dn) (kN)		$V_{dn} = \frac{0.75 * A_{vn} * f_u}{\sqrt{3} * \gamma_{mo}}$ $= 1 * (135 - (2 * 13.0)) * 4.0 * 410$ $= 134.07$	
Block Shear Capacity in Shear (V_db) (kN)		79.79	
Shear Capacity (V_d) (kN)	1.0	$V_d = Min(V_{dy}, V_{dn}, V_{db})$ $= Min(39.11, 134.07, 79.79)$ $= 39.11$	Pass

Company Name	LoremIpsum	Project Title	Fossee
Group/Team Name	LoremIpsum	Subtitle	
Designer	LoremIpsum	Job Number	123
Date	29 /04 /2020	Client	LoremIpsum

Check	Required	Provided	Remarks
Tension Yielding Capacity (kN)		$T_{dg} = \frac{l * t * f_y}{\gamma_{mo}} = \frac{60.0 * 4.0 * 230}{\sqrt{3} * 1.1} = 50.18$	
Tension Rupture Capacity(kN)		$T_{dn} = \frac{0.9 * A_n * f_u}{\gamma_{m1}} = \frac{0.9 * (60.0 - 2 * 13.0) * 4.0 * 410}{1.25} = 55.5$	
Block Shear Capacity in Tension (T_db) (kN)		79.79	
Tension Capacity (kN)	1.0	$T_d = Min(T_{dg}, T_{dn}, T_{db}) = Min(50.18, 55.5, 79.79) = 50.18$	Pass
Moment Capacity (kNm)	0.04	3.05	Pass
Interaction Ratio	≤ 1	$\frac{0.04}{3.05} + \frac{1.0}{50.18} = 0.03$	Pass

2.3 Weld Checks

Check	Required	Provided	Remarks
Min Weld Size (mm)	$Thickness\ of\ Thicker\ part = Max(9, 9) = 9$ $IS800:2007\ cl.10.5.2.3\ Table21,\ t_{w_{min}} = 3$	3	Pass
Max Weld Size (mm)	$Thickness\ of\ Thinner\ part = Min(9, 9) = 4.0$ $t_{w_{max}} = 4.0$	3	Pass
Weld Strength (kN/mm)	$R_w = \sqrt{(T_{wh} + A_{wh})^2 + (T_{wv} + V_{wv})^2}$ $T_{wh} = \frac{M * y_{max}}{Ipw} = \frac{35000.0 * 64.5}{357781.5}$ $T_{wv} = \frac{M * x_{max}}{Ipw} = \frac{35000.0 * 0.0}{357781.5}$ $V_{wv} = \frac{V}{l_w} = \frac{1000.0}{258}$ $A_{wh} = \frac{A}{l_w} = \frac{1000.0}{258}$ $R_w = \sqrt{(6.31 + 3.88)^2 + (0.0 + 3.88)^2} = 10.9$	$f_w = \frac{t_t * f_u}{\sqrt{3} * \gamma_{mw}} = \frac{3 * 410}{\sqrt{3}} * 1.25 = 568.11$	Pass

Company Name	LoremIpsum	Project Title	Fossee
Group/Team Name	LoremIpsum	Subtitle	
Designer	LoremIpsum	Job Number	123
Date	29 /04 /2020	Client	LoremIpsum

3 3D View



Figure 1: 3D View