
CASA ÁNGEL · CLIMATIZACIÓN · FICHA CI-PA-01 · BAÑO PA

01. Planta Alta · 33,35 ml · 5,81 m² · 5,74 m/m² · CO-S S01 · completo

CI-PA-01 · planta 1:25



Datos del circuito 1:10

Ficha CI-PA-01

Local: Baño PA · 01. Planta Alta
Circuito: CI-PA-01
Tubo PEX Ø20: 33,35 ml (ida 22,22 · retorno 11,13)
Superficie servida: 5,81 m²
Densidad: 5,74 m/m² · paso equivalente 0,17 m
Colector: CO-S · salida S01
Termostato: (ninguno en el modelo)
Estado: completo (completo ≥ 4 m/m²)

Referencias

Trazo de color: serpentín de este circuito sobre el eje del tubo del modelo
Cuadrado: termostato · arquitectura vinculada en medio tono
Cotas: extensión del serpentín (m)

Climatización R32 (archivo de documentación con el modelo principal vinculado). Piso radiante: serpentines PEX Ø20 (mando + retorno) trazados sobre el eje de cada tubo del modelo; colector de cada circuito por conectividad de tubos y accesorios. Densidad completa ≥ 4 m/m². Bomba de calor: no modelada.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

No.	Description	Date

Angel Luis Brusca

CASA ANGEL

CLI-F-CI-PA-01

Project number	0001
Date	18 de Agosto, 2025
Drawn by	Author
Checked by	Checker
Climatiz. · CI-PA-01	
Scale	As indicated

10/26/2026 10:06:22 AM