
CASA ÁNGEL · CLIMATIZACIÓN · FICHA CI-PA-04 · COMEDOR

01. Planta Alta · 157,95 ml · 23,26 m² · 6,79 m/m² · CO-N S07 · completo

CI-PA-04 · planta 1:50



Datos del circuito 1:10

Ficha CI-PA-04

Local: Comedor · 01. Planta Alta
Circuito: CI-PA-04
Tubo PEX Ø20: 157,95 ml (ida 89,26 · retorno 68,69)
Superficie servida: 23,26 m²
Densidad: 6,79 m/m² · paso equivalente 0,15 m
Colector: CO-N · salida S07
Termostato: TE-10
Estado: completo (completo ≥ 4 m/m²)

Referencias

Trazo de color: serpentín de este circuito sobre el eje del tubo del modelo
Cuadrado: termostato · arquitectura vinculada en medio tono
Cotas: extensión del serpentín (m)

Climatización R32 (archivo de documentación con el modelo principal vinculado). Piso radiante: serpentines PEX Ø20 (mando + retorno) trazados sobre el eje de cada tubo del modelo; colector de cada circuito por conectividad de tubos y accesorios. Densidad completa ≥ 4 m/m². Bomba de calor: no modelada.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

No.	Description	Date

Angel Luis Brusca

CASA ANGEL

CLI-F-CI-PA-04

Project number	0001
Date	18 de Agosto, 2025
Drawn by	Author
Checked by	Checker

Climatiz. · CI-PA-04

Scale As indicated

10/26/2026 10:06:25 AM