
# CASA ÁNGEL · CLIMATIZACIÓN · FICHA CI-PB-11 · PASILLO

**00. Planta Baja · 133,58 ml · 26,08 m² · 5,12 m/m² · CO-S S10 · completo**

**CI-PB-11 · planta 1:50**




**Datos del circuito 1:10**

**Ficha CI-PB-11**

Local: Pasillo · 00. Planta Baja
Circuito: CI-PB-11
Tubo PEX Ø20: 133,58 ml (ida 63,56 · retorno 70,02)
Superficie servida: 26,08 m²
Densidad: 5,12 m/m² · paso equivalente 0,20 m
Colector: CO-S · salida S10
Termostato: (ninguno en el modelo)
Estado: completo (completo ≥ 4 m/m²)

**Referencias**

Trazo de color: serpentín de este circuito sobre el eje del tubo del modelo
Cuadrado: termostato · arquitectura vinculada en medio tono
Cotas: extensión del serpentín (m)

Climatización R32 (archivo de documentación con el modelo principal vinculado). Piso radiante: serpentines PEX Ø20 (mando + retorno) trazados sobre el eje de cada tubo del modelo; colector de cada circuito por conectividad de tubos y accesorios. Densidad completa ≥ 4 m/m². Bomba de calor: no modelada.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

| No. | Description | Date |
|---|---|---|
| | | |

Angel Luis Brusca

CASA ANGEL

CLI-F-CI-PB-11

| | |
|---|---|
| Project number | 0001 |
| Date | 18 de Agosto, 2025 |
| Drawn by | Author |
| Checked by | Checker |
| Climatiz. · CI-PB-11 | |
| Scale | As indicated |

10/26/2026 10:06:43 AM