# CASA ÁNGEL · CLIMATIZACIÓN · ÍNDICE, CRITERIOS Y CÓMPUTO

## Criterios

CI: serpentín por local (tramos horizontales del nivel).
DI: distribución y montantes fuera de locales.
Densidad de referencia: paso 15 cm ≈ 6,7 m/m².
Códigos solo como anotación (no en Mark).

## Cómputo

PB: 554,83 ml en 14 locales
PA: 538,68 ml en 10 locales
PE: 96,44 ml en 2 locales
Distribución/montantes: 209,56 ml
Total PEX Ø20: 1399,51 ml
Locales con densidad completa (≥ 4 m/m²): 7 de 26
Colectores: CO-N (SM, PE) y CO-S (Sala de Máquinas, PA)
Termostatos: 11

## Láminas

CLI-00 Índice
CLI-F-CI-PA-01
CLI-F-CI-PA-02
CLI-F-CI-PA-03
CLI-F-CI-PA-04
CLI-F-CI-PA-05
CLI-F-CI-PA-06
CLI-F-CI-PA-07
CLI-F-CI-PA-08
CLI-F-CI-PA-09
CLI-F-CI-PA-10
CLI-F-CI-PB-01
CLI-F-CI-PB-02
CLI-F-CI-PB-03
CLI-F-CI-PB-04
CLI-F-CI-PB-05
CLI-F-CI-PB-06
CLI-F-CI-PB-07
CLI-F-CI-PB-08
CLI-F-CI-PB-09
CLI-F-CI-PB-10
CLI-F-CI-PB-11
CLI-F-CI-PB-12
CLI-F-CI-PB-13
CLI-F-CI-PB-14
CLI-F-CI-PE-01
CLI-F-CI-PE-02
CLI-F-CO-N
CLI-F-CO-S
CLI-PA-01
CLI-PB-01
CLI-PE-01

## No modelado / a definir

Bomba de calor inverter (no modelada).
Circuito por salida de colector (sin sistemas propios).
Retorno clasificado como impulsión (Hydronic Supply).
Locales con densidad baja: trazado parcial.
Tanque de inercia, vaso de expansión, válvulas.

Climatización: piso radiante con serpentines PEX Ø20 (mando + retorno) según el modelo. Longitudes por local tomadas en el nivel de cada tramo. Bomba de calor, circuitos por salida de colector y sistemas de retorno: no modelado / a definir.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

| No. | Description | Date |
|---|---|---|

Angel Luis Brusca

CASA ANGEL

CLI-00

| | |
|---|---|
| Project number | 0001 |
| Date | 18 de Agosto, 2025 |
| Drawn by | Author |
| Checked by | Checker |

Climatización · índice

Scale

10/23/2026 7:46:00 PM