
CASA ÁNGEL · CLIMATIZACIÓN · CIRCUITO CI-PB-14 · VESTIDOR PPAL


CI-PB-14 · Vestidor ppal · 15,99 ml · 2,11 m/m²

CI-PB-14 · planta 1:20



CI-PB-14 · Vestidor ppal · 15,99 ml · 2,11 m/m²
Mando 11,09 ml · Retorno 4,91 ml · Local 7,57 m²
Densidad 2,11 m/m² (paso 15 cm = 6,7 m/m²) · incompleto o solo distribución (densidad < 4 m/m²)
Sistemas Revit: Hydronic Supply 1

CI-PB-14 · axonométrica 1:20



Climatización: piso radiante con serpentines PEX Ø20 (mando + retorno) según el modelo. Longitudes por local tomadas en el nivel de cada tramo. Bomba de calor, circuitos por salida de colector y sistemas de retorno: no modelado / a definir.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

No.	Description	Date

Angel Luis Brusca

CASA ANGEL

CLI-F-CI-PB-14

Project number	0001
Date	18 de Agosto, 2025
Drawn by	Author
Checked by	Checker
Scale	1 : 20

Climatización · CI-PB-14

10/23/2026 5:45 PM