CASA ÁNGEL · CLIMATIZACIÓN · ÍNDICE (R32)

Láminas R32 (etapas 1 y 2)

CLI-00 Índice
CLI-P-PB Planta Baja · serpentines
CLI-P-PA Planta Alta · serpentines
CLI-P-PE Entrepiso · serpentines
CLI-CO-N Colector Norte · planta, alzado, salidas
CLI-CO-S Colector Sur · planta, alzado, salidas
R19: plantas y fichas previas (las fichas por local se reemplazan en la etapa 3)

Por nivel

CLI-P-PB: 14 circuitos · 554,83 ml · 173,91 m² · distr. 45,76 ml
CLI-P-PA: 10 circuitos · 538,68 ml · 130,54 m² · distr. 87,67 ml
CLI-P-PE: 2 circuitos · 96,44 ml · 25,92 m² · distr. 76,13 ml

Por colector

CO-N: 14 circuitos
CO-S: 12 circuitos
CO-N: CI-PB-04, CI-PB-08, CI-PB-09*, CI-PB-10*, CI-PB-12, CI-PB-13*, CI-PB-14, CI-PA-02, CI-PA-03, CI-PA-04, CI-PA-05, CI-PA-06, CI-PA-08, CI-PA-09, CI-PA-10, CI-PE-01, CI-PE-02
CO-S: CI-PB-01, CI-PB-02*, CI-PB-03, CI-PB-05, CI-PB-06*, CI-PB-07, CI-PB-11, CI-PA-01, CI-PA-06, CI-PA-07*, CI-PA-11, CI-PE-03, CI-PE-04
* asignado por cercanía

Notas

Densidad completa ≥ 4 m/m².
Incompletos: CI-PB-01, CI-PB-02, CI-PB-03, CI-PB-04, CI-PB-05, CI-PB-06, CI-PB-07, CI-PB-08, CI-PB-09, CI-PB-10, CI-PB-13, CI-PB-14, CI-PA-02, CI-PA-03, CI-PA-05, CI-PA-07, CI-PA-08, CI-PA-10, CI-PE-02, CI-PE-05, CI-PA-10, CI-PE-01, CI-PE-04 en el modelo.
Bomba de calor: no modelada.

Climatización R32 (archivo de documentación con el modelo principal vinculado). Piso radiante: serpentines PEX Ø20 (mando + retorno) trazados sobre el eje de cada tubo del modelo; colector de cada circuito por conectividad de tubos y accesorios. Densidad completa ≥ 4 m/m². Bomba de calor: no modelada.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

No.	Description	Date

Angel Luis Brusca

CASA ANGEL

CLI-00

Project number	0001
Date	18 de Agosto, 2025
Drawn by	Author
Checked by	Checker
Climatización · índice	
Scale	

10/25/2026 11:37:06 AM