
CASA ÁNGEL · CLIMATIZACIÓN · FICHA CI-PA-08 · SALA DE MAQUINAS

01. Planta Alta · 16,57 ml · 4,79 m² · 3,46 m/m² · CO-S S07 · incompleto

CI-PA-08 · planta 1:20



Datos del circuito 1:10

Ficha CI-PA-08

Local: Sala de Maquinas · 01. Planta Alta
Circuito: CI-PA-08
Tubo PEX Ø20: 16,57 ml (ida 8,05 · retorno 8,51)
Superficie servida: 4,79 m²
Densidad: 3,46 m/m² · paso equivalente 0,29 m
Colector: CO-S · salida S07
Termostato: (ninguno en el modelo)
Estado: incompleto (completo ≥ 4 m/m²)

Referencias

Trazo de color: serpentín de este circuito sobre el eje del tubo del modelo
Cuadrado: termostato · arquitectura vinculada en medio tono
Cotas: extensión del serpentín (m)

Climatización R32 (archivo de documentación con el modelo principal vinculado). Piso radiante: serpentines PEX Ø20 (mando + retorno) trazados sobre el eje de cada tubo del modelo; colector de cada circuito por conectividad de tubos y accesorios. Densidad completa ≥ 4 m/m². Bomba de calor: no modelada.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

No.	Description	Date

Angel Luis Brusca

CASA ANGEL

CLI-F-CI-PA-08

Project number	0001
Date	18 de Agosto, 2025
Drawn by	Author
Checked by	Checker
Climatiz. · CI-PA-08	
Scale	As indicated

10/26/2026 10:06:29 AM