
CASA ÁNGEL · CLIMATIZACIÓN · FICHA CI-PB-09 · HAB. SERVICIO

00. Planta Baja · 19,19 ml · 6,61 m² · 2,90 m/m² · CO-N S12 · incompleto

CI-PB-09 · planta 1:20



Datos del circuito 1:10

Ficha CI-PB-09

Local: Hab. servicio · 00. Planta Baja
Circuito: CI-PB-09
Tubo PEX Ø20: 19,19 ml (ida 10,90 · retorno 8,29)
Superficie servida: 6,61 m²
Densidad: 2,90 m/m² · paso equivalente 0,34 m
Colector: CO-N · salida S12 (asignado por cercanía)
Termostato: (ninguno en el modelo)
Estado: incompleto (completo ≥ 4 m/m²)

Referencias

Trazo de color: serpentín de este circuito sobre el eje del tubo del modelo
Cuadrado: termostato · arquitectura vinculada en medio tono
Cotas: extensión del serpentín (m)

Climatización R32 (archivo de documentación con el modelo principal vinculado). Piso radiante: serpentines PEX Ø20 (mando + retorno) trazados sobre el eje de cada tubo del modelo; colector de cada circuito por conectividad de tubos y accesorios. Densidad completa ≥ 4 m/m². Bomba de calor: no modelada.

https://ezeader.myportfolio.com/ezequiel-ader

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

No.	Description	Date

Angel Luis Brusca

CASA ANGEL

CLI-F-CI-PB-09

Project number	0001
Date	18 de Agosto, 2025
Drawn by	Author
Checked by	Checker
Climatiz. · CI-PB-09	
Scale	As indicated

10/26/2026 10:06:41 AM