

		PANEL BOM GUIDELINE-THREE STAGE						PP-ELE-GL-013-R04 06.04.2023						
PROJECT NAME : MS GERAWA GLOBAL ENGINEERING LIMITED						SALE ORDER NO : 2001400544								
REV NO. : R01 (JAW HYD. ARRANGEMENT ADDED)						LAYOUT/REVISION NO. : AVE435-350-00-01/R02								
PREPARED ON : 22.02.2024						LAYOUT DATE : 18.12.2023								
STAGE/MODEL : PROFAST - 350/250 TPH 2STAGE CRUSHING & SCREENING PLANT														
PANEL - 01														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	OLR/MPCB/ MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
1	AVELCP08SSGER-JAWANJ 912/50FT STARTER WITH CONV PANEL	JAW	AVJ 912	1	SOFT STARTER	106KW	ABB MAKE 470A SOFT STARTER	-	-	SCHNEIDER	-	M50 & M63 GLANDS 2NOS EACH	M20 - SNOS	
		GRIZLY FEEDER	AVGF 1344-VFD	1	62A VFD	2 X 6.2KW	ACS S80 62A VFD PROVIDE BYPASS OPTION	2 X 9-14A,80A MCCB	50A X 2	SCHNEIDER	M20 X 2		M25 - SNOS	
		BC 101	CONVEYOR	1	DOL	9.3KW		13-18A	32A	SCHNEIDER	M20			
		BC 102	CONVEYOR	1	DOL	30KW		40-80A	105A	SCHNEIDER	M32			
		BC 103	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
		HYD. JACK-JAW		1	DOL	2.2KW		4-6.3A	12A	SCHNEIDER	M20			
TOTAL (KW)						218KW	630A INCOMER	NOTE: * JAW HYD. CSS ARRANGEMENT, PLC & HMI CONTROL CIRCUIT TO BE ADD FOR JAW CSS ARRANGEMENT.						
CT COIL - 400/5A - 2NOS														
ESTOP IP - INO														
PANEL - 02														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	MPCB/MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
2	AVELCPC08SSGER	CONE/QM 250/ SOFT STARTER PANEL	QM250	1	SOFT STARTER	187KW	ABB MAKE 370A SOFT STARTER	-	-	-	-	SCHNEIDER		
PANEL - 03														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	MPCB/MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
3	AVELCPC08SSGER	CONE/QM 250/ SOFT STARTER PANEL	QM250	1	SOFT STARTER	187KW	ABB MAKE 370A SOFT STARTER	-	-	-	-	SCHNEIDER		
LUB PANEL														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	MPCB/MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
4	AVELQM250PNL	QM 250/350 LUB PANEL	QM LUB	2	-	0	-	-	-	-	-	SCHNEIDER		
PANEL - 05														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	OLR/MPCB/ MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
1	AVELCPCN08GER- CONVEYOR PANEL-01	BC 201	CONVEYOR	1	DOL	30KW		40-80A	105A	SCHNEIDER	M32	M50 & M63 GLANDS - 2NOS EACH	M20-SNOS	
2		BC 202	CONVEYOR	1	DOL	11KW		17-23A	32A	SCHNEIDER	M20		M25-SNOS	
3		BC 203	CONVEYOR	1	DOL	11KW		17-23A	32A	SCHNEIDER	M20			
4		BC 204	CONVEYOR	1	DOL	9.3KW		13-18A	32A	SCHNEIDER	M20			
5		BC 205	CONVEYOR	1	DOL	11KW		17-23A	32A	SCHNEIDER	M20			
6		BC 206	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
7		BC 207	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
8		BC 208	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
9		BC 209	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
10		HYD. JACK-CONE-01		1	DOL	2.2KW		4-6.3A	12A	SCHNEIDER	M20			
11								#N/A	#N/A		#N/A			
12								#N/A	#N/A		#N/A			
13								#N/A	#N/A		#N/A			
14								#N/A	#N/A		#N/A			
15								#N/A	#N/A		#N/A			
16								#N/A	#N/A		#N/A			
17								#N/A	#N/A		#N/A			
18								#N/A	#N/A		#N/A			
19								#N/A	#N/A		#N/A			
20		PAN FEEDER-01	AVPF 158-VFD	1	18A VFD	2 X 1.13KW	ACS S80 18A VFD PROVIDE BYPASS OPTION	2 X 1.6-2.5A,25A MCCB	18A X 2	SCHNEIDER	M20 X 2			
21		PAN FEEDER-02	AVPF 158-VFD	1	18A VFD	2 X 1.13KW	ACS S80 18A VFD PROVIDE BYPASS OPTION	2 X 1.6-2.5A,25A MCCB	18A X 2	SCHNEIDER	M20 X 2			
22		PAN FEEDER-03	AVPF 158-VFD	1	18A VFD	2 X 1.13KW	ACS S80 18A VFD PROVIDE BYPASS OPTION	2 X 1.6-2.5A,25A MCCB	18A X 2	SCHNEIDER	M20 X 2			
23		SCREEN-01	MVS 1860 4D	1	DOL	15 KW-DOL		24-32A	65A	SCHNEIDER	M25			
24								#N/A	#N/A		#N/A			
25								#N/A	#N/A		#N/A			
26								#N/A	#N/A		#N/A			
27								#N/A	#N/A		#N/A			
28								#N/A	#N/A		#N/A			
29		QM LUBRICATION PANEL INCOMER		1	DOL	25.57KW		4P 32A MCCB	-	SCHNEIDER	M20			
30		0						0	-		0			
31		CONTROL DESK SUPPLY		1	DOL			3P,10A MCCB	-	SCHNEIDER	M20			
TOTAL (KW)						137KW	400A INCOMER							
CT COIL - 400/5A - 2NOS														
ESTOP IP - INO														
PANEL - 06														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	OLR/MPCB/ MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
1	AVELCPCN02GER- CONVEYOR PANEL-02	BC 301	CONVEYOR	1	DOL	11KW		17-23A	32A	SCHNEIDER	M20	M50 & M63 GLANDS - 2NOS EACH	M20 - SNOS	
2		BC 302	CONVEYOR	1	DOL	11KW		17-23A	32A	SCHNEIDER	M20		M25 - SNOS	
3		BC 303	CONVEYOR	1	DOL	9.3KW		13-18A	32A	SCHNEIDER	M20			
4		BC 304	CONVEYOR	1	DOL	11KW		17-23A	32A	SCHNEIDER	M20			
5		BC 305	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
6		BC 306	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
7		BC 307	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
8		BC 308	CONVEYOR	1	DOL	3.7KW		6-10A	12A	SCHNEIDER	M20			
9		HYD. JACK-CONE-02		1	DOL	2.2KW		4-6.3A	12A	SCHNEIDER	M20			
10								#N/A	#N/A		#N/A			
11								#N/A	#N/A		#N/A			
12								#N/A	#N/A		#N/A			
13								#N/A	#N/A		#N/A			
14								#N/A	#N/A		#N/A			
15								#N/A	#N/A		#N/A			
16								#N/A	#N/A		#N/A			
17								#N/A	#N/A		#N/A			
18								#N/A	#N/A		#N/A			
19								#N/A	#N/A		#N/A			
20								#N/A	#N/A		#N/A			
21								#N/A	#N/A		#N/A			
22		PAN FEEDER-04	AVPF 158-VFD	1	18A VFD	2 X 1.13KW	ACS S80 18A VFD PROVIDE BYPASS OPTION	2 X 1.6-2.5A,25A MCCB	18A X 2	SCHNEIDER	M20 X 2			
23		SCREEN-02	MVS 1860 4D	1	15 KW-DOL	15 KW-DOL		24-32A	65A	SCHNEIDER	M25			
24								#N/A	#N/A		#N/A			
25								#N/A	#N/A		#N/A			
26								#N/A	#N/A		#N/A			
27								#N/A	#N/A		#N/A			
28		QM LUBRICATION PANEL INCOMER		1	DOL	25.57KW		4P 32A MCCB	-	SCHNEIDER	M20			
29		0						0	-		0			
30														
TOTAL (KW)						102KW	250A INCOMER							
CT COIL - 250/5A - 2NOS														
ESTOP IP - INO.														
PANEL - 07														
S.NO	ITEM CODE	DESCRIPTION	AMMETER	MCB 2 P / 10A		ALL PB REQUIRED IN CONTROL DESK / SIREN PB REQUIRED / SYSTEM START STOP ALARM TO BE PROVIDE						SPARE GLAND	SPARE GLAND	
4	AVELCMIMICDGER	CONTROL DESK MIMIC PANEL	3	1								M20-10NOS	M25-10NOS	
PANEL - 08														
S.NO	ITEM CODE	DESCRIPTION	EQUIPMENT	QTY	STARTER	POWER (KW)	REMARKS	MPCB/MCCB	CONTACTOR	MAKE	O/G GLAND	INCOMER GLAND	SPARE GLAND	
PREPARED BY : JS DATE : 22.02.2024							CHECKED BY : DS DATE : 22.02.2024							