

Lift 10,11



1.HALL BUTTON(HBP)
165X400 THROUGH HOLE ,IN THE DISCRETIONARY FLOOR
2.FIREMAN SERVICE (FSS)
Φ40mm THROUGH HOLE, IN THE MAIN FLOOR
3. PIT INSPECTION RESET SW
Φ40mm ONLY FOR PIT LANDING
4.E&I PANEL.


1 Door Elevation At "G" Floor - ELEV-L10 & L11

1 : 25




2 Door Elevation At "1" Floor - ELEV-L10 & L11

1 : 25




3 Door Elevation At "2" Floor - ELEV-L10 & L11

1 : 25




4 Cross-Section View A-A - ELEV-L10 & L11

1 : 25




5 E&I SPOT DETAIL - ELEV-L10 & L11

1 : 25




6 Cross-Section View B-B - ELEV-L10 & L11

1 : 25




Protection Elevation Detail
At Each Elevator Shaft Opening



Hook Fixation Detail

Hooks Design,Supply & Install By Main Contractor





KEY PLAN

GENERAL NOTES: ALL LEVELS SHOWN ON THE DRAWING ARE CHART DATUM LEVELS PROJECT LEVEL+0.000 = +3.700 CHART DATUM.


dar Dar Al-Handasah Consultants (Shair and Partners)
Checked and Reviewed
Refer to CRS : SD-OPE-MBL-JCDC-01441

For ELE. Panels Distribution and Connections
Refer to drawing Ref. (JOH-ICD-S5-01-056-003-02-SD-EL-011623)

CONTROLLED COPY
MBL IFC
JEDDAH OPERA HOUSE PROJECT
QA/QC Department
MBL QAM
Engr. Mudassar Altaf

SCEC – K&A Reviewed
Civil ☐ Arch. ☐ Elec. ☒ ELV. ☐ Mech. ☒ Acoustic ☒

Duplex Units



PUSH BUTTON
(a) FACE PLATE:400(L)x 165 (w)
(b) CONCRETE OPENING: 386 (L) x 158 (w) X 62 (D)
(c) Back BOX: 384(L) X 153(W) x 60(D)

DRAWING / DOCUMENT REFERENCE

NO.	NUMBER	TITLE	REV.
01	L-10 & L-11	JOH-HLA-S4-01-056-XXX-02-DR-AR-011120	F00
02		JOH-BHC-S4-01-056-XXX-XX-DR-VT-015001	
03		JOH-BHC-S4-01-056-XXX-XX-DR-VT-010001	
04		JOH-BHC-S4-01-056-005-ZZ-DR-VT-013001	
05		JOH-BHC-S4-01-056-005-ZZ-DR-VT-011001	
06		TQ-OPE-MBL-JCDC-00952	
07		TQ-OPE-MBL-JCDC-00544	
08		TQ-OPE-MBL-JCDC-00222	
09		TQ-OPE-MBL-JCDC-01052	
10		JCD-OPE-MBL-MR-003-NMR-601-03	
11		JCD-OPE-MBL-MR-003-NMR-602-01	

REVIEWED BY DISCIPLINE	SIGNATURE	DATE
ARCHITECTURAL		04-22
STRUCTURAL		2026-04-22
MECHANICAL		
PLUMBING		
ELECTRICAL		
ICT		
ADDITIONAL DISCIPLINES TO BE ADDED AS REQUIRED		

REV	DATE	BY	DESCRIPTION	CHK	APD
S01	16-APR-2026	AK	Shop Drawing	NA	SS
S00	15-APR-2026	AK	Issued for Approval	NA	SS

DRAWING STATUS: CONSTRUCTION SHOPDRAWING

CLIENT: شركة وسط جدة للتطوير Jeddah Central Development Co.

LEAD DESIGN CONSULTANTS: Henning Larsen

LEAD ENGINEERING CONSULTANT: BURO HAPPOLD

PROJECT SUPERVISION CONSULTANT: KHATIB & ALAMI

GENERAL CONTRACTOR: MBL

REVIEWER: dar

SUB CONTRACTOR: OTIS ELEVATOR COMPANY (SAUDI ARABIA) LIMITED — OTIS

SCEC – K&A Reviewed
Code B – Approved with Comments
(Do not Resubmit)

LEGEND	
HW	HOIST WAY WIDTH
HD	HOIST WAY DEPTH
CRH	CAR ROUGH HEIGHT
DOOR OP	DOOR OPENING
ROP	ROUGH OPENING
CW	CAR WIDTH
CD	CAR DEPTH
CH	CAR HEIGHT
DBG	DISTANCE BETWEEN GUARDRAIL
CWT	COUNTERWEIGHT
E&I PANEL	EMERGENCY & INSPECTION PANEL
G.O.V	CAR GOVERNOR
COP	CAR OPERATING PANEL
HBP	HALL POSITION INDICATOR

PROJECT: JEDDAH OPERA HOUSE


TITLE: OPERA BUILDING
VERTICAL TRANSPORTATION
PART 003
ELEVATIONS - LIFT SHAFT (L10 & L11)

SCALE @ A1:	CHECKED:	APPROVED:
1:25	Salma Sakr	Ali Basit
PROJECT No:	DESIGNED:	DRAWN:
440014	Abdul Kafoor	Pranoti
DATE:		
16-APR-2026		

DRAWING No: JOH-OTS-S5-01-056-003-ZZ-SD-VT-012000
REV: S01


MODEL FILE REF: JOH-OTS-S5-01-056-XXX-ZZ-M3-VT-010001

© JCDC




1 Hoist Way Plan At "G" Floor - ELEV-L10 & L11

1 : 25



2 Hoist Way Plan At "1" Floor - ELEV-L10 & L11

1 : 25



KEY PLAN

GENERAL NOTES: ALL LEVELS SHOWN ON THE DRAWING ARE CHART DATUM LEVELS PROJECT LEVEL+0.000 = +3.700 CHART DATUM.

dar Dar Al-Handasah consultants (Shair and Partners)

Checked and Reviewed

Refer to CRS : SD-OPE-MBL-JCDC-01441

For ELE. Panels Distribution and Connections

Refer to drawing Ref. (JOH-ICD-S5-01-056-003-02-SD-EL-011623)

DRAWING / DOCUMENT REFERENCE

NO.	NUMBER	TITLE	REV.
01	L-10 & L-11	JOH-HLA-S4-01-056-XXX-02-DR-AR-011120	F00
02		JOH-BHC-S4-01-056-XXX-XX-DR-VT-015001	
03		JOH-BHC-S4-01-056-XXX-XX-DR-VT-010001	
04		JOH-BHC-S4-01-056-005-ZZ-DR-VT-013001	
05		JOH-BHC-S4-01-056-005-ZZ-DR-VT-011001	
06		TQ-OPE-MBL-JCDC-00952	
07		TQ-OPE-MBL-JCDC-00544	
08		TQ-OPE-MBL-JCDC-00222	
09		TQ-OPE-MBL-JCDC-01052	
10		JCD-OPE-MBL-MR-003-NMR-601-03	
11		JCD-OPE-MBL-MR-003-NMR-602-01	

REVIEWED BY DISCIPLINE	SIGNATURE	DATE
ARCHITECTURAL		2026-04-22
STRUCTURAL		2026-04-22
MECHANICAL		
PLUMBING		2026-04-22
ELECTRICAL		
ICT		2026-04-22
ADDITIONAL DISCIPLINES TO BE ADDED AS REQUIRED		

REV	DATE	BY	DESCRIPTION	CHK	APD
S01	16-APR-2026	AK	Shop Drawing	NA	SS

DRAWING STATUS: CONSTRUCTION SHOPDRAWING

CLIENT: شركة وسط جدة للتطوير Jeddah Central Development Co.

LEAD DESIGN CONSULTANTS: Henning Larsen

LEAD ENGINEERING CONSULTANT: BURO HAPPOLD

PROJECT SUPERVISION CONSULTANT: KHATIB & ALAMI

GENERAL CONTRACTOR: MBL

REVIEWER: dar

SUB CONTRACTOR: OTIS ELEVATOR COMPANY (SAUDI ARABIA) LIMITED — OTIS

PROJECT: JEDDAH OPERA HOUSE

TITLE: OPERA BUILDING
VERTICAL TRANSPORTATION
PART 003
PLANS - LIFT SHAFT SHEET 01 OF 02 (L10 & L11)

SCALE @ A1:	CHECKED:	APPROVED:
1:25	Salma Sakr	Ali Basit
PROJECT No:	DESIGNED: / DRAWN:	DATE:
440014	Abdul Kafoor / Pranoti	16-APR-2026

DRAWING No: JOH-OTS-S5-01-056-003-ZZ-SD-VT-011000 REV: S01


MODEL FILE REF: JOH-OTS-S5-01-056-XXX-ZZ-M3-VT-010001

© JCDC


ELEV-L10 & L11 ELEVATOR GENERAL SPECIFICATIONS	
LIFT NUMBER	ELEV.L10 & L11
CABIN INTERNAL SIZE(WXDXH)	2000X1750X2600
CAPACITY	1600 Kg
CLEAR ENTRACE	1200X2400
CONTROL	VVVF
CONTROL SYSTEM	DUPLEX FULL COLLECTIVE
COUNTERWEIGHT SAFETY	NO
DOOR TYPE	CLD1
EMERGENCY EXITS	-
FRONT OPENING	3
HEAT RELEASE	1616Kcal/h
HOISTWAY SIZE(HWXHD)	2750X2400
LIFT NUMBER	ELEV-L10 & L11
LIGHTING SUPPLY	220V 60HZ
MIN.FLOOR HEIGHT	3000
NO. OF FLOOR	3
NO. OF OPENINGS	3
NO. OF UNITS	2
NON-STOP FLOORS	-
NON-STOP FLOORS NAMES	-
NUMBER OF PASSENGERS	21P
OVERHEAD	5300mm
PIT DEPTH	1600mm
POWER SUPPLY	380V 3P 60HZ
PRODUCT NO.	GeN2 MRL
RATED CURRENT(A)	25.6
REAR OPENING	-
ROPING	2:1
SPEED(m/s)	1.00
START CURRENT(A)	28.4
SYSTEM POWER(KW)	13.5
TRAVEL	9975mm
USE	PASSENGER LIFT

REACTIONS FORCE (KN)			
Car side rail	CWT guide rail	Pit reaction	
R= 41	R= 48	U= 165	R, R2, R2, R1
R1= 2.47	R1= 1.13	V= 132	
R2= 3.14	R2= 0.3		

LEGEND	
HW	HOIST WAY WIDTH
HD	HOIST WAY DEPTH
CRH	CAR ROUGH HEIGHT
DOOR OP	DOOR OPENING
ROP	ROUGH OPENING
CW	CAR WIDTH
CD	CAR DEPTH
CH	CAR HEIGHT
DBG	DISTANCE BETWEEN GUARDRAIL
CWT	COUNTERWEIGHT
E&I PANEL	EMERGENCY & INSPECTION PANEL
G.O.V	CAR GOVERNOR
COP	CAR OPERATING PANEL
HBP	HALL POSITION INDICATOR



KEY PLAN



CONTROLLED COPY — MBL IFC — JEDDAH OPERA HOUSE PROJECT — QA/QC Department — MBL QAM — Engr. Mudassar Altaf

SCEC – K&A Reviewed


Civil	Arch.	Elec.	ELV.	Mech.	Acoustic
☐	☐	☒	☐	☒	☒

SCEC – K&A Reviewed

Code B – Approved with Comments (Do not Resubmit)


NOTE No.:
FRONT WALLS,FINISHES & ARCHITRAVES TO BE BUILT (BY CLIENT) AFTER THE INSTALLATION OF THE (LANDING) EXTERNAL DOORS.

IMPORTANT NOTE FOR MAIN CONTRACTOR.
FREEDOM OF ACCESS MUST BE AVAILABLE FOR POINT OF ENTRY INTO THE BUILDING UP TO THE ELEVATOR HOIST WAY AND THE FRONT WALLS OF THE HOIST WAY AT MAIN FLOOR TO BE LEFT OPEN FOR FULL WIDTH AND HEIGHT TO PERMIT ENTRY OF OUR EQUIPMENT.




3 Hoist Way Plan At "2" Floor - ELEV-L10 & L11

1 : 25




1 Machine Plan Level - ELEV-L10 & L11

1 : 25




2 Hoist Way Pit Plan Floor - ELEV-L10 & L11

1 : 25



3 Hoist Way Hook Plan Floor - ELEV-L10 & L11

1 : 25



KEY PLAN

GENERAL NOTES: ALL LEVELS SHOWN ON THE DRAWING ARE CHART DATUM LEVELS PROJECT LEVEL+0.000 = +3.700 CHART DATUM.


dar — Dar Al-Handasah Consultants (Shair and Partners)
Checked and Reviewed
Refer to CRS : SD-OPE-MBL-JCDC-01441

For ELE. Panels Distribution and Connections
Refer to drawing Ref. (JOH-ICD-S5-01-056-003-02-SD-EL-011623)

DRAWING / DOCUMENT REFERENCE

NO.	NUMBER	TITLE	REV.
01	L-10 & L-11	JOH-HLA-S4-01-056-XXX-02-DR-AR-011120	F00
02		JOH-BHC-S4-01-056-XXX-XX-DR-VT-015001	
03		JOH-BHC-S4-01-056-XXX-XX-DR-VT-010001	
04		JOH-BHC-S4-01-056-005-ZZ-DR-VT-013001	
05		JOH-BHC-S4-01-056-005-ZZ-DR-VT-011001	
06		TQ-OPE-MBL-JCDC-00952	
07		TQ-OPE-MBL-JCDC-00544	
08		TQ-OPE-MBL-JCDC-00222	
09		TQ-OPE-MBL-JCDC-01052	
10		JCD-OPE-MBL-MR-003-NMR-601-03	
11		JCD-OPE-MBL-MR-003-NMR-602-01	


ELEV-L10 & L11 ELEVATOR GENERAL SPECIFICATIONS	
LIFT NUMBER	ELEV.L10 & L11
CABIN INTERNAL SIZE(WXDXH)	2000X1750X2600
CAPACITY	1600 Kg
CLEAR ENTRACE	1200X2400
CONTROL	VVVF
CONTROL SYSTEM	DUPLEX FULL COLLECTIVE
COUNTERWEIGHT SAFETY	NO
DOOR TYPE	CLD1
EMERGENCY EXITS	-
FRONT OPENING	3
HEAT RELEASE	1616Kcal/h
HOISTWAY SIZE(HWXHD)	2750X2400
LIFT NUMBER	ELEV-L10 & L11
LIGHTING SUPPLY	220V 60HZ
MIN.FLOOR HEIGHT	3000
NO. OF FLOOR	3
NO. OF OPENINGS	3
NO. OF UNITS	2
NON-STOP FLOORS	-
NON-STOP FLOORS NAMES	-
NUMBER OF PASSENGERS	21P
OVERHEAD	5300mm
PIT DEPTH	1600mm
POWER SUPPLY	380V 3P 60HZ
PRODUCT NO.	GeN2 MRL
RATED CURRENT(A)	25.6
REAR OPENING	-
ROPING	2:1
SPEED(m/s)	1.00
START CURRENT(A)	28.4
SYSTEM POWER(KW)	13.5
TRAVEL	9975mm
USE	PASSENGER LIFT



KEY PLAN

CONTROLLED COPY
MBL IFC
JEDDAH OPERA HOUSE PROJECT
QA/QC Department
MBL QAM
Engr. Mudassar Altaf

REACTIONS FORCE (KN)			
Car side rail	CWT guide rail	Pit reaction	
R= 41	R= 48	U= 165	R, R2, R1, R2
R1= 2.47	R1= 1.13	V= 132	
R2= 3.14	R2= 0.3		



LEGEND	
HW	HOIST WAY WIDTH
HD	HOIST WAY DEPTH
CRH	CAR ROUGH HEIGHT
DOOR OP	DOOR OPENING
ROP	ROUGH OPENING
CW	CAR WIDTH
CD	CAR DEPTH
CH	CAR HEIGHT
DBG	DISTANCE BETWEEN GUARDRAIL
CWT	COUNTERWEIGHT
E&I PANEL	EMERGENCY & INSPECTION PANEL
G.O.V	CAR GOVERNOR
COP	CAR OPERATING PANEL
HBP	HALL POSITION INDICATOR

SCEC – K&A Reviewed

Civil	Arch.	Elec.	ELV.	Mech.	Acoustic
☐	☐	☒	☐	☒	☒

SCEC – K&A Reviewed
Code B – Approved with Comments (Do not Resubmit)

NOTE No.:
FRONT WALLS,FINISHES & ARCHITRAVES TO BE BUILT (BY CLIENT) AFTER THE INSTALLATION OF THE (LANDING) EXTERNAL DOORS.

IMPORTANT NOTE FOR MAIN CONTRACTOR.
FREEDOM OF ACCESS MUST BE AVAILABLE FOR POINT OF ENTRY INTO THE BUILDING UP TO THE ELEVATOR HOIST WAY AND THE FRONT WALLS OF THE HOIST WAY AT MAIN FLOOR TO BE LEFT OPEN FOR FULL WIDTH AND HEIGHT TO PERMIT ENTRY OF OUR EQUIPMENT.

REVIEWED BY DISCIPLINE	SIGNATURE	DATE
ARCHITECTURAL		
STRUCTURAL		2026-04-22
MECHANICAL		
PLUMBING		
ELECTRICAL		
ICT		2026-04-2*
ADDITIONAL DISCIPLINES TO BE ADDED AS REQUIRED		

REV	DATE	BY	DESCRIPTION	CHK	APD
S01	16-APR-2026	AK	Shop Drawing	NA	SS
S00	15-APR-2026	AK	Issued for Approval	NA	SS

DRAWING STATUS: CONSTRUCTION SHOPDRAWING

CLIENT: شركة وسط جدة للتطوير Jeddah Central Development Co.

LEAD DESIGN CONSULTANTS: Henning Larsen

LEAD ENGINEERING CONSULTANT: BURO HAPPOLD

PROJECT SUPERVISION CONSULTANT: KHATIB & ALAMI

GENERAL CONTRACTOR: MBL

REVIEWER: dar

SUB CONTRACTOR: OTIS ELEVATOR COMPANY (SAUDI ARABIA) LIMITED — OTIS

PROJECT: JEDDAH OPERA HOUSE

TITLE: OPERA BUILDING
VERTICAL TRANSPORTATION
PART 003
PLANS - LIFT SHAFT SHEET 02 OF 02 (L10 & L11)


SCALE @ A1:	CHECKED:	APPROVED:
1:25	Salma Sakr	Ali Basit

PROJECT No:	DESIGNED:	DRAWN:	DATE:
440014	Abdul Kafoor	Pranoti	16-APR-2026

DRAWING No: JOH-OTS-S5-01-056-003-ZZ-SD-VT-011001 REV: S01


MODEL FILE REF: JOH-OTS-S5-01-056-XXX-ZZ-M3-VT-010001

© JCDC




1 Section "A" - ELEV-L10 & L11

1 : 50




2 Section "B" - ELEV-L10

1 : 50




3 Section "C" - ELEV-L11

1 : 50




4 Landing Door Header Detail - ELEV-L10 & L11

1 : 10



5 Landing Door Bottom Detail - ELEV-L10 & L11

1 : 10



KEY PLAN

GENERAL NOTES: ALL LEVELS SHOWN ON THE DRAWING ARE CHART DATUM LEVELS PROJECT LEVEL+0.000 = +3.700 CHART DATUM.

dar Dar Al-Handasah consultants (Shair and Partners)
Checked and Reviewed
Refer to CRS : SD-OPE-MBL-JCDC-01441

For ELE. Panels Distribution and Connections
Refer to drawing Ref. (JOH-ICD-S5-01-056-003-02-SD-EL-011623)

SCEC – K&A Reviewed
Civil ☐ Arch. ☐ Elec. ☒ ELV. ☐ Mech. ☒ Acoustic ☒

SCEC – K&A Reviewed
Code B – Approved with Comments
(Do not Resubmit)

CONTROLLED COPY
MBL IFC
JEDDAH OPERA HOUSE PROJECT
QA/QC Department
MBL QAM
Engr. Mudassar Altaf

DRAWING / DOCUMENT REFERENCE

NO.	NUMBER	TITLE	REV.
01	L-10 & L-11	JOH-HLA-S4-01-056-XXX-02-DR-AR-011120	F00
02		JOH-BHC-S4-01-056-XXX-XX-DR-VT-015001	
03		JOH-BHC-S4-01-056-XXX-XX-DR-VT-010001	
04		JOH-BHC-S4-01-056-005-ZZ-DR-VT-013001	
05		JOH-BHC-S4-01-056-005-ZZ-DR-VT-011001	
06		TQ-OPE-MBL-JCDC-00952	
07		TQ-OPE-MBL-JCDC-00544	
08		TQ-OPE-MBL-JCDC-00222	
09		TQ-OPE-MBL-JCDC-01052	
10		JCD-OPE-MBL-MR-003-NMR-601-03	
11		JCD-OPE-MBL-MR-003-NMR-602-01	

REVIEWED BY DISCIPLINE	SIGNATURE	DATE
ARCHITECTURAL		
STRUCTURAL		2026-04-22
MECHANICAL		
PLUMBING		
ELECTRICAL		
ICT		2026-04-21
ADDITIONAL DISCIPLINES TO BE ADDED AS REQUIRED		

REV	DATE	BY	DESCRIPTION	CHK	APD
S01	16-APR-2026	AK	Shop Drawing	NA	SS
S00	15-APR-2026	AK	Issued for Approval	NA	SS

DRAWING STATUS: CONSTRUCTION SHOPDRAWING

CLIENT: شركة وسط جدة للتطوير Jeddah Central Development Co.

LEAD DESIGN CONSULTANTS: Henning Larsen

LEAD ENGINEERING CONSULTANT: BURO HAPPOLD

PROJECT SUPERVISION CONSULTANT: KHATIB & ALAMI

GENERAL CONTRACTOR: MBL

REVIEWER: dar

SUB CONTRACTOR: OTIS ELEVATOR COMPANY (SAUDI ARABIA) LIMITED — OTIS

PROJECT: JEDDAH OPERA HOUSE

TITLE: OPERA BUILDING
VERTICAL TRANSPORTATION
PART 003
SECTIONS - LIFT SHAFT (L10 & L11)

SCALE @ A1:	CHECKED:	APPROVED:
As indicated	Salma Sakr	Ali Basit

PROJECT No:	DESIGNED:	DRAWN:	DATE:
440014	Abdul Kafoor	Pranoti	16-APR-2026

DRAWING No: JOH-OTS-S5-01-056-003-ZZ-SD-VT-013000 REV: S01

MODEL FILE REF: JOH-OTS-S5-01-056-XXX-ZZ-M3-VT-010001

© JCDC