



Issued for Construction

Date 31.01.2024

Plumbing Fixtures Schedule

Rev.Date 31.01.2024
Rev. No. F00

- General note:**
- 1. All reference manufacturers, brands and products are representative of the design intent as referenced in the design drawings, specifications, schedules and reports. They may be substituted under a Contractor’s Proposal provided that they are accepted by the Designers and that they conform to any specified performance requirements.
 - 2. All divergence from the reference products/ materials are to be formally notified in writing to the designer. The Designer shall have not less than 10 working days to respond to all proposals. The Designer reserves the right to reject the proposed alternative product or material.
 - 3. All suggested alternative samples are to be issued to the Designer for review at least 10 working days prior to the submission of a formal Contractor’s Proposal. Acceptance of the sample by the Designer does not relieve the Contractor of conformance of the installation works to the Design Intent.
 - 4. Image swatches are indicative only and are not to be used for colour matching, sampling, or benchmarking.
 - 5. Refer to the design drawings for locations of finishes.
 - 6. Refer to note on page 5 with respect to permissible water flowrates.

TAG	IMAGE	LOCATION	PRODUCT	MODEL No./ Type	COLOR / FINISH	MANUFACTURER	NOTES
Plumbing Fixtures							
PFX01		Toilets Generally	Robe Hook	Curve Mini Hook H: 5,8 x W: 2,1 x D: 3 cm 0,024 kg Including mounting fixture, screws and rawlplugs. Max weight load: 3kg.	Matt Gold Material: Anodized Aluminium	Normann Copenhagen or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX02		Toilets Generally	Paper Towel Dispenser + Bin Combo Unit Recessed	Code: 10-6467-00 Capacity: 16 L Waste Bin 800 multi fold paper towel Finished Wall Opening required: 332 W x 1399 H x 119mm D	White Phenolic Door, Piatto Collection	JD MacDonald or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX03		5.B1.T0128 - Public Toilet Male	Paper Towel Dispenser + Bin Combo Unit Surface Mounted	Code: B-380349 Capacity: 14,4 L Waste Bin 800 multi fold paper towel Size 330 W x 1400 H x 117mm D	Stainless Steel Satin Finish	Bobrick or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX04		FoH Toilets Vanity Basin Typically	Soap Dispenser Bench / Hob Mounted	Code: 99679BB Urbane II Sensor Hob Mounted Soap Dispenser Capacity: 1000ml, top refill technology	Finish: Brushed Brass fingerprint proof coating	Caroma or similar to be approved by architect	
PFX05		BoH Toilets Vanity Basin Generally	Dual Bottle Holder - wall mounted	Code: USP-071312	Steel	Buster & Punch or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX06		ADA Toilet Cubicles Generally	Liquid Soap Dispenser Surface Mounted	Code: T10 Capacity: 500ml Size 75mm DIA x 195mm H	40 Brushed Stainless Steel	Vola or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX07			Double Toilet Roll Holder	Code: T13L-BP No Backplate	40 Brushed Stainless Steel	Vola or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX08		Toilet Cubicles Generally (Female only)	Sanitary bag clip	Code: ABN-200000	Aluminium	Madame or similar to be approved by architect	Sanitary bag not included

DOCUMENT NO.:
JOH-HLA-S4-01-056-XXX-DS-SCH-ID-000040

JEDDAH OPERA HOUSE



BURO HAPPOLD

Henning
Larsen

Issued for Construction

Date

31.01.2024

Plumbing Fixtures Schedule

Rev.Date

31.01.2024

Rev. No.

F00

General note:

1. All reference manufacturers, brands and products are representative of the design intent as referenced in the design drawings, specifications, schedules and reports. They may be substituted under a Contractor's Proposal provided that they are accepted by the Designers and that they conform to any specified performance requirements.

2. All divergence from the reference products/ materials are to be formally notified in writing to the designer. The Designer shall have not less than 10 working days to respond to all proposals. The Designer reserves the right to reject the proposed alternative product or material.

3. All suggested alternative samples are to be issued to the Designer for review at least 10 working days prior to the submission of a formal Contractor's Proposal. Acceptance of the sample by the Designer does not relieve the Contractor of conformance of the installation works to the Design Intent.

4. Image swatches are indicative only and are not to be used for colour matching, sampling, or benchmarking.

5. Refer to the design drawings for locations of finishes.

6. Refer to note on page 5 with respect to permissible water flowrates.

TAG	IMAGE	LOCATION	PRODUCT	MODEL No./ Type	COLOR / FINISH	MANUFACTURER	NOTES
Plumbing Fixtures							
PFX09		Toilet Cubicles Generally	Ablution Hose	Code: 26354000 EAN: 4005176333873 Tempesta Trigger Spray 30 V hand shower with trigger control 27 512 001 shower holder for wall 28 605	Chrome	Grohe or similar to be approved by architect	Refer to interior elevation drawings for installation heights Flow Rate: 4.6 L / min at pressure bar 1 6.5 L / min at pressure bar 2 8.0 L / min at pressure bar 3 9.2 L / min at pressure bar 4 10.3 L / min at pressure bar 5 11.3 L / min at pressure bar 6
PFX10		Toilet Cubicles Generally	Wall Mounted Toilet Brush	Code: T33 Plumbing no. 778577500,	40 Brushed Stainless Steel	Vola or similar to be approved by architect	Refer to interior elevation drawings for installation heights Includes extra brush head in black
PFX11		Toilets Generally (Artist Quarter & Back of House)	Wall Mounted Basin	Opal 510 Wall Mounted Basin Code: 632610W (basin) 632601W (shroud) 1 taphole, 9.5 L capacity Size: 450 D x 510 W mm	White Ceramic	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Install shroud below to conceal piperwork Tapware to be PFX19 Paired with PFX05
PFX12		Toilets Generally (Artist Quarter & Back of House)	Wall Mounted Basin w/ shelf, Right Hand	Opal 720 Wall Mounted Basin with right hand shelf Code: 632110W (basin) 632601W (shroud) 1 taphole, 9.5 L capacity Size: 450 D x 720 W mm	White Ceramic	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Install shroud below to conceal piperwork Tapware to be PFX19 Paired with PFX05
PFX13		Toilets Generally (Artist Quarter & Back of House)	Wall Mounted Basin w/ shelf, Left Hand	Opal 720 Wall Mounted Basin with right hand shelf Code: 632210W(basin) 632601W (shroud) 1 taphole, 9.5 L capacity Size: 450 D x 720 W mm	White Ceramic	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Install shroud below to conceal piperwork Tapware to be PFX19 Paired with PFX05
PFX14		Toilets Generally (Artist Quarter & Back of House)	Wall Mounted Basin w/ shelf, centre aligned	Opal 900 Twin Wall mounted basin Code: 632510W(basin) 632601W (shroud) 1 taphole, 9.5 L capacity Size: 450 D x 900 W mm	White Ceramic	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Install shroud below to conceal piperwork Tapware to be PFX19 Paired with PFX05
PFX15		FoH Toilets in Artist Quarters Restaurant Cafe	Undermount basin	Urbane II undermount basin Code: 878500W 0 taphole, 0 overflow, 10,2 L capacity Size: 370 D x 540 W x 187 H mm	White Ceramic	Caroma or similar to be approved by architect	Includes integrated white ceramic pop up plug & waste Tapware to be PFX20 Paired with PFX04

DOCUMENT NO.:

JOH-HLA-S4-01-056-XXX-DS-SCH-ID-000040

JEDDAH OPERA HOUSE**BURO HAPPOLD****Henning
Larsen****Issued for Construction****Date****31.01.2024****Plumbing Fixtures Schedule**

Rev.Date

31.01.2024

Rev. No.

F00

General note:

1. All reference manufacturers, brands and products are representative of the design intent as referenced in the design drawings, specifications, schedules and reports. They may be substituted under a Contractor's Proposal provided that they are accepted by the Designers and that they conform to any specified performance requirements.


2. All divergence from the reference products/ materials are to be formally notified in writing to the designer. The Designer shall have not less than 10 working days to respond to all proposals. The Designer reserves the right to reject the proposed alternative product or material.

3. All suggested alternative samples are to be issued to the Designer for review at least 10 working days prior to the submission of a formal Contractor's Proposal. Acceptance of the sample by the Designer does not relieve the Contractor of conformance of the installation works to the Design Intent.

4. Image swatches are indicative only and are not to be used for colour matching, sampling, or benchmarking.

5. Refer to the design drawings for locations of finishes.

6. Refer to note on page 5 with respect to permissible water flowrates.

TAG	IMAGE	LOCATION	PRODUCT	MODEL No./ Type	COLOR / FINISH	MANUFACTURER	NOTES
Plumbing Fixtures							
PFX16		Toilet Cubicles Generally Front of House	Concealed Cistern Wall Hung Toilet Suite	PURA wall hung toilet suite with Swirl Flush, concealed cistern Code: 881509 (toilet bowl) SIGMA 111.300.00.5 (cistern) 115.889.SN.1 (flush plate) Size: 360 W x 550 L x 420 H mm	White, Matt	GSI or similar to be approved by architect	Refer to interior elevation drawings for installation heights Seats included To be Flush Valve in all Front of House areas Flow Rate: 6L / flush
PFX17		Toilet Cubicles Generally Artist's Quarter Back of House Parking	Concealed Cistern Wall Hung Toilet Suite	Basic+ Wall Hung Toilet Suite Code: C762E (toilet) WH172A (concealed cistern) TC384CVK (seat & cover) MB174P (flush panel)	White, glossy	TOTO or similar to be approved by architect	Refer to interior elevation drawings for installation heights To be Tank Valve in all Artist Quarter and Back of House areas Flow Rate: 4,5L / 3 L per flush
PFX18		ADA Toilet Cubicles Generally	Wall hung ADA toilet suite	Wc Community 37 x 70 Width: 37 cm Depth: 70 cm Weight: 33.7 kg Code: 761511 (toilet bowl) GEBERIT 109.770.00.1(cistern) 115.889.SN.1 (flush plate) MS86CSN11 (Seats & Cover)	White, glossy	GSI or similar to be approved by architect	To be Tank Valve Flow Rate: 6L / flush
PFX19		Toilets Generally (Artist Quarter & Back of House)	Hob Mounted Mixer Tap with extended pin lever	Code: HV1L+30 One-handle mixer with long lever, ceramic disc technology, fixed spout with water saving aerator. Height: 150 mm. Spout extension: 114mm	40 Brushed Stainless Steel	Vola or similar to be approved by architect	Flow Rate: 2.9 L / min at pressure bar 1 4.1 L / min at pressure bar 2 5.0 L / min at pressure bar 3 5.0 L / min at pressure bar 4 5.0 L / min at pressure bar 5
PFX20		Toilets Generally (Front of House)	Automatic Hob Mounted Outlet	Build-in basin tap with on-off sensor for 'hands free' operation. Code: 99674BB6A Size: 118 mm spout length	Brushed Brass	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Flow Rate: 4.5 Litre per minute. WELS 6 Star
PFX20a		Ablution	Automatic Wall Mounted Outlet	Build-in basin tap with on-off sensor for 'hands free' operation. Code: 4311 4311UP = Valve 4300, sensor cable VR509. 4311AP = 160 mm spout 010, sensor VR510, 60 mm circular flanges 001, VR512. Size: 160 mm spout length	40 Brushed Stainless Steel	Vola or similar to be approved by architect	Refer to interior elevation drawings for installation heights For vertical mounting. Sensor aligned with wall. Flow Rate: 2.9 L / min at pressure bar 1 4.1 L / min at pressure bar 2 5.0 L / min at pressure bar 3 5.0 L / min at pressure bar 4 5.0 L / min at pressure bar 5



Issued for Construction

Date 31.01.2024

Plumbing Fixtures Schedule

Rev.Date 31.01.2024
Rev. No. F00

- General note:**
1. All reference manufacturers, brands and products are representative of the design intent as referenced in the design drawings, specifications, schedules and reports. They may be substituted under a Contractor’s Proposal provided that they are accepted by the Designers and that they conform to any specified performance requirements.
2. All divergence from the reference products/ materials are to be formally notified in writing to the designer. The Designer shall have not less than 10 working days to respond to all proposals. The Designer reserves the right to reject the proposed alternative product or material.
3. All suggested alternative samples are to be issued to the Designer for review at least 10 working days prior to the submission of a formal Contractor’s Proposal. Acceptance of the sample by the Designer does not relieve the Contractor of conformance of the installation works to the Design Intent.
4. Image swatches are indicative only and are not to be used for colour matching, sampling, or benchmarking.
5. Refer to the design drawings for locations of finishes.
6. Refer to note on page 5 with respect to permissible water flowrates.

TAG	IMAGE	LOCATION	PRODUCT	MODEL No./ Type	COLOR / FINISH	MANUFACTURER	NOTES
Plumbing Fixtures							
PFX21		ADA Toilet Cubicles Generally	Grab Rails	Opal Support Grab Rail Length : 600mm Code: 687377BN	Brushed Nickel	Caroma or similar to be approved by architect	To be installed to comply with 1431 H - 2010
PFX22		ADA Toilet Cubicles Generally	Grab Rails	Opal Support Grab Rail 90 degree Size: 720 x 430 mm Code: 687380BN	Brushed Nickel	Caroma or similar to be approved by architect	To be installed to comply with 1431 H - 2010
PFX23		ADA Shower Cubicles Generally	Grab Rails	Virtu Comfort Grab Rail Length : 800mm Code: 6873771BN Installed vertically	Brushed Nickel	Caroma or similar to be approved by architect	To be installed to comply with 1431 H - 2010
PFX24		Shower Cubicles Generally	Twin Shower System	Esence Rail Shower with Overhead Code: 90310C3A Wall Mixer Code: CL10002.C (in-wall body) CL10027.C (pin wall mixer) CL10003.C (trim kit)	Chrome	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Flow Rate: WELS 3 Star Rated: 9.0 L/min
PFX25		ADA Shower Cubicles Generally	Rail Shower	Care support accessible shower set w/ 1000mm grab rail Code: 91129C4E (shower set) Wall Mixer Code: CL10002.C (in-wall body) CL10027.C (pin wall mixer) CL10003.C (trim kit)	Chrome	Caroma or similar to be approved by architect	To be installed to comply with 1431 H - 2010 Flow Rate: WELS 4 Star Rated: 7,5 L/min



Issued for Construction

Date 31.01.2024

Plumbing Fixtures Schedule

Rev.Date 31.01.2024
Rev. No. F00

- General note:**
1. All reference manufacturers, brands and products are representative of the design intent as referenced in the design drawings, specifications, schedules and reports. They may be substituted under a Contractor’s Proposal provided that they are accepted by the Designers and that they conform to any specified performance requirements.
2. All divergence from the reference products/ materials are to be formally notified in writing to the designer. The Designer shall have not less than 10 working days to respond to all proposals. The Designer reserves the right to reject the proposed alternative product or material.
3. All suggested alternative samples are to be issued to the Designer for review at least 10 working days prior to the submission of a formal Contractor’s Proposal. Acceptance of the sample by the Designer does not relieve the Contractor of conformance of the installation works to the Design Intent.
4. Image swatches are indicative only and are not to be used for colour matching, sampling, or benchmarking.
5. Refer to the design drawings for locations of finishes.
6. Refer to note on page 5 with respect to permissible water flowrates.

TAG	IMAGE	LOCATION	PRODUCT	MODEL No./ Type	COLOR / FINISH	MANUFACTURER	NOTES
Plumbing Fixtures							
PFX26		ADA Shower Cubicles Generally	Recessed soap dispenser	Code: B-4063 Capacity: 1,5L Size 185 W x 160 H mm 40mm projection wall opening requiement 150mm wide 140mm high 102mm minimum recessed depth	304 Stainless Steel	Bobrick or similar to be approved by architect	To be installed to comply with 1431 H - 2010
PFX27		Shower Cubicles Generally	Metal Shelf	Cosmo Metal Shelf Code: 305006C Size 412 W x 146 D mm	Chrome	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX28		Cleaner's Cupboard	Cleaner's Sink	Cosmo Metal Shelf Code: 811593 (grate) 811592W (sink) 811595 (bracket) 90331C4A (wall mixer) Size 575 x 435mm with buffer and centre back outlet Capacity: 27L	White Chrome (mixer)	Caroma or similar to be approved by architect	Refer to interior elevation drawings for installation heights Flow Rate: WELS 4 Star Rated: 7,5 L/min
PFX29		Family Room	Baby Change Station	Wall mounted baby changing station. Carrying capacity max. 80 kg. Code: 3200 EAN no. 5-709818-032009 Folded up: H:781 mm, W: 552 mm, D:100 mm Open size of 552 (W) x 760 mm (D) with a usable changing surface of 510 x 700mm	White RAL 9003, gloss 75	Dan Dryer or similar to be approved by architect	Refer to interior elevation drawings for installation heights
PFX30		Artist Quarter Dressing Rooms	Free Standing Bath Tub	Contura Solid Surface Free Standing Bath Tub Code: C07W Size: 1700 L x 760 W x 584 H mm 45L capacity, no overflow	White Matte	Caroma or similar to be approved by architect	Includes an integrated solid surface pop up plug and waste for a seamless look
PFX31		Artist Quarter Dressing Rooms	Floor Mounted Bath Mixer with hand shower	Vivid Slimline Floor Mounted Bath Mixer with Hand Shower Code: VS7451-00 35mm ceramic cartridge with 15 year warranty	Chrome	Phoenix Tapware or similar to be approved by architect	Includes an integrated solid surface pop up plug and waste for a seamless look Flow Rate: WELS 3 Star Rated: 8.0 L/min Pressure rating: 150-500 kPa



Issued for Construction

Date 31.01.2024

Plumbing Fixtures Schedule

Rev.Date 31.01.2024
Rev. No. F00

- General note:**
1. All reference manufacturers, brands and products are representative of the design intent as referenced in the design drawings, specifications, schedules and reports. They may be substituted under a Contractor’s Proposal provided that they are accepted by the Designers and that they conform to any specified performance requirements.
2. All divergence from the reference products/ materials are to be formally notified in writing to the designer. The Designer shall have not less than 10 working days to respond to all proposals. The Designer reserves the right to reject the proposed alternative product or material.
3. All suggested alternative samples are to be issued to the Designer for review at least 10 working days prior to the submission of a formal Contractor’s Proposal. Acceptance of the sample by the Designer does not relieve the Contractor of conformance of the installation works to the Design Intent.
4. Image swatches are indicative only and are not to be used for colour matching, sampling, or benchmarking.
5. Refer to the design drawings for locations of finishes.
6. Refer to note on page 5 with respect to permissible water flowrates.

TAG	IMAGE	LOCATION	PRODUCT	MODEL No./ Type	COLOR / FINISH	MANUFACTURER	NOTES
Plumbing Fixtures							
PFX32		Shower Areas Generally Ablution Room	Channel Drain with floor tile insert	Phoenix V Channel Drain TI 75 x 900mm Outlet 45mm Code: 201-1131-51 Size: 75 W x 900 L mm , 45mm outlet	316 Stainless Steel	Phoenix Tapware or similar to be approved by architect	Tile Insert to match floor alignment Channel shall be fitted with trapped outlet
PFX33		Shower Areas Generally Ablution Room	Channel Drain with floor tile insert	Phoenix V Channel Drain TI 75 x 1200mm Outlet 45mm Code: 201-1141-51 Size: 75 W x 1200 L mm , 45mm outlet	316 Stainless Steel	Phoenix Tapware or similar to be approved by architect	Tile Insert to match floor alignment Channel shall be fitted with trapped outlet
PFX34		Toilets Generally	Point Drain with floor tile insert	Phoenix Point Drain TI 100mm Outlet 90mm Code: 202-1205-51 Size: 103 x 103 mm , 90mm outlet	316 Stainless Steel	Phoenix Tapware or similar to be approved by architect	Tile Insert to match floor alignment
PFX35		ADA Shower Cubicles Generally	Folding Shower Bench	Care Support Folding Shower Seat Code: 687397W Size: 1020 L x 355 W mm Max load: 250kg	304 Stainless Steel White Polyprop	Caroma or similar to be approved by architect	
EMERGENCY STRIP		ADA CUBICLES TYPICALLY	Emergency strip with lights and sound	Dado panic and affray switch strip with led illumination SKU: RPLED00000 Length: Refer to drawings	Grey & Red	Hoyles or similar to be approved by architect	Refer to typical ADA toilet cubicle drawings for specific lengths.
IMPORTANT NOTE: All fittings and fixtures need to comply with the maximum permissible water flowrates indicated below. If above selection does not comply, contractor is to present deviations and appropriate compliant alternatives to design architect for approval.							
• Water Closet – 2.4 LPF- Water sense labelled • Urinals – 0.94 LPF (Litres per Flush) • Kitchen Faucets/Tap – 3.4 LPM • Public Lavatory Faucet – 0.95 LPM at 415 KPa • Private Lavatory Faucet – 4.15 LPM at 415 KPa • Showerhead – 3.8 lpm at 550 KPa Water sense labelled • Washing Machine - 62.95 LPC (Litres Per Cycle) • Dishwasher - 12 LPC (Litres Per Cycle) • Drinking Fountain / Water Cooler- 1.33 LPM • Ablution Hose- 3.8 LPM (Litres Per Minute) • Wash Basin (Public)-0.25 LPM • Wash Basin (Private)- 4.1 LPMx • Bidet- 3.4 LPM • Sink- 4.1 LPM • Janitor MOP Sink- 5.1 LPM to be provided							