



# Bureau of Research, Testing and Consultation (BRTC)

## Department of Civil Engineering

Chittagong University of Engineering & Technology (CUET)

Chattogram-4349, Bangladesh

### TEST REPORT

Memo No. : BRTC/TEST/CE/2021/1745 Date: 10/06/2021  
 Supplier : Director, H. M. Steel & Industry Limited  
 Ref. No. : H M STEEL/CUET/02/21 Date: 07/06/2021  
 Name of the Test : Diameter, Tensile Strength, Elongation, Unit Weight, Bend & Re-Bend Test of Rebar (Brand: H M XPERT B-500CWR).  
 Location : Not Available  
 Sample : Unsealed

| Nominal Dia | Actual Dia (mm) | Avg. Actual Dia (mm) | Yield Strength (MPa) | Avg. Yield Strength (MPa) | Ult. Strength (MPa) | Avg. Ult. Strength (MPa) | US/YS | Elongation (%) | Avg. Elongation (%) | Unit Weight (kg/m) | Avg. Unit Weight (kg/m) | Bend | Re-bend |
|-------------|-----------------|----------------------|----------------------|---------------------------|---------------------|--------------------------|-------|----------------|---------------------|--------------------|-------------------------|------|---------|
| 8           | 8.09            | 8.08                 | 505.3                | 509.8                     | 660.8               | 668.9                    | 1.31  | 19.00          | 19.43               | 0.41               | 0.41                    | S    | S       |
|             | 8.08            |                      | 516.3                |                           | 672.2               |                          | 1.3   | 19.90          |                     | 0.41               |                         |      |         |
|             | 8.07            |                      | 507.8                |                           | 673.8               |                          | 1.33  | 19.40          |                     | 0.41               |                         |      |         |
| 10          | 10.10           | 10.08                | 511.5                | 518.0                     | 648.7               | 643.3                    | 1.27  | 18.05          | 18.48               | 0.64               | 0.63                    | S    | S       |
|             | 10.04           |                      | 530.2                |                           | 643.8               |                          | 1.21  | 18.93          |                     | 0.63               |                         |      |         |
|             | 10.09           |                      | 512.3                |                           | 637.3               |                          | 1.24  | 18.45          |                     | 0.63               |                         |      |         |
| 12          | 12.02           | 12.02                | 537.1                | 537.4                     | 642.8               | 643.1                    | 1.2   | 16.83          | 16.61               | 0.90               | 0.90                    | S    | S       |
|             | 12.01           |                      | 537.9                |                           | 634.9               |                          | 1.18  | 16.75          |                     | 0.90               |                         |      |         |
|             | 12.02           |                      | 537.0                |                           | 651.5               |                          | 1.21  | 16.27          |                     | 0.90               |                         |      |         |
| 16          | 16.05           | 16.06                | 533.6                | 529.4                     | 667.0               | 669.1                    | 1.25  | 15.09          | 14.53               | 1.60               | 1.61                    | S    | S       |
|             | 16.07           |                      | 527.3                |                           | 670.2               |                          | 1.27  | 14.08          |                     | 1.61               |                         |      |         |
|             | 16.07           |                      | 527.3                |                           | 670.2               |                          | 1.27  | 14.42          |                     | 1.61               |                         |      |         |

Explanatory Notes: 1MPa = 145.048 psi, S=Satisfactory, U=Unsatisfactory.

ASTM A615-16 Weight Requirements & Nominal Area of bars (Table A1.1)

| Nominal Dia, mm      | 10    | 12    | 16    | 20    | 22    | 25    | 28    | 32    | 36    | 40    | 50    | 60   |
|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|------|
| Nominal Area, sq. mm | 79    | 113   | 201   | 314   | 380   | 491   | 616   | 804   | 1018  | 1257  | 1963  | 2827 |
| Nominal Weight, kg/m | 0.617 | 0.888 | 1.578 | 2.466 | 2.984 | 3.853 | 4.834 | 6.313 | 7.990 | 9.865 | 15.41 | 22.2 |

• Measured unit weight shall not be less than 94% of the nominal weight.

• Area & weight of 22mm dia bar is derived based on principle followed for other sizes in Table A1.1.

• Actual dia & US/YS ratio are provided for informative purpose only.

These are not requirements of ASTM A615M-16

#### ASTM A 615M-16 Tensile Requirements for Common Steel Grades

|                                  | Grade 60 (420) | Grade 75 (520) | Grade 80 (530) |
|----------------------------------|----------------|----------------|----------------|
| Tensile strength min. MPa (psi)  | 620 (90000)    | 690 (100000)   | 725 (105000)   |
| Yield strength, min MPa (psi)    | 420 (60000)    | 520 (75000)    | 550 (80000)    |
| Elongation in 200mm (8in), min % |                |                |                |
| Bar designation No.              |                |                |                |
| 10,12,16,20                      | 9              | 7              | 7              |
| 25,22                            | 8              | 7              | 7              |
| 28,32,36,40,50,60                | 7              | 6              | 6              |

Countersigned by

*24/06/2021*

Head

Department of Civil Engineering  
Chittagong University of Engineering and Technology



Test Conducted by

*20/6/21*  
Dr. Md. Moinul Islam  
Professor