1	mage not found of

typelunigate ARI TATA UDARA INDONESIA

ENGINEERING DIVISION

CHILLER

SERVICE	REPORT	PM -	MIN
----------------	--------	------	-----

Sales, Design, Service, Installation, Prepentive Maintenance Customer/User: Location o Site : Code/No. o				Ea.					Engineer Name List:				Date:			FORM NO.		
				ode/No. of Eq. :										Start Time	Stop Time			
																	Tipe Form PM07	
TASKLIS'	ľ										SERVIC	Е СН	ECI	K		1		
	_	Stan- dard	Actual Check						G _t 1	Measurement						a	Measurement	
Item	Freq.			No	1	Description	ı U	UoM	Standard	Before	After	No		Description	UoM	Standard	Before	After
INTENSIVE SAFETY BRIEFING TEAM		OK		1		EWT		°C	1	1	1	21		Ambient Temp	°C	max 35		
1. Losgsheet Parameter Unit	1	OK	1	2	1	LWT		°C	1	1	1	22	C	Outlet Air Temp	°C	max 40		
2. Inspect Condition Condensor coil	1	OK	1	3	N	Setpoint		°C	1	1	1	23	N	Sat. Cond Temp A	°C	max 45		
3. Cleaning Condensor coil	1	OK	1	4	I	Load		%	1	1	1	24	E	Sat. Cond Temp B	°C	max 45		
4. Cleaning Fan Condensor	1	OK	1	5	T	EXV Level		%	1	1	1	25	N	Air Flow	m/s			
5. Cleaning Component Unit	1	OK	1	6		Suction Press A	Ā	kPa	600-750	1	1	26	o	Ampere Fan 1	Amp			
6. Cleaning Strainer	1	OK	1	7		Discharge press	s A	kPa	2400-3200	1	1	27	R	Ampere Fan 2	Amp			
7. Check Physical Condition Unit	1	OK	1	8		Suction Press B		kPa	600-750	1	1	28	28	CHW Press In	Bar	3		
8. Check Part Fungction	1	011	1	9		Discharge press	s B	kPa	2400-3200	1	1	29		CHW Press Out	Bar	2		
(Compressor, TXV, Sensor, etc.)	İ	OK		10	C	C Sat. Suction Temp A		°C	0-5	1	1	30	C	CHW Temp In	°C			
9. Check Pressure Water in & Out	1	OK	1	11	O M	Sat. Suction Temp I		°C	0-5	1	1	31	ŏ	CHW Temp Out	°C			
10. Check Temperatur EWT & LWT	1	OK	1	12		P Oil Level A		%	50-75	1	1	32	L	Flow Switch status	ON	= close		
11. Check Actual Pressure Refrigerant	1	OK	1	13		Oil Level B	%	%	50-75	1	1		R	Flow Switch status	OFF	= open		
12. Check Motorize Valve Water	1	OK	1	14	S		L1-L2	V		1111	1	33		Flow Rate	gpm	30-177		
13. Syncronize All Program Match With BMS	1	OK	1	15		Voltage	L2-L3	V	380	1	1	?? Li	ngka	ri atau stabilo jika angka p	engukuran	kurang/lebih	dari standar	
14. Inspection Piping Chillwater	1	OK	1	16	O R		L3-L1	V	380	1	1	J P			RESU	ME		
15. Inspection Piping Refrigeration	1 0 0		1	17			A1	Amp	1	1	1	41	JO	B COMPLETED ?	? YES			
16. Checklist History PM		OK	1	18 19	-	Ampere	A2 Amp B1 Amp		1	1	11	-	•	z cominant				
? Checklist jika sesuai standar, jika tidak sesuai ditulis kondisi actualnya			l	20		i impere	B2	Amp Amp	1	1	1		? NO, please che			ck on NOTES		
FIND DH	nis konaisi a	сишнуи		-		S / RECOMME		_	•		*				SIGN	ING		
				1 —		ımbar saat PM diinfok			nnva.			1		Approved by	Verific		Service 1	By
				′-	6				,					ISS,		Supervisor,		Leader/Staf,
				Ш										155,		supervisor,	1 caiii L	æadei/Stai,
				Ш														
Keterangan : Lembar 1 untuk Teknisi; Lembar 2 un		1 24	· V ·	Щ								4						
Xeterangan : Lembar I untuk 1 eknisi; Lembar 2 un	шк User; Le	embar 3 Ai	sip Kantor															
													()	()	()