1	mage not found of

type Long LARI TATA UDARA INDONESIA

ENGINEERING DIVISION

CHILLER

SERVICE REPORT PM - MINI

Sales, Design, Service, Ins.	tallation, P	repentive l	Maintenance																
Customer/User:			Location of Eq. :						Engineer Name List:					Date:	FORM NO.				
														Start Time	Stop Time				
Site :			Code/No. of	f Eq. :										İ	İ		Ti	pe Form PM07	
TASKLIST							'				SERVICE	СН	ECI	K					
•.	Freq.	Stan- dard	Actual Check			D : 4:			G. 1 1	Measu	rement			D : 4:	UoM	Standard	Measurement		
Item				No	1	Descriptio	Description Uo		Standard	Before	After	No		Description			Before	After	
INTENSIVE SAFETY BRIEFING TEAM		OK		1		EWT		°C	1	1	1	21		Ambient Temp	°C	max 35			
Losgsheet Parameter Unit	1	OK	1	2	٦,	LWT		°C	1	1	1	22	C	Outlet Air Temp	°C	max 40			
2. Inspect Condition Condensor coil	1	OK	1	3	N	Setpoint		°C	1	1	1	23	N	Sat. Cond Temp A	°C	max 45			
3. Cleaning Condensor coil	1	OK	1	4	I	Load		%	1	1	1	24	E	Sat. Cond Temp B	°C	max 45			
4. Cleaning Fan Condensor	1	OK	1	5	T	EXV Level		%	1	1	1	25	N S	Air Flow	m/s				
5. Cleaning Component Unit	1	OK	1	6		Suction Press	A	kPa	600-750	1	1	26	ŏ	Ampere Fan 1	Amp				
6. Cleaning Strainer	1	OK	1	7		Discharge pres	s A	kPa	2400-3200	1	1	27	R	Ampere Fan 2	Amp				
7. Check Physical Condition Unit	1	OK	1	8	1	Suction Press	В	kPa	600-750	1	1	28		CHW Press In	Bar	3			
8. Check Part Fungction	1	OK	1	9		Discharge pres		kPa	2400-3200	1	1	29		CHW Press Out	Bar	2			
(Compressor , TXV, Sensor, etc.)		l OK		10	\int_{C}	Sat. Suction To	emp A	°C	0-5	1	1	30	CO	CHW Temp III	°C				
9. Check Pressure Water in & Out	1	OK	1	11	$\frac{1}{N}$	Sat. Suction To	emp B	°C	0-5	1	1	31	0	CHW Temp Out	°C				
10. Check Temperatur EWT & LWT	1	OK	1	12	P	Oil Level A		%	50-75	1	1	32	L	Flow Switch status		= close			
11. Check Actual Pressure Refrigerant	1	OK	1	13		Oil Level B		%	50-75				R			= open			
12. Check Motorize Valve Water	1	OK	1	14	$oldsymbol{S}$		L1-L2	_	380			33		Flow Rate	gpm	30-177			
3. Syncronize All Program Match With BMS 1 OK		1		15 S Voltage		L2-L3 V		380			?? Lingkari atau stabilo jika angka pengukuran kurang/l					dari standar			
14. Inspection Piping Chillwater	1	OK	1	16 17			L3-L1	V	380						RESU	ME			
15. Inspection Piping Refrigeration 1 OK 16. Checklist History PM 1 OK			1		18		A1 A2	Amp Amp					JO	OB COMPLETED ? ? YES					
		OK	1	19		Ampere	B1	Amp							? NO, please chec		ols on NOTES		
? Checklist jika sesuai standar, jika tidak sesuai dituli:	is kondisi ad	ctualnya		20			B2	Amp							? NO, p	iease cnec	K on NOTE	5	
FIND DH						NOTES / RECOMMENDATIONS							SIGNING						
*) Data gamb					gambar saat PM diinfo	nbar saat PM diinfokan melalui media laini			nnya.				Approved by	Verifi	ed By	Service l	Ву		
														ISS,	:	Supervisor,	Team Leader/Staf.		
				Ш										,		,		,	
				Ш															
Keterangan : Lembar 1 untuk Teknisi; Lembar 2 untu	uk User; Le	embar 3 Ar	sip Kantor	ш_								1							
,			•																
															,		,		
												_	()	()	()	