

# SERVICE REPORT PREVENTIVE MAINTENANCE P O M P A

FORM NO.

Tipe Form PM15

Team Engineer List :	Date :	Start PM :
		Close PM :

## SPESIFIKASI UNIT

Unit 1	Unit 2	Unit 3
Lokasi : 1	Lokasi : 1	Lokasi : 1
Code unit : 1	Code unit : 1	Code unit : 1
No. Unit : 1	No. Unit : 1	No. Unit : 1
Model : 1	Model : 1	Model : 1
No. Seri : 1	No. Seri : 1	No. Seri : 1
Capasatiy : 1	Capasatiy : 1	Capasatiy : 1

## TASK LIST

No.	Item Checked	Freq.	Unit 1		Unit 2		Unit 3	
			Standar	Actual	Standar	Actual	Standar	Actual
INTENSIVE SAFETY BRIEFING TEAM ? OK ? NOT OK								
1	Replace rubber coupling, mechanical seal, bearing motor & pumps, lacos filter							
2	Resistance test & megger motor							
3	Verify all pressure & temperature gauge replace if necessary							
4	Cleaning heat exchanger if available							
1	Cleaning Filter, Strainer, check valve,							
2	Cleaning & tightening pumps panels							

## SERVICE CHECKED

Unit	Condition	P In	P Out	J. Coupl.	MecSeal	Bearing	Voltage			Ampere		
							R	S	T	R	S	T
1	Before											
	Standard											
	After											
2	Before											
	Standard											
	After											
3	Before											
	Standard											
	After											

## NOTES

Temuan :	Rekomendasi :
----------	---------------

## RESUME

<b>JOB COMPLETED ?</b> ?    ? NO, please check on NOTES YES	<b>RUNNING HOURS :</b>
--	------------------------

## APPROVAL SIGNING

<b>Approved by</b> ISS,	<b>Verified By</b> Supervisor,	<b>Service By</b> Team Leader/Staf,
( _____ ) No. HP.	( _____ ) No. HP.	( _____ ) No. HP.

*Keterangan : Lembar 1 untuk Teknisi; Lembar 2 untuk User; Lembar 3 Arsip Kantor*