

SERVICE REPORT PREVENTIVE MAINTENANCE
PRECISION AIR CONDITIONING (PAC)
PT. HM SAMPOERNA SUKOREJO PLANT

Lokasi :	Model Unit :	Team Engineer List :
Code unit :	No. Seri :	
Nomor Unit :	Periode :	

CHECKLIST TEAM BRIEFING

INTENSIVE SAFETY BRIEFING TEAM

? OK

A Filter Section

Item Checked	Spec. Range / Cond. Std.	Actual Checked	Item Checked	Spec. Range
1. Check/Replace filters	Clean or Dirty		5. Clean condensate pan	Clean or Dirty
2. Grille area unrestricted	OK / Not OK		6. Clean trap in condensate drain	Clean or Dirty
3. Wipe section clean	Clean or Dirty		7. Check/Test filter-clog switch operation	Ok or No
4. Coil clean	Clean or Dirty			

B Blower Section

Item Checked	Spec. Range / Cond. Std.	Blower 1		Blower 2		Blower 3
		Before	After	Before	After	Before
1. Mounting bolts tight	Ok or No					
2. Fan-guard bolts tight	Ok or No					
3. Impeller spins freely	Ok or No					
4. Check/Test air sail switch	Ok or No					
5. Motor amp draw • Compare to nameplate amps	FLA L1 =..... A	L1	L1	L1	L1	L1
	FLA L2 =..... A	L2	L2	L2	L2	L2
	FLA L3 =..... A	L3	L3	L3	L3	L3
6. Check belt tension and condition	Ok or No					
7. Check sheave/pulley	Ok or No					

C Reheat

Item Checked	Spec. Range / Cond. Std.	Heater 1		Heater 2		Heater 3
		Before	After	Before	After	Before
1. Reheat amp draw	FLA =..... A					
2. Check Heater Resistance	18-22 ohm					
3. Inspect elements	Ok or No					
4. Check wire connections	Ok or No					

D Steam Generating Humidifier

Item Checked	Spec. Range	Actual Checked	Item Checked
1. Humidifier amp draw A		4. Check condition of steam hose
2. Check drain valve/drain lines/trap for damage/clogs/leaks	Ok or No		5. Clean strainer
3. Check water fill valve and all supply lines/connection for leaks	Ok or No		6. Check humidifier bottle (Boiler tank)
			7. Check operation of humidifier

E Electrical Panel

Item Checked	Spec. Range / Cond. Std.	Actual Checked	
		Before	After
1. Check fuses	Ok or No		

2.
Ch
eck
con
tact
ors
for
pitti
ng
(Re
pla
ce
if
pitt
ed)

Ok or No

3.
Ch
eck
/Re
-
tor
que
wir
e
con
nec
tio
ns

Ok or No