

PT. DIKARI TATA UDARA INDONESIA SERVICE REPORT PM Sales, Design, Service, Installation, Prepentive Maintenance AIR COOLED WATER CHILLER

Customer/User: DKR

Site: Ciomas

Location of Eq. :LT3

Engineer Name List :asd

Date :2024-11-09

FORM NO. COO-PM-11-24-00003

Code/No. of Eq. : asd

Start Time: 11:11 Stop Time: 11:11

Tipe Form PM02

	TASKLIST			
	Scope Of Work Maintenance Chiller	Freq.	Standard	Actual
	Elektrik			Check
	ENSIVE SAFETY ? OK ? NOT OK			
1	Check the evaporator refrigerant pressure and the	Wkly		
•	condenser refrigerant .		1	1
2	Check the liquid line sight glasses.	Wkly	1	1
3	Measure and record the system superheat.	1 M	3	3
4	Measure and record the system subcooling.	1 M	3	3
5	Manually rotate condenser fans to insure proper clearance.	1 M	3	3
6	Check the fan assemblies for proper clearance in the fan openings	6 M	3	3
7	Check motor shaft misalignment, abnormal end- play, vibration and noise.	6 M	3	3
8	Check the oil level and refrigerant charge.	6 M	3	3
9	Check oil analysis to determine system moisture content and acid level.	6 M	3	3
10	Leak test the chiller	6 M	3	3
11	Check operating and safety controls	6 M	3	3
12	Inspect electrical components for deficiencies.	6 M	3	3
13	Inspect all piping components for leakage and damage.	6 M	3	3
14	Clean out any inline strainers.	6 M	3	3
15	Clean and repaint any areas that show signs of corrosion.	6 M	3	3
16	Clean the condenser coils.	6 M	3	3
17	Clean the condenser fans.	6 M	3	3

	SERVICE CHECK		
Unit Serial Number : 3	Elevation (°)	:3	
Unit Model No. : 3	Nameplate Voltage (V)	:3	
Compressor A Serial : 3 No.	Fan Motor RLA	:3	
Compressor A : 3 Model No.	Evap Water Drop Press. (Ba	ar)	
Compressor B Serial :3 No.	Des. PSID :3	Act. PSID:3	
Compressor B : 3 Model No.	Des. GPM :3	Act. GPM :3	

Model No.	_						
Circuit	UoM	Standard	Ве	efore	Aft	Remarks	
Compressor			Cir A	Cir B	Cir A	Cir B	
	R-S	Volt	3	3	3	3	3
Unit Voltage	S-T	Volt	3	3	3	3	3
	T-R	Volt	3	3	3	3	3
	R	Amp	3	3	3	3	3
Comp. Amp	S	Amp	3	3	3	3	3
	Т	Amp	3	3	3	3	3
Unit Operating Mode		3	3	3	3	3	3
Last Diagnostic		3	3	3	3	3	3
Evap EWT		3	3	3	3	3	3
Evap LWT		3	3	3	3	3	3
Outdoor Air Temp.		5	5	5	5	5	5
Chilled Water Setpoint		5	5	5	5	5	5
Current Limit Setpoint		5	5	5	5	5	5
Sat. Evap. Ref. Temp.		5	5	5	5	5	5
Sat. Cond. Ref. Temp.		7	7	7	7	7	7

18	Clean panel control box	ox & Component 6 M 3 3			Condensor ref. press.	8	8	8	8	8	8	
19	Check all sensor (Condi	, , , , , , , , , , , , , , , , , , , ,				Evaporator ref. Press.	9	9	9	9	9	9
20	Check Cooler & Pipe Ins	sulation	6 M	3	3	Compressor RLA	9	9	9	9	9	9
21	Check Condensor air ve	locity	6 M	3	3	Compressor start	9	9	9	9	9	9
	FIND DH	*) Data gambar saat PM diinfokan melalui media lainnya.				Compressor hours	9	9	9	9	9	9
						Compressor hours	9	9	9	9	9	9
						Oil Level Compressor	9	9	9	9	9	9

	Foto Equipment		
No	Gambar	Info	Keterangan
1		9	Before
	Foto Parameter		
No	Gambar	Info	Keterangan
		9	Before