

<div><div></div><div>PT DIKARI TATA UDARA INDONESIA</div><div>ENGINEERING DIVISION</div><div>CHILLER</div><div>Sales, Design, Service, Installation, Prepentive Maintenance</div></div>		SERVICE REPORT PM - MINI																
Customer/User :				Location of Eq. :				Engineer Name List :				Date :		FORM NO.				
Site :				Code/No. of Eq. :								Start Time		Stop Time				
														Tipe Form PM07				
TASKLIST				SERVICE CHECK														
Item		Freq.	Stand-ard	Actual Check	No	Description		UoM	Standard	Measurement		No	Description		UoM	Standard	Measurement	
										Before	After						Before	After
INTENSIVE SAFETY BRIEFING TEAM			OK		1	EWT		°C	1	1	1	21	Ambient Temp		°C	max 35	1	1
1. Losgsheet Parameter Unit		1	OK	1	2	LWT		°C	1	1	1	22	Outlet Air Temp		°C	max 40	1	1
2. Inspect Condition Condensor coil		1	OK	1	3	Setpoint		°C	1	1	1	23	Sat. Cond Temp A		°C	max 45	1	1
3. Cleaning Condensor coil		1	OK	1	4	Load		%	1	1	1	24	Sat. Cond Temp B		°C	max 45	1	1
4. Cleaning Fan Condensor		1	OK	1	5	EXV Level		%	1	1	1	25	Air Flow		m/s	1	1	1
5. Cleaning Component Unit		1	OK	1	6	Suction Press A		kPa	600-750	1	1	26	Ampere Fan 1		Amp	1	1	1
6. Cleaning Strainer		1	OK	1	7	Discharge press A		kPa	2400-3200	1	1	27	Ampere Fan 2		Amp	1	1	1
7. Check Physical Condition Unit		1	OK	1	8	Suction Press B		kPa	600-750	1	1	28	CHW Press In		Bar	3	1	1
8. Check Part Fungtion		1	OK	1	9	Discharge press B		kPa	2400-3200	1	1	29	CHW Press Out		Bar	2	1	1
( Compressor , TXV, Sensor, etc. )			OK		10	Sat. Suction Temp A		°C	0-5	1	1	30	CHW Temp In		°C	1	1	1
9. Check Pressure Water in & Out		1	OK	1	11	Sat. Suction Temp B		°C	0-5	1	1	31	CHW Temp Out		°C	1	1	1
10. Check Temperatur EWT & LWT		1	OK	1	12	Oil Level A		%	50-75	1	1	32	Flow Switch status		ON = close OFF = open	1	1	
11. Check Actual Pressure Refrigerant		1	OK	1	13	Oil Level B		%	50-75	1	1	33	Flow Rate		gpm	30-177	1	1
12. Check Motorize Valve Water		1	OK	1	14			L1-L2	V	380	1111	1	?? Lingkari atau stabilo jika angka pengukuran kurang/lebih dari standar					
13. Synchronize All Program Match With BMS		1	OK	1	15	Voltage		L2-L3	V	380	1	1	RESUME					
14. Inspection Piping Chillwater		1	OK	1	16			L3-L1	V	380	1	1						
15. Inspection Piping Refrigeration		1	OK	1	17	Ampere		A1	Amp	1	1							
16. Checklist History PM		1	OK	1	18			A2	Amp	1	1							
					19			B1	Amp	1	1	JOB COMPLETED ? ? YES						
					20			B2	Amp	1	1							? NO, please check on NOTES
? Checklist jika sesuai standar, jika tidak sesuai ditulis kondisi actualnya				NOTES / RECOMMENDATIONS														
FIND DH				*) Data gambar saat PM diinfokan melalui media lainnya.														
Keterangan : Lembar 1 untuk Teknisi; Lembar 2 untuk User; Lembar 3 Arsip Kantor																		
				SIGNING														
				Approved by ISS,														
				Verified By Supervisor,														
				Service By Team Leader/Staf,														
				(                    )                    (                    )                    (                    )														