

<div><div></div><div>PT DIKARI TATA UDARA INDONESIA</div><div>ENGINEERING DIVISION</div><div>CHILLER</div><div>Sales, Design, Service, Installation, Prepentive Maintenance</div></div>		SERVICE REPORT PM - MINI																																	
Customer/User :				Location of Eq. :				Engineer Name List :				Date :		FORM NO.																					
Site :				Code/No. of Eq. :								Start Time		Stop Time																					
												Tipe Form PM07																							
TASKLIST				SERVICE CHECK																															
<table><tr><th rowspan="2">Item</th><th rowspan="2">Freq.</th><th rowspan="2">Stand-ard</th><th rowspan="2">Actual Check</th></tr><tr></tr></table>				Item	Freq.	Stand-ard	Actual Check	<table><tr><th rowspan="2">No</th><th rowspan="2">Description</th><th rowspan="2">UoM</th><th rowspan="2">Standard</th><th colspan="2">Measurement</th><th rowspan="2">No</th><th rowspan="2">Description</th><th rowspan="2">UoM</th><th rowspan="2">Standard</th><th colspan="2">Measurement</th></tr><tr><th>Before</th><th>After</th><th>Before</th><th>After</th></tr></table>												No	Description	UoM	Standard	Measurement		No	Description	UoM	Standard	Measurement		Before	After	Before	After
Item	Freq.	Stand-ard	Actual Check																																
No	Description	UoM	Standard	Measurement		No	Description	UoM	Standard	Measurement																									
				Before	After					Before	After																								
INTENSIVE SAFETY BRIEFING TEAM				1	EWT	°C	1	1	1	21	Ambient Temp	°C	max 35	1	1																				
1. Losgsheet Parameter Unit				2	LWT	°C	1	1	1	22	Outlet Air Temp	°C	max 40	1	1																				
2. Inspect Condition Condensor coil				3	Setpoint	°C	1	1	1	23	Sat. Cond Temp A	°C	max 45	1	1																				
3. Cleaning Condensor coil				4	Load	%	1	1	1	24	Sat. Cond Temp B	°C	max 45	1	1																				
4. Cleaning Fan Condensor				5	EXV Level	%	1	1	1	25	Air Flow	m/s	1	1	1																				
5. Cleaning Component Unit				6	Suction Press A	kPa	600-750	1	1	26	Ampere Fan 1	Amp	1	1	1																				
6. Cleaning Strainer				7	Discharge press A	kPa	2400-3200	1	1	27	Ampere Fan 2	Amp	1	1	1																				
7. Check Physical Condition Unit				8	Suction Press B	kPa	600-750	1	1	28	CHW Press In	Bar	3	1	1																				
8. Check Part Fungction				9	Discharge press B	kPa	2400-3200	1	1	29	CHW Press Out	Bar	2	1	1																				
(Compressor , TXV, Sensor, etc.)				10	Sat. Suction Temp A	°C	0-5	1	1	30	CHW Temp In	°C																							
9. Check Pressure Water in & Out				11	Sat. Suction Temp B	°C	0-5	1	1	31	CHW Temp Out	°C																							
10. Check Temperatur EWT & LWT				12	Oil Level A	%	50-75	1	1	32	Flow Switch status	ON = close OFF = open																							
11. Check Actual Pressure Refrigerant				13	Oil Level B	%	50-75	1	1	33	Flow Rate	gpm	30-177																						
12. Check Motorize Valve Water				14	Voltage	L1-L2	V	380	1111	1	?? Lingkari atau stabilo jika angka pengukuran kurang/lebih dari standar																								
13. Synchronize All Program Match With BMS				15		L2-L3	V	380	1	1																									
14. Inspection Piping Chillwater				16		L3-L1	V	380	1	1																									
15. Inspection Piping Refrigeration				17	Ampere	A1	Amp	1	1	1	RESUME																								
16. Checklist History PM				18		A2	Amp	1	1	1																									
				19		B1	Amp	1	1	11																									
				20		B2	Amp	1	1	1																									
? Checklist jika sesuai standar, jika tidak sesuai ditulis kondisi actualnya				NOTES / RECOMMENDATIONS																															
FIND DH				*) Data gambar saat PM diinfokan melalui media lainnya.																															
Keterangan : Lembar 1 untuk Teknisi; Lembar 2 untuk User; Lembar 3 Arsip Kantor				SIGNING																															
				Approved by				Verified By				Service By																							
				ISS,				Supervisor,				Team Leader/Staf,																							
				() () ()																															