nage not found or t	PT. DIKARI TATA UDARA INDONESIA SERVICE REPORT PI	V
	Sales, Design, Service, Installation, Prepentive Maintenance AIR COOLED WATER CHILLE	R

		Sales, Design, Service, Installation, Prepentive Maintenance AIR COOLED WATER CHILLER									
(Customer/User : DKR	Location of Eq. :LT3	Engineer Name List :	Date :		FORM NO.					
ŀ	Site : Ciomas	Code/No. of Eq. : 12		Start Time	Stop Time						
l						Tipe Form					

	TASKLIST													
	Scope Of Work Maintenance Chiller Elektrik	Freq.	Standard	Actual Check										
	NTENSIVE SAFETY ? OK ? NOT OK BRIEFING TEAM													
1	Check the evaporator refrigerant pressure and the condenser refrigerant .	Wkly	1	1										
2	Check the liquid line sight glasses.	Wkly	1	1										
3	Measure and record the system superheat.	1 M	1	1										
4	Measure and record the system subcooling.	1 M	1	1										
5	Manually rotate condenser fans to insure proper clearance.	1 M	1	1										
6	Check the fan assemblies for proper clearance in the fan openings	6 M	1	1										
7	Check motor shaft misalignment, abnormal end- play, vibration and noise.	6 M	1	1										
8	Check the oil level and refrigerant charge.	6 M	1	1										
9	Check oil analysis to determine system moisture content and acid level.	6 M	1	1										
10	Leak test the chiller	6 M	1	1										
11	Check operating and safety controls	6 M	1	1										
12	Inspect electrical components for deficiencies.	6 M	1	1										
13	Inspect all piping components for leakage and damage.	6 M	1	1										
14	Clean out any inline strainers.	6 M	1	1										
15	Clean and repaint any areas that show signs of corrosion.	6 M	1	1										
16	Clean the condenser coils.	6 M	1	1										
17	Clean the condenser fans.	6 M	1	1										

	SERV	ICE CHECK	
Unit Serial Number :	1	Elevation (°)	:1
Unit Model No. :	1	Nameplate Voltage (V)	:1
 Compressor A Serial: No.	1	Fan Motor RLA	:1
Compressor A : Model No.	1	Evap Water Drop Press. (Bar)	
Compressor B Serial :1 No.		Des. PSID :1	Act. PSID:1
Compressor B : Model No.	1	Des. GPM : 1	Act. GPM :1

Circuit	UoM	Standard	Ве	efore	Aft	er	Remarks	
Compressor		Otandara,	Cir A	Cir B	Cir A	Cir B	Kemarko	
	R-S	Volt	35	36	37	38	39	
Unit Voltage	S-T	Volt	35	36	37	38	39	
	T-R	Volt	35	36	37	38	39	
	R	Amp	40	41	42	43	44	
Comp. Amp	S	Amp	40	41	42	43	44	
	Т	Amp	40	41	42	43	44	
Unit Operating Mode		45	45	45	45	45	45	
Last Diagnostic		46	46	46	46	46	46	
Evap EWT		47	47	47	47	47	47	
Evap LWT		48	48	48	48	48	48	
Outdoor Air Temp.		49	49	49	49	49	49	
Chilled Water Setpoint		50	50	50	50	50	50	
Current Limit Setpoint		51	51	51	51	51	51	
Sat. Evap. Ref. Temp.		52	52	52	52	52	52	
Sat. Cond. Ref. Temp.		53	53	53	53	53	53	

18	Clean panel control box	& Component	6 M	1	1	Condensor ref. press.	5	4	54	54	54	54	54	
19 Check all sensor (Condition & read) 6 M		1	1	Evaporator ref. Press.	5	5	55	55	55	55	55			
20	Check Cooler & Pipe In	sulation	6 M	1	1	Compressor RLA	5	6	56	56	56	56	56	
21 Check Condensor air velocity		6 M	1	1	Compressor start	5	7	57	57	57	57	57		
FIND DH NOTES / RECOMMENDATIONS				NS	Compressor hours	5	8	58	58	58	58	58		
*) Data gambar saat PM diinfokan melalui media lainnya.					Compressor hours	5	9	59	59	59	59	59		
					Oil Level Compressor	6	0	60	60	60	60	60		
				RESUME	APPROVAL SIGNING		NING							
					Approved by		ed by	Verified By			Service By			
					JOB COMPLETED ?	ISS,			Supervisor,			Team Leader/Staf,		
						? YES ? NO, please check on	() No. HP.			() No. HP.		No	() No. HP.	
Kete	rangan : Lembar 1 untuk	NOTES												