1	mage not found of

## typelunigate ARI TATA UDARA INDONESIA

ENGINEERING DIVISION

## **CHILLER**

<b>SERVICE</b>	REPORT	PM -	MIN
		- IVI -	

Sales, Design, Service, Installation, Prepentive Maintenan Customer/User: Location									Engineer Name List:					Date:			FORM NO.	
													Start Time	Stop Time				
Site : Code/No.																Tipe Form PM07		
TASKLIS'	r			П							SERVIC	E CHI	ECI	K		1		
	Freq.	Stan- dard	Actual Check			5	tion		a	Measu	rement				Standard	Measurement		
Item				No		Description		UoM	Standard	Before	After	No		UoM		Before	After	
INTENSIVE SAFETY BRIEFING TEAM		OK		1		EWT		°C	1	1	1	21	_	Ambient Temp	°C	max 35		
Losgsheet Parameter Unit	1	OK	1	2 ,		LWT		°C	1	1	1	22	C	Outlet Air Temp	°C	max 40		
2. Inspect Condition Condensor coil	1	OK	1	3		N Setpoint		°C	1	1	1 23	23	N	Sat. Cond Temp A	°C	max 45		
3. Cleaning Condensor coil	1	OK	1	4 5	I	Load		%	1	1	1	24		Sat. Cond Temp B	°C	max 45		
4. Cleaning Fan Condensor	1	OK	1			EXV Level	%	%	1			25	N S	Air Flow	m/s			
5. Cleaning Component Unit	1	OK	1 6		1	Suction Press A	1	kPa	a 600-750			26	0	Ampere Fan 1	Amp			
6. Cleaning Strainer	1	OK	1		Discharge pres		s A	kPa	2400-3200			27	R	Ampere Fan 2	Amp			
7. Check Physical Condition Unit	1	OK	1	8		Suction Press B		kPa	600-750			28		CHW Press In	Bar	3		
8. Check Part Fungction	1	OV	1	9		Discharge press B		kPa	2400-3200			29		CHW Press Out	Bar	2		
(Compressor, TXV, Sensor, etc.)		OK		10 C		Sat. Suction Te	mp A	°C	0-5			30	C	CHW Temp In	°C			
9. Check Pressure Water in & Out	1	OK	1	11			mp B	°C	0-5			31		CHW Temp Out	°C			
10. Check Temperatur EWT & LWT	1	OK	1	12				%	50-75			1	L	Eleme Constante et atom	ON	= close		
11. Check Actual Pressure Refrigerant	1	OK	1	13	R	Oil Level B	%		50-75			32	E Flow Switch statu	Flow Switch status	OFF = open			
12. Check Motorize Valve Water	1	OK	1	14	S		L1-L2	V	380			33		Flow Rate	gpm	30-177		
13. Syncronize All Program Match With BMS	1	OK	1	15	$\mathbf{S}$	Voltage	L2-L3	V	380			?? Li	ngka	ri atau stabilo jika angka p	engukuran	kurang/lebih	dari standar	
14. Inspection Piping Chillwater	1	OK	1	16	O R		L3-L1	V	380						RESU	ME		
15. Inspection Piping Refrigeration			1	17	/ AI AIII		Amp				<b>!</b>	m	B COMPLETED ?	2 2 VES				
16. Checklist History PM 1 OK  ? Checklist jika sesuai standar, jika tidak sesuai ditulis kondisi actualnya		OK	1	18		Ampere	A2	Amp				41	30	D COMI LETED.	. ILS			
					19 Ampere 20			Amp Amp				<del> </del>			? NO, please check on NOTES			
? Checklist jika sesuai standar, jika tidak sesuai ditu FIND DH	ılıs kondisi a	ctualnya				S / RECOMME									SIGN	INC		
FIND DH						mbar saat PM diinfok			nnva					Approved by	Verific		Service 1	Rv
				'	ши ди	mour saai 1 m ainjok	ан тешин	пеши ш	nnya.				-			•		•
				Ш										ISS,	,	Supervisor,	Team L	eader/Staf,
				Ш														
				Ш								Ц						
Keterangan : Lembar 1 untuk Teknisi; Lembar 2 un	tuk User; Le	mbar 3 Aı	sip Kantor															
													,	,	,		,	,