

PROGRESS OM ACTUATOR VALVE UNIT 1



FINISH	IN PROGRESS	TOTAL	% IN PROGRESS	% FINISH
0	0	0	0.00	0.00

AREA	DESCRIPTION	FINISH DATE	PIC	PROGRESS	%	REMARKS
BOILER	ACTUATOR FEED WATER CONTROL VALVE 100% 10LAB30AA210		AMP	FINISH	100	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☒	
BOILER	ACTUATOR FEED WATER CONTROL VALVE 30% 10LAB30AA210		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
BOILER	ACTUATOR DESH-1 SPRAY WATER ISOLATION		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
BOILER	ACTUATOR DESH-1 SPRAY WATER CONTROL VALVE		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
BOILER	ACTUATOR DESH-2 SPRAY WATER ISOLATION		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
BOILER	ACTUATOR DESH-2 SPRAY WATER CONTROL VALVE		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
BOILER	ACTUATOR FUEL COAL GATE VALVE 1 (MFT-1) 10HHE11AA01		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
BOILER	ACTUATOR FUEL COAL GATE VALVE 2 (MFT-2) 10HHE12AA01		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
ID FAN	ACTUATOR IGV ID FAN 1 10HNC01EX001		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
ID FAN	ACTUATOR IGV ID FAN 2 10HNC01EX002		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
ID FAN	ACTUATOR INLET ID FAN 1 MOV 10HNA61AA001		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
ID FAN	ACTUATOR INLET ID FAN 2 MOV 10HNA62AA001		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
ID FAN	ACTUATOR OUTLET ID FAN 1 MOV 10HNA71AA001		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
ID FAN	ACTUATOR OUTLET ID FAN 2 MOV 10HNA72AA001		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
STG	BFP SPRAY LINE (FEED WATER) TO DEAERATOR PRDS I/L MOV 10LAE10AA110		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
STG	ACTUATOR MAIN STEAM LINE (START UP BYPASS) TO DEAERATOR PRDS I/L CV 10LBH10AA210		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
STG	ACTUATOR BFP SPRAY LINE (FEED WATER) TO DEAERATOR PRDS I/L CV 10LAE10AA210		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
STG	ACTUATOR TURBINE EXTRACTION III TO DEAERATOR CV 10LBD10AA210		AMP	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
STG	MOV DISCHARGE BFP-1		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
STG	MOV DISCHARGE BFP-2		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☒	
	FUNCTION TEST		AMP		☐	
PA FAN	ACTUATOR MOV OUTLET PA FAN 1		MSW	SCHED-OK	0	

	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
PA FAN	ACTUATOR MOV PA FAN 1		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
BOILER	ACTUATOR ISOLATION STARTUP VENTING BOILER		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR IGV SA FAN 1 10HLB01EX001		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR IGV SA FAN 2 10HLB02EX001		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR IGV SA CONTROL DAMPER 10HLA25AA010		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR IGV SUB 1 10HJL10AA010		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR IGV SUB 2 10HJL11AA010		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR BED MATERIAL DISCHARGE GATE VALVE 10ETG31AA01		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR VALVE DRAIN SOOT BLOWER 10HCB10AA101		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☐	
	FUNCTION TEST		AMP		☐	
BOILER	COMBUSTER ASH DRAIN 1 (BED ASH COLLER DRAIN) MOV 10HHC01AA001		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	COMBUSTER ASH DRAIN 2 (EMERGENCY ASH DRAIN) MOV 10HHC01AA002		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☐	
	FUNCTION TEST		AMP		☐	
BOILER	SOOT BLOWER CONTROL VALVE		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	SOOT BLOWER ISOLATION VALVE MOV 10HCB10AA001		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	MS START UP VENT VALVE (REG) MOV 10LBA21AA011		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	MS START UP VENT VALVE (ISO) MOV 10LBA21AA001		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	ACTUATOR SOOT BLOWER CV 10HCB10EX001		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
BOILER	ACTUATOR DAMPER SEALPOT BLOWER 1		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
BOILER	ACTUATOR DAMPER SEALPOT BLOWER 2		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
BOILER	COMBUSTER ASH DRAIN 1 (BED ASH COLLER DRAIN) MOV 10HHC01AA001		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	COMBUSTER ASH DRAIN 2 (EMERGENCY ASH DRAIN) MOV 10HHC01AA002		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
BOILER	FLUIDIZING VALVE BED MATERIAL		MSW	IN PROGRESS	50	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
BOILER	FLUIDIZING VALVE LIMESTONE 1&2		MSW	IN PROGRESS	50	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
DRUM	ACTUATOR STEAM DRUM VENTING ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
DRUM	ACTUATOR STEAM DRUM MOV VENTING VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
DRUM	ACTUATOR STEAM DRUM CBD ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	

	Function Test		MSW		☐	
DRUM	ACTUATOR STEAM DRUM MOV CBD CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
DRUM	ACTUATOR STEAM DRUM IBD ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
DRUM	ACTUATOR STEAM DRUM MOV IBD CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
PA FAN	ACTUATOR MOV OUTLET PA FAN 2		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
PA FAN	ACTUATOR MOV PA FAN2		MSW	IN PROGRESS	50	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
SA FAN	ACTUATOR MOV OUTLET SA FAN 1		MSW	IN PROGRESS	50	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
SA FAN	ACTUATOR MOV OUTLET SA FAN 2		MSW	IN PROGRESS	50	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
STG	ACTUATOR HP BYPASS CONTROL VALVE 10LBF10AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☐	
	FUNCTION TEST		AMP		☐	
STG	ACTUATOR CONDENSATE PUMP RECIRCULATION CONTROL VALVE 10LCA31AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	ACTUATOR MAIN CONDENSATE CONTROL VALVE 10LCA30AA240		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	ACTUATOR GLAND STEAM PRESSURE CONTROL VALVE 10MAW10AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	ACTUATOR GLAND STEAM TEMP. CONTROL VALVE 10LCE10AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☐	
	FUNCTION TEST		AMP		☐	
STG	ACTUATOR BYPASS SPRAY CONTROL VALVE 10LCE40AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		AMP		☐	
	FUNCTION TEST		AMP		☐	
STG	CEP DISCHARGE VALVE		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
STG	DISCHARGE, SUCTION & VENTING VALVE VACUM PUMP-1 & 2		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	MOV MAIN STEAM DRAIN STG-2		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	DRAIN OF ESV 10MAL10AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	DRAIN OF CV CHAMBER 10MAL10AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	TURBINE DRAIN VALVE AFTER FIRST STAGE 10MAL30AA210		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	TURBINE DRAIN VALVE 10MAL40AA210		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
STG	TURBINE DRAIN VALVE 10MAL50AA210		MSW	IN PROGRESS	50	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☒	
	FUNCTION TEST		MSW		☐	
STG	TURBINE DRAIN VALVE 10MAL60AA210		MSW	IN PROGRESS	50	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
STG	TURBINE DRAIN VALVE 10MAL70AA210		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☐	
STG	CONTROL VALVE LPH-2		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	CONTROL VALVE LPH-1		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	

STG	MOV TURBINE STEAM EXTRACTION-1 & 2		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
STG	ACTUATOR MOV TURBINE STOP VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
STG	ACTUATOR MOV PREHEATING 1 TURBINE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
STG	ACTUATOR MOV PREHEATING 2 TURBINE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
STG	ACTUATOR ON/OFF NRV STEAM EXTRACTION 1, 2, 3		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
STG	ACTUATOR ON/OFF VALVE CEP-1 & CEP-2		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SUB BURNER 1 VALVE 10HJN11AA003		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
SUB	ACTUATOR SUB BURNER 2 VALVE 10HJN12AA003		MSW	SCHED-OK	0	
	GENERAL INSPECTION, CALIBRATION AND CLEANING		MSW		☐	
	FUNCTION TEST		MSW		☐	
SUB	ACTUATOR SKID BURNER MAIN LDO LINE CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 1 LDO LINE CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 1 ATOMISING AIR LINE CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 2 LDO LINE CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 2 ATOMISING AIR LINE CONTROL VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 1 ATOM AIR ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 1 LDO ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 1 SCAVENGING VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 2 ATOM AIR ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 2 LDO ISOLATION VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
SUB	ACTUATOR SKID BURNER 2 SCAVENGING VALVE		MSW	SCHED-OK	0	
	General Inspection, Calibration and Cleaning		MSW		☐	
	Function Test		MSW		☐	
BOILER	ACTUATOR MOV INLET ECONOMIZER		MSW	FINISH	100	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☒	
BOILER	ACTUATOR MOV RECIRCULATION ECONOMIZER		MSW	FINISH	100	
	General Inspection, Calibration and Cleaning		MSW		☒	
	Function Test		MSW		☒	