

PROGRESS JOBS OUTAGE UNIT 1



SECTION ELECTRIC, INSTRUMENT, CONTROL (EIC)

SCHED-OK	FINISH	IN PROGRESS	TOTAL	% FINISH	1 PROGRES
26	3	35	64	36.1%	2311.2

NO	NO WO	JOB DESCRIPTION	DATED			STATUS	PIC	N Task	%Estimation	SCOPE	REMARKS
			SCHEDULE	ACTUAL START	FINISH						
1	WO-100826-0012	OM EIC Y1 UNIT COMMON COOLING TOWER FAN 1	22/8/2026			IN PROGRESS	Aldhly	9	89	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR							☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)							☒		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)							☒		
		INSPECTION TAHANAN ISOLASI							☒		
		INSPECTION TAHANAN WINDING							☒		
		INSPECTION COOLING FAN							☒		
		INSPECTION TERMINASI							☒		
		INSPECTION KONEKSI GROUNDING SYSTEM							☒		
		SOLO RUN							☐		
2	WO-100826-0013	OM EIC Y1 UNIT COMMON COOLING TOWER FAN 2	22/8/2026			IN PROGRESS	Aldhly	9	89	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION TAHANAN WINDING	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☒		
		SOLO RUN	22/8/2026						☐		
3	WO-100826-0014	OM EIC Y1 UNIT COMMON MAIN COOLING WATER PUMP 1	22/8/2026			IN PROGRESS	Aldhly	9	78	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION TAHANAN WINDING	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☒		
		SOLO RUN	22/8/2026						☐		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	22/8/2026						☐		
4	WO-100826-0015	OM EIC Y1 UNIT COMMON MAIN COOLING WATER PUMP 2	22/8/2026			IN PROGRESS	Aldhly	9	78	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION TAHANAN WINDING	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☒		
		SOLO RUN	22/8/2026						☐		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	22/8/2026						☐		
5	WO-100826-0016	OM EIC Y1 UNIT COMMON AUXILIARY COOLING WATER PUMP 1	22/8/2026			IN PROGRESS	Aldhly	9	56	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026						☐		
		INSPECTION BEARING & REPLACEMENT	22/8/2026						☐		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION TAHANAN WINDING	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☐		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	22/8/2026						☐		
6	WO-100826-0017	OM EIC Y1 UNIT COMMON AUXILIARY COOLING WATER PUMP 2	22/8/2026			IN PROGRESS	Aldhly	9	67	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026						☐		
		INSPECTION BEARING & REPLACEMENT	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION TAHANAN WINDING	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☐		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	22/8/2026						☐		
7	WO-100826-0160	OM EIC Y1 UNIT 1 INDUCED DRAUGHT FAN 1	22/8/2026			IN PROGRESS	M. Toher	14	62	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		UNIT 1 INDUCED DRAUGHT FAN 1 INLET GATE ACTUATOR MOV 20HNA61AA001	22/8/2026				AMP		☐		
		UNIT 1 INDUCED DRAUGHT FAN 1 OUTLET GATE ACTUATOR MOV 20HNA71AA001	22/8/2026				AMP		☐		
		MSW20HNC10-M103:UNIT 1 INDUCED DRAUGHT FAN 1 MOTOR	22/8/2026				JAPA		☒		
		REPOSISI MOTOR	22/8/2026				JAPA		☒		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	22/8/2026				JAPA		☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE (REPLACE BEARING IF NEEDED)	22/8/2026				JAPA		☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	22/8/2026				JAPA		☒		
		PENGUKURAN TAHANAN BELITAN	22/8/2026				JAPA		☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	22/8/2026				JAPA		☒		
		UNIT 1 INDUCED DRAUGHT FAN 1 IGW 10HNC01EX001	22/8/2026				AMP		☒		
		INLET ID FAN 1 PRESSURE TRANSMITTER 10HNA61CP001	22/8/2026				JAPA		☐		
		INLET PRESSURE ESP PRESSURE TRANSMITTER 10HNA41CP001	22/8/2026				JAPA		☐		
		OUTLET PRESSURE ESP PRESSURE TRANSMITTER 10HNA41CP002	22/8/2026				JAPA		☐		
		SOLO RUN	22/8/2026				MSW		☐		
8	WO-100826-0161	OM EIC Y1 UNIT 1 INDUCED DRAUGHT FAN 2	22/8/2026			SCHED-OK	M. Toher	12	0	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		UNIT 1 INDUCED DRAUGHT FAN 2 INLET ACTUATOR MOV 20HNA62AA001	22/8/2026				AMP		☐		
		UNIT 1 INDUCED DRAUGHT FAN 2 OUTLET ACTUATOR MOV 20HNA72AA001	22/8/2026				AMP		☐		
		MSW20HNC10-M203:UNIT 1 INDUCED DRAUGHT FAN 2 MOTOR	22/8/2026				JAPA		☐		
		REPOSISI MOTOR	22/8/2026				JAPA		☐		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	22/8/2026				JAPA		☐		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE (REPLACE BEARING IF NEEDED)	22/8/2026				JAPA		☐		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	22/8/2026				JAPA		☐		

		PENGUKURAN TAHANAN BELITAN	22/8/2026		JAPA		☐		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	22/8/2026		JAPA		☐		
		UNIT 1 INDUCED DRAUGHT FAN 2 IGV 10HNC01EX002	22/8/2026		AMP		☐		
		SOLO RUN	22/8/2026		MSW		☐		
		INLET ID FAN 2 PRESSURE TRANSMITTER 10HNA62CP001	22/8/2026		JAPA		☐		
9	WO-100826-0020	OM EIC Y1 UNIT 1 PRIMARY AIR FAN 1	22/8/2026	IN PROGRESS	M. Zaini	10	80	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	22/8/2026		JAPA		☒		
		DISSASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	22/8/2026		JAPA		☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	22/8/2026		JAPA		☒		
		REPLACE BEARING IF NEEDED	22/8/2026		JAPA		☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	22/8/2026		JAPA		☒		
		PENGUKURAN TAHANAN BELITAN	22/8/2026		JAPA		☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	22/8/2026		JAPA		☒		
		UNIT 1 PRIMARY AIR FAN 1 IGV	22/8/2026		MSW		☐		
		UNIT 1 PRIMARY AIR FAN 1 OUTLET MOV	22/8/2026		MSW		☐		
		PA FAN 1 OUTLET PRESSURE TRANSMITTER 10HLB03CP001	22/8/2026		JAPA		☒		
10	WO-100826-0021	OM EIC Y1 UNIT 1 PRIMARY AIR FAN 1 LUBE OIL SYSTEM	22/8/2026	IN PROGRESS	Aldhy	6	67	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN20-M101:UNIT 1 PRIMARY AIR FAN 1 LUBE OIL PUMP 1 MOTOR (STAND BY)	22/8/2026				☒		
		MSW20HLN20-M102:UNIT 1 PRIMARY AIR FAN 1 LUBE OIL PUMP 2 MOTOR (MAIN)	22/8/2026				☒		
		20HLB01CP104: LO HEADER PRESSURE LOW ALARM FOR PA FAN-1	22/8/2026				☒		
		20HLB01CP103: PRESSURE SWITCH TO START PERMISSIVE FOR PA FAN-1 START	22/8/2026				☒		
		20HLB01CP102: PRESSURE SWITCH TO START LO PA FAN-1 STANDBY PUMP	22/8/2026				☐		
		20HLB01CP101: DP SWITCH ACROSS LO TANK FOR PA FAN-1	22/8/2026				☐		
11	WO-100826-0022	OM EIC Y1 UNIT 1 PRIMARY AIR FAN 2	22/8/2026	IN PROGRESS	M. Zaini	10	80	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	22/8/2026				☒		
		DISSASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	22/8/2026				☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	22/8/2026				☒		
		REPLACE BEARING IF NEEDED	22/8/2026				☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	22/8/2026				☒		
		PENGUKURAN TAHANAN BELITAN	22/8/2026				☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	22/8/2026				☒		
		UNIT 1 PRIMARY AIR FAN 2 IGV	22/8/2026				☐		
		MSW20HLB20AA202:UNIT 1 PRIMARY AIR FAN 2 OUTLET MOV	22/8/2026				☐		
		PA FAN 2 OUTLET PRESSURE TRANSMITTER 10HLB04CP001	22/8/2026				☒		
12	WO-100826-0014	OM EIC Y1 UNIT 1 PRIMARY AIR FAN 2 LUBE OIL SYSTEM	22/8/2026	IN PROGRESS	Aldhy	6	83	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN20-M201:UNIT 1 PRIMARY AIR FAN 2 LUBE OIL PUMP 1 MOTOR (STAND BY)	22/8/2026				☒		
		MSW20HLN20-M202:UNIT 1 PRIMARY AIR FAN 2 LUBE OIL PUMP 2 MOTOR (MAIN)	22/8/2026				☒		
		20HLB02CP104: LO HEADER PRESSURE LOW ALARM FOR PA FAN-2	22/8/2026				☒		
		20HLB02CP103: PRESSURE SWITCH TO START PERMISSIVE FOR PA FAN-2 START	22/8/2026				☒		
		20HLB02CP102: PRESSURE SWITCH TO START LO PA FAN-2 STANDBY PUMP	22/8/2026				☒		
		MSW20HLN20CL201:UNIT 1 PRIMARY AIR FAN 2 LUBE OIL TANK LEVEL SWITCH	22/8/2026				☐		
13	WO-100826-0014	OM EIC Y1 UNIT 1 SECONDARY AIR FAN 1	22/8/2026	IN PROGRESS	M. Zaini	10	78	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	22/8/2026				☒		
		DISSASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	22/8/2026				☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	22/8/2026				☒		
		REPLACE BEARING IF NEEDED	22/8/2026				☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	22/8/2026				☒		
		PENGUKURAN TAHANAN BELITAN	22/8/2026				☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	22/8/2026				☒		
		UNIT 1 SECONDARY AIR FAN 1 OUTLET MOV	22/8/2026				☐		
		SA FAN 1 OUTLET PRESSURE TRANSMITTER 10HLB01CP001	22/8/2026				☐		
		UNIT 1 SECONDARY AIR FAN 1 IGV SA FAN 1 20HLB01EX001	22/8/2026				☐		
14	WO-100826-0014	OM EIC Y1 UNIT 1 SECONDARY AIR FAN 1 LUBE OIL SYSTEM	22/8/2026	SCHED-OK	Aldhy	7	0	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN10-M101:UNIT 1 SECONDARY AIR FAN 1 LUBE OIL PUMP 1 MOTOR (STAND BY)	22/8/2026				☐		
		MSW20HLN10-M102:UNIT 1 SECONDARY AIR FAN 1 LUBE OIL PUMP 2 MOTOR (MAIN)	22/8/2026				☐		
		20HLB02CP101: DP SWITCH ACROSS LO TANK FOR SA FAN-1	22/8/2026				☐		
		20HLB05CP104: LO HEADER PRESSURE LOW ALARM FOR SA FAN-1	22/8/2026				☐		
		20HLB05CP103: PRESSURE SWITCH TO START PERMISSIVE FOR SA FAN-1 START	22/8/2026				☐		
		20HLB05CP102: PRESSURE SWITCH TO START LO SA FAN-1 STANDBY PUMP	22/8/2026				☐		
		20HLB05CP101: DP SWITCH ACROSS LO TANK FOR SA FAN-1	22/8/2026				☐		
15	WO-100826-0014	OM EIC Y1 UNIT 1 SECONDARY AIR FAN 2	22/8/2026	IN PROGRESS	M. Zaini	10	70	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	22/8/2026				☒		
		DISSASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	22/8/2026				☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	22/8/2026				☒		
		REPLACE BEARING IF NEEDED	22/8/2026				☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	22/8/2026				☒		
		PENGUKURAN TAHANAN BELITAN	22/8/2026				☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	22/8/2026				☒		
		UNIT 1 SECONDARY AIR FAN 2 OUTLET MOV	22/8/2026				☐		
		UNIT 1 IGV SA FAN 2 10HLB01EX001	22/8/2026				☐		
		SA FAN 2 OUTLET PRESSURE TRANSMITTER 10HLB02CP001	22/8/2026				☐		
16	WO-100826-0014	OM EIC Y1 UNIT 1 SECONDARY AIR FAN 2 LUBE OIL SYSTEM	22/8/2026	SCHED-OK	Jhon FM	6	0	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN10-M201:UNIT 1 SECONDARY AIR FAN 2 LUBE OIL PUMP 1 MOTOR (STAND BY)	22/8/2026				☐		
		MSW20HLN10-M202:UNIT 1 SECONDARY AIR FAN 2 LUBE OIL PUMP 2 MOTOR (MAIN)	22/8/2026				☐		
		20HLB06CP104: LO HEADER PRESSURE LOW ALARM FOR SA FAN-2	22/8/2026				☐		
		20HLB06CP103: PRESSURE SWITCH TO START PERMISSIVE FOR SA FAN-2 START	22/8/2026				☐		
		20HLB06CP102: PRESSURE SWITCH TO START LO SA FAN-2 STANDBY PUMP	22/8/2026				☐		
		20HLB06CP101: DP SWITCH ACROSS LO TANK FOR SA FAN-2	22/8/2026				☐		
17	WO-100826-0014	OM EIC Y1 UNIT 1 COAL FEEDER NO 1	22/8/2026	IN PROGRESS	Aldhy	13	92	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR DRAG CHAIN	22/8/2026				☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026				☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026				☒		
		INSPECTION COOLING FAN	22/8/2026				☒		
		INSPECTION TERMINASI	22/8/2026				☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026				☒		
		INSPECTION FRAME MOTOR ROTARY AIR LOCK	22/8/2026				☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026				☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026				☒		
		INSPECTION COOLING FAN	22/8/2026				☒		
		INSPECTION TERMINASI	22/8/2026				☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026				☒		
		INSPECTION OF MFT ACTUATOR 10HHE11AA01	22/8/2026				☐		

18	WO-100826-0014	OM EIC Y1 UNIT 1 COAL FEEDER NO 2	22/8/2026			IN PROGRESS	Aldhy	13	92	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR DRAG CHAIN	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☒		
		INSPECTION FRAME MOTOR ROTARY AIR LOCK	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☒		
		INSPECTION OF MFT ACTUATOR 10HH12AA01	22/8/2026				AMP		☐		
19	WO-100826-0014	OM EIC Y1 UNIT 1 LDO START-UP BURNER 1	22/8/2026			IN PROGRESS	Jhon FM	18	11	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION OF IGNITER GUN	22/8/2026			MSW			☐		
		INSPECTION OF START UP BURNER SKID DEVICE	22/8/2026			MSW			☐		
		LDO PRESSURE BEFORE MTV SWITCH 10HIF11CP301	22/8/2026			MSW			☐		
		ATOM AIR INLET PRESSURE LOW SWITCH 10HIN11CP301	22/8/2026			MSW			☐		
		LDO PRESSURE LOW TRIP FOR SUB 1 SWITCH 10HIF11CP302	22/8/2026			MSW			☐		
		ATOM AIR PRESSURE LOW TRIP FOR SUB 1 SWITCH 10HIN11CP302	22/8/2026			MSW			☐		
		LDO PRESSURE HIGH TRIP FOR SUB 1 SWITCH 10HIF11CP303	22/8/2026			MSW			☐		
		SCANNER AIR PRESSURE OK 1 SWITCH 10HG68CP301	22/8/2026			MSW			☐		
		SCANNER AIR PRESSURE OK 2 SWITCH 10HG68CP302	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER MAIN LDO LINE CONTROL VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 1 LDO LINE CONTROL VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 1 ATOMISING AIR LINE CONTROL VALVE	22/8/2026			MSW			☐		
		ACTUATOR SUB BURNER 1 VALVE 10HIN11AA003	22/8/2026			AMP			☐		
		ACTUATOR SKID BURNER 1 ATOM AIR ISOLATION VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 1 LDO ISOLATION VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 1 SCAVENGING VALVE	22/8/2026			MSW			☐		
		ATOM AIR PRESSURE AFTER SUB 1 TRANSMITTER 10HIN11CP001	22/8/2026			JAPA			☒		
		LDO PRESS AFTER SUB1 FVC TRANSMITTER 10HIF11CP001	22/8/2026			JAPA			☒		
20	WO-100826-0014	OM EIC Y1 UNIT 1 LDO START-UP BURNER 2	22/8/2026			SCHED-OK	Jhon FM	13	0	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION OF IGNITER GUN	22/8/2026			MSW			☐		
		INSPECTION OF START UP BURNER SKID DEVICE	22/8/2026			MSW			☐		
		LDO PRESSURE LOW TRIP FOR SUB 2 SWITCH 10HIF12CP302	22/8/2026			MSW			☐		
		ATOM AIR PRESSURE LOW TRIP FOR SUB 2 SWITCH 10HIN12CP302	22/8/2026			MSW			☐		
		LDO PRESSURE HIGH TRIP FOR SUB 2 SWITCH 10HIF12CP303	22/8/2026			MSW			☐		
		ATOM AIR PRESSURE AFTER SUB 2 TRANSMITTER 10HIN12CP001	22/8/2026			JAPA			☐		
		LDO PRESS AFTER SUB2 FVC TRANSMITTER 10HIF12CP001	22/8/2026			JAPA			☐		
		ACTUATOR SKID BURNER 2 LDO LINE CONTROL VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 2 ATOMISING AIR LINE CONTROL VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 2 ATOM AIR ISOLATION VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 2 LDO ISOLATION VALVE	22/8/2026			MSW			☐		
		ACTUATOR SKID BURNER 2 SCAVENGING VALVE	22/8/2026			MSW			☐		
		ACTUATOR SUB BURNER 2 VALVE 10HIN12AA003	22/8/2026			AMP			☐		
21	WO-100826-0014	OM EIC Y1 UNIT 1 SEALPOT BLOWER NO 1	22/8/2026			FINISH	Ferryus	9	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	22/8/2026			JAPA			☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026			JAPA			☒		
		PENGgantian BEARING (JIKA DIPERLUKAN)	22/8/2026			JAPA			☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026			JAPA			☒		
		INSPECTION COOLING FAN	22/8/2026			JAPA			☒		
		INSPECTION TERMINASI	22/8/2026			JAPA			☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026			JAPA			☒		
		SEALPOT BLOWER PRESS OUTLET TRANSMITTER 10HLB41CP001	22/8/2026			JAPA			☒		
		P&S BLOWER PRESS OUTLET TRANSMITTER 10QEB20CP001	22/8/2026			JAPA			☒		
22	WO-100826-0014	OM EIC Y1 UNIT 1 SEALPOT BLOWER NO 2	22/8/2026			FINISH	Ferryus	7	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	22/8/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026						☒		
		PENGgantian BEARING	22/8/2026						☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026						☒		
		INSPECTION COOLING FAN	22/8/2026						☒		
		INSPECTION TERMINASI	22/8/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026						☒		
23	WO-100826-0014	OM EIC Y1 UNIT 1 ELECTROSTATIC PRECIPITATOR 1-6	22/8/2026			IN PROGRESS	M. Iqbal	19	26	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		MSW20HDE10-M101:UNIT 1 ESP RAPPING MOTOR (GDRM)	22/8/2026				JAPA		☐		
		MSW20HDE10-M102:UNIT 1 ESP RAPPING MOTOR (CERM-1)	22/8/2026				JAPA		☐		
		MSW20HDE10-M103:UNIT 1 ESP RAPPING MOTOR (CERM-2)	22/8/2026				JAPA		☐		
		MSW20HDE10-M104:UNIT 1 ESP RAPPING MOTOR (CERM-3)	22/8/2026				JAPA		☐		
		MSW20HDE10-M105:UNIT 1 ESP RAPPING MOTOR (CERM-4)	22/8/2026				JAPA		☐		
		MSW20HDE10-M106:UNIT 1 ESP RAPPING MOTOR (CERM-5)	22/8/2026				JAPA		☐		
		MSW20HDE10-M107:UNIT 1 ESP RAPPING MOTOR (CERM-6)	22/8/2026				JAPA		☐		
		MSW20HDE10-M108:UNIT 1 ESP RAPPING MOTOR (EERM-1)	22/8/2026				JAPA		☐		
		MSW20HDE10-M109:UNIT 1 ESP RAPPING MOTOR (EERM-2)	22/8/2026				JAPA		☐		
		MSW20HDE10-M110:UNIT 1 ESP RAPPING MOTOR (EERM-3)	22/8/2026				JAPA		☐		
		MSW20HDE10-M120:UNIT 1 ESP RAPPING MOTOR (EERM-4)	22/8/2026				JAPA		☐		
		MSW20HDE10-M130:UNIT 1 ESP RAPPING MOTOR (EERM-5)	22/8/2026				JAPA		☐		
		MSW20HDE10-M140:UNIT 1 ESP RAPPING MOTOR (EERM-6)	22/8/2026				JAPA		☐		
		UNIT 1 ESP TRAF0 1 (GENERAL CLEANING, INSPEKSI, IR TEST)	22/8/2026				JAPA		☒		
		UNIT 1 ESP TRAF0 2 (GENERAL CLEANING, INSPEKSI, IR TEST)	22/8/2026				JAPA		☒		
		UNIT 1 ESP TRAF0 3 (GENERAL CLEANING, INSPEKSI, IR TEST)	22/8/2026				JAPA		☒		
		UNIT 1 ESP TRAF0 4 (GENERAL CLEANING, INSPEKSI, IR TEST)	22/8/2026				JAPA		☒		
		UNIT 1 ESP TRAF0 5 (GENERAL CLEANING, INSPEKSI, IR TEST)	22/8/2026				JAPA		☒		
		UNIT 1 ESP TRAF0 6 (GENERAL CLEANING, INSPEKSI, IR TEST)	22/8/2026				JAPA		☐		
24	WO-100826-0014	OM EIC Y1 UNIT 1 BOILER FEED PUMP 1	22/8/2026			IN PROGRESS	Yoga	21	33	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	22/8/2026				JAPA		☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026				JAPA		☒		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)	22/8/2026				JAPA		☒		
		INSPECTION TAHANAN ISOLASI	22/8/2026				JAPA		☐		
		INSPECTION TAHANAN WINDING	22/8/2026				JAPA		☐		
		INSPECTION COOLING FAN	22/8/2026				JAPA		☒		

		INSPECTION TERMINASI	22/8/2026			JAPA		☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026			JAPA		☒		
		MSW20LAC10-M101:MOV DISCHARGE BFP- 1	22/8/2026			MSW		☒		
		MSW20LAC10AA104:UNIT 1 BOILER FEED PUMP 1 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	22/8/2026			MSW		☐		
		MSW20LAC10AA105:UNIT 1 BOILER FEED PUMP 1 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	22/8/2026			MSW		☐		
		MSW20LAC10CG101:UNIT 1 BOILER FEED PUMP 1 LIMIT SWITCH	22/8/2026			MSW		☐		
		20LAC10CP101:UNIT 1 BOILER FEED PUMP 1 PRESSURE DIFFERENTIAL SWITCH	22/8/2026			MSW		☐		
		MSW20LAC10CT101:UNIT 1 BOILER FEED PUMP 1 R PHASE WDG TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10CT102:UNIT 1 BOILER FEED PUMP 1 B PHASE WDG TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10CT103:UNIT 1 BOILER FEED PUMP 1 B PHASE WDG TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10CT104:UNIT 1 BOILER FEED PUMP 1 B NDE MOTOR BEARING TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10CT105:UNIT 1 BOILER FEED PUMP 1 B NDE MOTOR BEARING TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10CT106:UNIT 1 BOILER FEED PUMP 1 B NDE PUMP BEARING TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10CT107:UNIT 1 BOILER FEED PUMP 1 B NDE PUMP BEARING TEMPERATURE	22/8/2026			MSW		☐		
		MSW20LAC10GH101:UNIT 1 BOILER FEED PUMP 1 FCMA PANEL	22/8/2026			MSW		☐		
25	WO-100826-0014	OM EIC Y1 UNIT 1 BOILER FEED PUMP 2	22/8/2026	IN PROGRESS	Yoga	21	33		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026		JAPA		☒			
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026		JAPA		☒			
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)	22/8/2026		JAPA		☒			
		INSPECTION TAHANAN ISOLASI	22/8/2026		JAPA		☐			
		INSPECTION TAHANAN WINDING	22/8/2026		JAPA		☐			
		INSPECTION COOLING FAN	22/8/2026		JAPA		☒			
		INSPECTION TERMINASI	22/8/2026		JAPA		☒			
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026		MSW		☒			
		MSW20LAC10-M201:MOV DISCHARGE BFP- 2	22/8/2026		MSW		☒			
		MSW20LAC10AA204:UNIT 1 BOILER FEED PUMP 2 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	22/8/2026		MSW		☐			
		MSW20LAC10AA205:UNIT 1 BOILER FEED PUMP 2 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	22/8/2026		MSW		☐			
		MSW20LAC10CG201:UNIT 1 BOILER FEED PUMP 2 LIMIT SWITCH	22/8/2026		MSW		☐			
		MSW20LAC10CP201:UNIT 1 BOILER FEED PUMP 2 PRESSURE DIFFERENTIAL SWITCH	22/8/2026		MSW		☐			
		MSW20LAC10CT201:UNIT 1 BOILER FEED PUMP 2 R PHASE WDG TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10CT202:UNIT 1 BOILER FEED PUMP 2 B PHASE WDG TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10CT203:UNIT 1 BOILER FEED PUMP 2 B PHASE WDG TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10CT204:UNIT 1 BOILER FEED PUMP 2 B NDE MOTOR BEARING TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10CT205:UNIT 1 BOILER FEED PUMP 2 B NDE MOTOR BEARING TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10CT206:UNIT 1 BOILER FEED PUMP 2 B NDE PUMP BEARING TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10CT207:UNIT 1 BOILER FEED PUMP 2 B NDE PUMP BEARING TEMPERATURE	22/8/2026		MSW		☐			
		MSW20LAC10GH201:UNIT 1 BOILER FEED PUMP 2 FCMA PANEL	22/8/2026		MSW		☐			
26	WO-100826-0014	OM EIC Y1 UNIT 1 FEED WATER LINE	22/8/2026	IN PROGRESS	M. Toher	10	30		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		UNIT 1 FEED WATER INLET ECONOMIZER MOTORIZED VALVE MOTOR 100% 10LAB30AA220	22/8/2026		AMP		☐			
		UNIT 1 FEED WATER INLET ECONOMIZER MOTORIZED VALVE ISOLATION VALVE	22/8/2026		AMP		☒			
		UNIT 1 FEED WATER INLET ECONOMIZER MOTORIZED VALVE MOTOR 30% 10LAB30AA210	22/8/2026		AMP		☒			
		UNIT 1 FEED WATER INLET ECONOMIZER MOTORIZED VALVE ISOLATION VALVE	22/8/2026		AMP		☒			
		ACTUATOR BFP SPRAY LINE (FEED WATER) TO DEAERATOR PRDS I/L CV 10LAE10AA210	22/8/2026		AMP		☐			
		BFP SPRAY LINE (FEED WATER) TO DEAERATOR PRDS I/L MOV 10LAE10AA110	22/8/2026		AMP		☐			
		DISTRIBUTOR LINE TO FEEDWATER TRANSMITTER 10LAB30CP001	22/8/2026		JAPA		☐			
		INLET FEEDWATER PRESSURE TRANSMITTER 10HAC30CP001	22/8/2026		JAPA		☐			
		INLET FEEDWATER FLOW TRANSMITTER 10HAC30CF001	22/8/2026		JAPA		☐			
		INLET FEEDWATER FLOW TRANSMITTER 10HAC30CF002	22/8/2026		JAPA		☐			
27	WO-100826-0014	OM EIC Y1 UNIT 1 DESH SUPERHEATER LINE 1	22/8/2026	IN PROGRESS	M. Toher	3	67		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		CALIBRATION/FUNCTION TEST SPRAY CONTROL VALVE 10LAE10EX001	22/8/2026				☒			
		CALIBRATION/FUNCTION ISOLATION (ON/OFF) VALVE	22/8/2026				☐			
		DESH 1 SPRAY WATER FLOW TRANSMITTER 10LAE20CF001	22/8/2026				☒			
28	WO-100826-0014	OM EIC Y1 UNIT 1 DESH SUPERHEATER LINE 2	22/8/2026	IN PROGRESS	M. Toher	4	50		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		DESH 2 SPRAY WATER FLOW TRANSMITTER 10LAE30CF001	22/8/2026		JAPA		☒			
		CALIBRATION/FUNCTION TEST SPRAY CONTROL VALVE 10LAE12EX001	22/8/2026		AMP		☐			
		BEFORE DESH 2 TEMP TRANSMITTER CALIBRATION (20HAH46CT001, 10HAH36CT009, 10HAH36CT009)	22/8/2026		MSW		☐			
		CALIBRATION/FUNCTION ISOLATION (ON/OFF) VALVE	22/8/2026		AMP		☒			
29	WO-100826-0014	OM EIC Y1 UNIT 1 GENERATOR CIRCUIT BREAKER	22/8/2026	IN PROGRESS	M. Zaini	30	10		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION MEKANIK PENGGERAK	22/8/2026				☒			
		INSPECTION MOTOR CHARGING	22/8/2026				☒			
		INSPECTION BEARING DRIVE RACK OUT/IN	22/8/2026				☒			
		REGREASING SOCKET MAIN KONTAK	22/8/2026				☐			
		INSPECTION SYSTEM KONTROL	22/8/2026				☐			
		TEST TAHANAN KONTAK	22/8/2026				☐			
		TEST KESEREMPAKAN	22/8/2026				☐			
		INSPECTION TAHANAN ISOLASI KONTAK	22/8/2026				☐			
		INSPECTION TAHANAN ISOLASI BUS BAR	22/8/2026				☐			
		FUNCTION TEST	22/8/2026				☐			
		PENGUKURAN TAHANAN MOTOR CHARGING, CLOSING DAN TRIPPING COIL	22/8/2026				☐			
		INSPECTION MODUL CONTROL BREAKER	22/8/2026				☐			
		INSPECTION LAMPU SWITCH GEAR GCB	22/8/2026				☐			
		INDIKATOR DAN LAMPU PANEL SWITCH GEAR GCB	22/8/2026				☐			
		PENGETESAN POWER DC UNTUK SUPPLY CONTROL 6,3 KV SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION HEATER CUBICLE SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION DAN CLEANING TERMINASI SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION DAN PENGUJIAN RELAY PROTEKSI SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION GROUNDING SYSTEM SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION TAHANAN ISOLASI BUS BAR SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION CT & PT SWITCH GEAR GCB	22/8/2026				☐			
		FUNCTION TEST SWITCH GEAR GCB	22/8/2026				☐			
		INSPECTION HEATER SYSTEM	22/8/2026				☐			
		INSPECTION DISPLAY BREAKER	22/8/2026				☐			
		INSPECTION HEATER BUSDUCT	22/8/2026				☐			
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	22/8/2026				☐			
		INSPECTION SILICA BUSDUCT	22/8/2026				☐			
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	22/8/2026				☐			
		INSPECTION CONTACT RESISTANCE BUSDUCT	22/8/2026				☐			
		INSPECTION ISOLATION RESISTANCE BUSDUCT	22/8/2026				☐			
30	WO-100826-0014	OM EIC Y1 UNIT 1 GENERATOR	22/8/2026	SCHED-OK	M. Zaini	40	0		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		DISASSEMBLY BRACKET GENERATOR SISI FRONT	22/8/2026		JAPA		☐			
		DISASSEMBLY BRACKET GENERATOR SISI REAR	22/8/2026		JAPA		☐			
		DISASSEMBLY OIL DEFLECTOR BEARING	22/8/2026		JAPA		☐			

		CLEANING BODY GENERATOR	22/8/2026			JAPA		☐		
		CLEANING OIL DEFLECTOR BEARING	22/8/2026			JAPA		☐		
		CLEANING BOLT & NUT	22/8/2026			JAPA		☐		
		INSPECTION OIL DEFLECTOR BEARING 3 & 4	22/8/2026			JAPA		☐		
		INSPECTION SHROUD & FAN BLADE	22/8/2026			JAPA		☐		
		INSPECTION STATOR GENERATOR (R, P1)	22/8/2026			JAPA		☐		
		INSPECTION ROTOR GENERATOR (R, P1, RSO)	22/8/2026			JAPA		☐		
		INSPECTION VISUAL ISOLATOR	22/8/2026			JAPA		☐		
		INSPECTION ROTOR GROUNDING	22/8/2026			JAPA		☐		
		INSPECTION VISUAL FLEXIBLE ISOLATOR	22/8/2026			JAPA		☐		
		INSPECTION BRUSH GROUNDING	22/8/2026			JAPA		☐		
		INSPECTION TAHANAN ISOLASI GENERATOR	22/8/2026			JAPA		☐		
		INSPECTION HEATER NEUTRAL SIDE CUBICLE	22/8/2026			JAPA		☐		
		INSPECTION HEATER LINE SIDE CUBICLE	22/8/2026			JAPA		☐		
		ASSEMBLY OIL DEFLECTOR BEARING	22/8/2026			JAPA		☐		
		ASSEMBLY BRACKET SISI FRONT	22/8/2026			JAPA		☐		
		ASSEMBLY BRACKET SISI REAR	22/8/2026			JAPA		☐		
		PENGUKURAN TAHANAN RESISTOR	22/8/2026			JAPA		☐		
		INSPECTION & CLEANING PT	22/8/2026			JAPA		☐		
		INSPECTION & CLEANING CT	22/8/2026			JAPA		☐		
		PENGUKURAN TAHANAN ISOLASI PERMANEN MAGNET GENERATOR (PMG)	22/8/2026			JAPA		☐		
		INSPECTION DIODA EXCITER PERMANEN MAGNET GENERATOR (PMG)	22/8/2026			JAPA		☐		
		INSPECTION TERMINASI PERMANEN MAGNET GENERATOR (PMG)	22/8/2026			JAPA		☐		
		INSPECTION GROUNDING SYSTEM PERMANEN MAGNET GENERATOR (PMG)	22/8/2026			JAPA		☐		
		INSPECTION FUSE PANEL PERMANEN MAGNET GENERATOR (PMG)	22/8/2026			JAPA		☐		
		INSPECTION DISCONNECTING SWITCH NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026			JAPA		☐		
		INSPECTION TRAF0 NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026			JAPA		☐		
		INSPECTION ISOLATOR BUSHING NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026			JAPA		☐		
		INSPECTION TERMINASI NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026			JAPA		☐		
		TEST TAHANAN ISOLASI NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026			JAPA		☐		
		INSPECTION HEATER BUSDUCT NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026			JAPA		☐		
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	22/8/2026			JAPA		☐		
		INSPECTION SILICA BUSDUCT	22/8/2026			JAPA		☐		
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	22/8/2026			JAPA		☐		
		INSPECTION CONTACT RESISTANCE BUSDUCT	22/8/2026			JAPA		☐		
		INSPECTION ISOLATION RESISTANCE BUSDUCT	22/8/2026			JAPA		☐		
		CLEANING	22/8/2026			JAPA		☐		
31	WO-100826-0014	OM EIC Y1 UNIT 1 AUXILIARY TRANSFORMER 2	22/8/2026	SCHED-OK	M. Zaini	24	0		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION ISOLATOR BUSHING	22/8/2026		JAPA		☐			
		INSPECTION TERMINASI	22/8/2026		JAPA		☐			
		CLEANING BUSHING CONNECTION HV & LV	22/8/2026		JAPA		☐			
		INSPECTION DAN CLEANING PANEL	22/8/2026		JAPA		☐			
		INSPECTION SILICAGEL	22/8/2026		JAPA		☐			
		INSPECTION GROUNDING SYSTEM	22/8/2026		JAPA		☐			
		INSPECTION KEBOCORAN MINYAK TRAF0	22/8/2026		JAPA		☐			
		PROTECTIVE DEVICE TEST DAN RESET TRAF0	22/8/2026		JAPA		☐			
		INSPECTION PANEL TAP CHANGER	22/8/2026		JAPA		☐			
		INSPECTION TAHANAN ISOLASI WINDING TRAF0	22/8/2026		JAPA		☐			
		RDS TEST	22/8/2026		JAPA		☐			
		MECHANICAL RELAY TEST	22/8/2026		JAPA		☐			
		INSPECTION DISCONNECTING SWITCH NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026		JAPA		☐			
		INSPECTION TRAF0 NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026		JAPA		☐			
		INSPECTION ISOLATOR BUSHING NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026		JAPA		☐			
		INSPECTION TERMINASI NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026		JAPA		☐			
		INSPECTION GROUNDING SYSTEM NETRAL GROUNDING RESISTANCE (NGR)	22/8/2026		JAPA		☐			
		INSPECTION HEATER BUSDUCT	22/8/2026		JAPA		☐			
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	22/8/2026		JAPA		☐			
		INSPECTION SILICA BUSDUCT	22/8/2026		JAPA		☐			
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	22/8/2026		JAPA		☐			
		INSPECTION CONTACT RESISTANCE BUSDUCT	22/8/2026		JAPA		☐			
		INSPECTION ISOLATION RESISTANCE BUSDUCT	22/8/2026		JAPA		☐			
		CLEANING	22/8/2026		JAPA		☐			
32	WO-100826-0014	OM EIC Y1 UNIT 1 6.6KV MEDIUM VOLTAGE STATION BOARDS PANEL	22/8/2026	IN PROGRESS	M. Zaini	15	7		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW208BA10GS101:UNIT 1 SWITCHGEAR 6.6KV INCOMING PANEL (MV UAT 2 CB9)	22/8/2026		JAPA		☒			
		MSW208BA10GS102:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 1 PA FAN 1	22/8/2026		JAPA		☐			
		MSW208BA10GS103:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 2 PA FAN 2	22/8/2026		JAPA		☐			
		MSW208BA10GS104:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 3 SA FAN 1	22/8/2026		JAPA		☐			
		MSW208BA10GS105:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 4 SA FAN 2	22/8/2026		JAPA		☐			
		MSW208BA10GS106:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 5 ID FAN 1	22/8/2026		JAPA		☐			
		MSW208BA10GS107:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 6 ID FAN 2	22/8/2026		JAPA		☐			
		MSW208BA10GS108:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 8 BF PUMP 1	22/8/2026		JAPA		☐			
		MSW208BA10GS109:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 9 BF PUMP 2	22/8/2026		JAPA		☐			
		MSW208BA10GS110:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 7 CW PUMP 3	22/8/2026		JAPA		☐			
		MSW208BA10GS111:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 11 CW PUMP 4	22/8/2026		JAPA		☐			
		MSW208BA10GS112:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 OUTGOING FEEDER 12 CW PUMP 5	22/8/2026		JAPA		☐			
		MSW208BA10GS113:UNIT 1 SWITCHGEAR 6.6KV UNIT 1 TRAF0 FEEDER	22/8/2026		JAPA		☐			
		UNIT 1 SWITCHGEAR 6.6KV UNIT 1 ADAPTER	22/8/2026		JAPA		☐			
		MSW208BA10GS114:UNIT 1 SWITCHGEAR 6.6KV METERING (IL10)	22/8/2026		JAPA		☐			
33	WO-100826-0014	OM EIC Y1 UNIT 1 MEDIUM VOLTAGE STATION BOARDS COMMON	22/8/2026	SCHED-OK	Aldhly	10	0		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		SWITCHGEAR 6.6KV UNIT 1 INCOMMMING GENERATOR 1	22/8/2026				☐			
		SWITCHGEAR 6.6KV UNIT 1 INCOMMMING GENERATOR 2	22/8/2026				☐			
		SWITCHGEAR 6.6KV UNIT 1 INCOMMMING GENERATOR 3	22/8/2026				☐			
		SWITCHGEAR 6.6KV UNIT 1 INCOMMMING GENERATOR 4	22/8/2026				☐			
		SWITCHGEAR 6.6KV UNIT 1 OUTGOING TRAF0 1	22/8/2026				☐			
		SWITCHGEAR 6.6KV UNIT 1 OUTGOING TRAF0 2	22/8/2026				☐			
		MSW008BA10CE201:MV COMMON METERING	22/8/2026				☐			
		MSW008BA10GH201:SWITCHGEAR 6.6KV COMMON BUSTIE RIGHT	22/8/2026				☐			
		MSW008BA10GH202:SWITCHGEAR 6.6KV COMMON BUSTIE LEFT	22/8/2026				☐			
		MSW008BA10GH203:SWITCHGEAR 6.6KV COMMON TRAF0 FEEDER	22/8/2026				☐			
34	WO-100826-0014	OMEIC Y1 UNIT 1 MAIN TURBINE	22/8/2026	SCHED-OK	M. Toher	42	0		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		CONDENSATE PRESSURE TO BYPASS SPRAY PRESSURE TRANSMITTER (20LCE40CP001)	22/8/2026				☐			
		CONDENSATE PRESSURE TO BYPASS SPRAY PRESSURE TRANSMITTER (20LCE40CP002)	22/8/2026				☐			

		CONDENSATE PRESSURE TO BYPASS SPRAY PRESSURE TRANSMITTER (20LCE40CP003)	22/8/2026						☐		
		ACTUATOR TURBINE EXTRACTION III TO DEAEATOR CV 10LBD20AA210	22/8/2026						☐		
		ACTUATOR MOV TURBINE STOP VALVE UNIT 1	22/8/2026						☐		
		ACTUATOR MOV PREHEATING 1 TURBINE	22/8/2026						☐		
		ACTUATOR MOV PREHEATING 2 TURBINE	22/8/2026						☐		
		TURBINE EXTRACTION II TO LPH2 TEMPERATURE TRANSMITTER (20LBD30CT001)	22/8/2026						☐		
		TURBINE EXTRACTION III TO DEAEATOR TEMPERATURE TRANSMITTER (20LBD20CT001)	22/8/2026						☐		
		TURBINE EXTRACTION I TO LPH1 TEMPERATURE TRANSMITTER (20LBD10CT001)	22/8/2026						☐		
		MSW20MAA10CP302 : UNIT 1 TURBINE BEHIND CONTROL STAGE PRESSURE TRANSMITTER (20MAA10C	22/8/2026						☐		
		MSW20MAA10CP303 : UNIT 1 TURBINE EXHAUST PRESSURE TRANSMITTER (20MAA10CP002)	22/8/2026						☐		
		MSW20MAA10CP304 : UNIT 1 TURBINE EXHAUST PRESSURE TRANSMITTER (20MAA10CP003)	22/8/2026						☐		
		MSW20MAA10CP305 : UNIT 1 TURBINE EXHAUST PRESSURE TRANSMITTER (20MAA10CP004)	22/8/2026						☐		
		MSW20MAA10CP306 : UNIT 1 TURBINE BEHIND CONTROL STAGE PRESSURE TRANSMITTER (20MAA10C	22/8/2026						☐		
		MOV TURBINE STEAM EXTRACTION-1	22/8/2026						☐		
		MOV TURBINE STEAM EXTRACTION-2	22/8/2026						☐		
		MOV MAIN STEAM DRAIN STG-2	22/8/2026						☐		
		TURBINE CASING TEMPERATURE - INSIDE TRANSMITTER 10MAA10CT012	22/8/2026						☐		
		TURBINE CASING TEMPERATURE - CENTER TRANSMITTER 10MAA10CT013	22/8/2026						☐		
		DEAEATOR PRDS OUTLET TO EXTRACTION I - DEAEATOR VL TEMP TRANSMITTER 10LBD11CT002	22/8/2026						☐		
		DEAEATOR PRDS OUTLET TO EXTRACTION I - DEAEATOR VL TEMP TRANSMITTER 10LBD11CT001	22/8/2026						☐		
		DEAEATOR PRDS TO OUTLET EXTRACTION TRANSMITTER 10LBD11CP001	22/8/2026						☐		
		DEAEATOR PRDS TO OUTLET EXTRACTION II TRANSMITTER 10LBD11CP002	22/8/2026						☐		
		FEEDWATER STORAGE TANK PRESSURE TRANSMITTER 10LAA20CP001	22/8/2026						☐		
		CONTROL VALVE LPH-1	22/8/2026						☐		
		CONTROL VALVE LPH-2	22/8/2026						☐		
		LP HEATER 2 TRANSMITTER 10LCC40CL001	22/8/2026						☐		
		LP HEATER 2 TRANSMITTER 10LCC40CL002	22/8/2026						☐		
		LPH II - TUBE SIDE OUTLET TO DEAEATOR TEMP TRANSMITTER 10LCC20CT001	22/8/2026						☐		
		FEEDWATER STORAGE TANK TRANSMITTER 10LAA20CT001	22/8/2026						☐		
		CYCLE MAKE UP PUMP DEAEATOR TRANSMITTER 10HOC20CF001	22/8/2026						☐		
		DEAEATOR TANK LEVEL 1 TRANSMITTER 10LAA20CL001	22/8/2026						☐		
		DEAEATOR TANK LEVEL 2 TRANSMITTER 10LAA20CL002	22/8/2026						☐		
		DEAEATOR TANK LEVEL 3 TRANSMITTER 10LAA20CL003	22/8/2026						☐		
		TURBINE EXTRACTION III TO DEAEATOR PRESSURE TRANSMITTER 10LBD20CP001	22/8/2026						☐		
		TURBINE EXTRACTION III TO LPH PRESSURE TRANSMITTER 10LBD30CP001	22/8/2026						☐		
		TURBINE EXTRACTION I TO PNEUMATIC OPERATED VALVE PRESSURE TRANSMITTER 10LBS10CP001	22/8/2026						☐		
		LP HEATER 1 TRANSMITTER 10LCC30CL001	22/8/2026						☐		
		LP HEATER 1 TRANSMITTER 10LCC30CL002	22/8/2026						☐		
		FLOW CONDESATE TO LP HEATER 1 TRANSMITTER 10LCA40CF001	22/8/2026						☐		
		CONDENSATE TO LP HEATER TRANSMITTER 10LCA40CF001	22/8/2026						☐		
35	WO-100826-0014	OM EIC 1Y FIRE ALARM LOCAL PANEL (UNIT 1)	22/8/2026	SCHED-OK	Jhon FM	13	0			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW00CYE10GH101 : ALARM SYSTEM ADMIN BUILDING	22/8/2026						☐		
		MSW00CYE10GH102 : ALARM SYSTEM DG SHEET	22/8/2026						☐		
		MSW00CYE10GH103 : PANEL MAIN FIRE ALARM SYSTEM	22/8/2026						☐		
		MSW00CYE10GH104 : ALARM SYSTEM DM MCC ROOM	22/8/2026						☐		
		MSW00CYE10GH105 : ALARM SYSTEM CHP MCC	22/8/2026						☐		
		MSW00CYE10GH106 : ALARM SYSTEM AHP MCC	22/8/2026						☐		
		MSW00CYE10GH107 : ALARM SYSTEM COOLING WATER	22/8/2026						☐		
		MSW00CYE10GH108 : ALARM SYSTEM DM/RW/PW TW PUMP	22/8/2026						☐		
		MSW00CYE10GH109 : ALARM SYSTEM WORKSHOP OFFICE ROOM	22/8/2026						☐		
		MSW00CYE10GH110 : ALARM SYSTEM 3WAS ROOM	22/8/2026						☐		
		MSW00CYE10GH111 : ALARM SYSTEM STG BUILDING	22/8/2026						☐		
		MSW00CYE10GH113 : ALARM SYSTEM SWITCHYARD BUILDING	22/8/2026						☐		
		MSW00CYE10GH114 : ALARM SYSTEM REMOTE SUBSTATION BUILDING	22/8/2026						☐		
36	WO-100826-0014	OM EIC 1Y UNIT 1 PRIMARY AIR FAN LINE	22/8/2026	IN PROGRESS	Ferryus	4	75			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION AND CALIBRATION OXYGEN ANALYZER	22/8/2026						☐		
		P.A APH OUTLET FLOW DP TRANSMITTER 10HLA15CF001	22/8/2026						☒		
		P.A APH OUTLET FLOW DP TRANSMITTER 10HLA15CF002	22/8/2026						☒		
		P.A APH OUTLET PRESSURE TRANSMITTER 10HLA15CP001	22/8/2026						☒		
37	WO-100826-0014	OM EIC 1Y UNIT 1 SECONDARY AIR FAN LINE	22/8/2026	IN PROGRESS	Ferryus	8	63			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		AIR SUB1 FLOW DP TRANSMITTER 10HIL10CF010	22/8/2026						☐		
		AIR SUB2 FLOW DP TRANSMITTER 10HIL11CF010	22/8/2026						☐		
		SA APH OUTLET FLOW TRANSMITTER 10HLA25CF001	22/8/2026						☐		
		SA APH OUTLET FLOW TRANSMITTER 10HLA25CF002	22/8/2026						☒		
		SA APH OUTLET PRESSURE TRANSMITTER 10HLA25CP001	22/8/2026						☒		
		UNIT 1 SECONDARY AIR FAN IGV SUB 1 20HIL10AA010	22/8/2026						☒		
		UNIT 1 SECONDARY AIR FAN IGV SUB 2 20HIL11AA010	22/8/2026						☒		
		UNIT 1 SECONDARY AIR FAN IGV SA CONTROL DAMPER 20HLA25AA010	22/8/2026						☒		
38	WO-100826-0014	OM EIC Y1 UNIT 1 BOILER DISTRIBUTED CONTROL PANEL	22/8/2026	SCHED-OK	Jhon FM	3	0			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		PM PC OWS	22/8/2026						☐		
		PM PC EWS	22/8/2026						☐		
		PM panel RIO	22/8/2026						☐		
39	WO-100826-0014	OM EIC Y1 UNIT 1 BOILER DRUM	22/8/2026	IN PROGRESS	Jhon FM	12	50			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION & CALIBRATION STEAM DRUM VENTING ISOLATION VALVE	22/8/2026						☒		
		INSPECTION & CALIBRATION STEAM DRUM MOV VENTING REGULATING VALVE	22/8/2026						☒		
		INSPECTION & CALIBRATION STEAM DRUM CBD ISOLATION VALVE	22/8/2026						☒		
		INSPECTION & CALIBRATION STEAM DRUM MOV CBD REGULATING VALVE	22/8/2026						☒		
		INSPECTION & CALIBRATION STEAM DRUM IBD ISOLATION VALVE	22/8/2026						☒		
		INSPECTION & CALIBRATION STEAM DRUM MOV IBD REGULATING VALVE	22/8/2026						☒		
		DRUM LEVEL TRANSMITTER 10HAD10CL001	22/8/2026						☐		
		DRUM LEVEL TRANSMITTER 10HAD10CL002	22/8/2026						☐		
		DRUM LEVEL TRANSMITTER 10HAD10CL003	22/8/2026						☐		
		DRUM PRESSURE TRANSMITTER 10HAD10CP002	22/8/2026						☐		
		DRUM PRESSURE TRANSMITTER 10HAD10CP003	22/8/2026						☐		
		DRUM PRESSURE TRANSMITTER 10HAD10CP001	22/8/2026						☐		
40	WO-100826-0014	OM EIC Y1 UNIT 1 COMBUSTOR	22/8/2026	IN PROGRESS	M. Toher	19	26			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		COMBUSTER ASH DRAIN 1 (BED ASH COOLER DRAIN) MOV 10HHC01AA001	22/8/2026						☐		
		COMBUSTER ASH DRAIN 2 (EMERGENCY ASH DRAIN) MOV 10HHC01AA002	22/8/2026						☐		
		LIMESTONE GATE VALVE	22/8/2026						☒		
		ACTUATOR BED MATERIAL DISCHARGE GATE VALVE 10ETG31AA01	22/8/2026						☒		
		COMBUSTOR LOWER PRESSURE TRANSMITTER 10HHC01CP001	22/8/2026						☒		
		MSW20HHC10CP102 : UNIT 1 COMBUSTOR DP WITH GRATE 10HHC01CP011	22/8/2026						☒		

		MSW20HHC10CP103 : UNIT 1 COMBUSTOR UPPER DP 10HHC01CP012	22/8/2026						☒		
		AIR COMBUSTOR AT LEVEL PRES TRANSMITTER 10HHC01CP060	22/8/2026						☐		
		MSW20HHC10CT101 : UNIT 1 COMBUSTOR LOWER TEMP 10HHC01CT011	22/8/2026						☐		
		MSW20HHC10CT102 : UNIT 1 COMBUSTOR LOWER TEMP 10HHC01CT012	22/8/2026						☐		
		MSW20HHC10CT103 : UNIT 1 COMBUSTOR LOWER TEMP 10HHC01CT013	22/8/2026						☐		
		MSW20HHC10CT104 : UNIT 1 COMBUSTOR MIDDLE TEMP 10HHC01CT041	22/8/2026						☐		
		MSW20HHC10CT105 : UNIT 1 COMBUSTOR MIDDLE TEMP 10HHC01CT042	22/8/2026						☐		
		MSW20HHC10CT106 : UNIT 1 COMBUSTOR MIDDLE TEMP 10HHC01CT043	22/8/2026						☐		
		INLET BACKPASS PRESSURE TRANSMITTER 10HBK01CP003	22/8/2026						☐		
		INLET BACKPASS PRESSURE TRANSMITTER 10HBK01CP002	22/8/2026						☐		
		INLET BACKPASS PRESSURE TRANSMITTER 10HBK01CP001	22/8/2026						☐		
		BACKPASS PRESSURE AFTER LT SH TRANSMITTER 10HBK01CP030	22/8/2026						☐		
		BACKPASS PRESSURE AFTER ECO TRANSMITTER 10HBK01CP050	22/8/2026						☐		
41	WO-100826-0014	OM EIC Y1 UNIT 1 CYCLONE	22/8/2026		IN PROGRESS	M. Toher	6	17		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		MSW20HDF10CP102 : UNIT 1 BACKPASS INLET PRESSURE	22/8/2026						☒		
		CYCLONE TO SEALPOT PRESSURE TRANSMITTER 10HDF01CP001	22/8/2026						☐		
		MSW20HDF10CT101 : UNIT 1 BACKPASS INLET TEMPERATURE	22/8/2026						☐		
		MSW20HDF10CT102 : UNIT 1 CYCLONE OUTLET TEMP 10HMA01CT001	22/8/2026						☐		
		MSW20HDF10CT103 : UNIT 1 BACKPASS INLET TEMPERATURE	22/8/2026						☐		
		MSW20HDF10CT104 : UNIT 1 CYCLONE INLET TEMPERATURE	22/8/2026						☐		
42	WO-100826-0014	OM EIC Y1 UNIT 1 SEALPOT	22/8/2026		SCHED-OK	M. Zaini	4	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		ACTUATOR DAMPER SEALPOT BLOWER 1	22/8/2026						☐		
		ACTUATOR DAMPER SEALPOT BLOWER 2	22/8/2026						☐		
		CALIBRATION PRESSURE TRANSMITTER	22/8/2026						☐		
		CALIBRATION TEMPERATURE TRANSMITTER	22/8/2026						☐		
43	WO-100826-0014	OM EIC Y1 UNIT 1 SUPERHEATER SYSTEM LINE	22/8/2026		IN PROGRESS	M. Zaini	12	17		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		ERV PRESSURE SWITCH 10LBA20CP502	22/8/2026						☐		
		INSPECTION AND CALIBRATION TEMP TRANSMITTER 10LBA10CT001	22/8/2026						☐		
		INSPECTION AND CALIBRATION TEMP TRANSMITTER 10LBA10CT002	22/8/2026						☐		
		INSPECTION AND CALIBRATION TEMP TRANSMITTER 10LBA10CT003	22/8/2026						☐		
		ACTUATOR MAIN STEAM LINE (START UP BYPASS) TO DEAERATOR PRDS I/L CV 10LBH10AA210	22/8/2026						☐		
		MS START-UP VENT VALVE (REGULATING) MOV 10LBA21AA011	22/8/2026						☒		
		MS START-UP VENT VALVE (ISOLATION) MOV 10LBA21AA001	22/8/2026						☒		
		MAIN STEAM LIVE PRESSURE TRANSMITTER 10LAB10CP001	22/8/2026						☐		
		MAIN STEAM LIVE PRESSURE TRANSMITTER 10LAB10CP002	22/8/2026						☐		
		MAIN STEAM LIVE PRESSURE TRANSMITTER 10LAB10CP003	22/8/2026						☐		
		INSPECTION AND CALIBRATION FLOW TRANSMITTER 10LBA10CF001	22/8/2026						☐		
		INSPECTION AND CALIBRATION FLOW TRANSMITTER 10LBA10CF002	22/8/2026						☐		
44	WO-100826-0014	OM EIC Y1 UNIT 1 JACKING OIL PUMP	22/8/2026		SCHED-OK	M. Toher	2	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		MSW20MAV10-M101 : UNIT 1 JACKING OIL PUMP MOTOR	22/8/2026			MSW			☐		
		MSW20MAV10CP101 : UNIT 1 JACKING OIL PRESSURE TRANSMITTER	22/8/2026			MSW			☐		
45	WO-100826-0014	OM EIC Y1 UNIT 1 MAIN OIL PUMP	22/8/2026		SCHED-OK	Aldhly	4	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		INSPEKSI & PM OIL PUMP MOTOR (AUXILIARY, EMERGENCY, JACKING, BREATHER)	22/8/2026			MSW			☐		
		INSPEKSI DAN KALIBRASI LUB OIL PRESSURE TRANSMITTER 10MAV40CP001	22/8/2026			JAPA			☐		
		INSPEKSI DAN KALIBRASI LUB OIL PRESSURE TRANSMITTER 10MAV40CP002	22/8/2026			JAPA			☐		
		INSPEKSI DAN KALIBRASI LUB OIL PRESSURE TRANSMITTER 10MAV40CP003	22/8/2026			JAPA			☐		
46	WO-100826-0014	OM EIC Y1 UNIT 1 TURBINE CONTROL VALVE	22/8/2026		SCHED-OK	Aldhly	8	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		VALVE POSITION BLOCK LIVE STEAM PT (20MAX45CP001)	22/8/2026			JAPA			☐		
		VALVE POSITION BLOCK LIVE STEAM PT (20MAX45CP002)	22/8/2026			JAPA			☐		
		VALVE POSITION BLOCK LIVE STEAM PT (20MAX45CP003)	22/8/2026			JAPA			☐		
		VALVE BLOCK - OUTLET POSITION LIVE STEAM PT (20MAX45CP004)	22/8/2026			JAPA			☐		
		CONTROL OIL PRESSURE PT (20MAX40CP001)	22/8/2026			JAPA			☐		
		VALVE CHEST TEMPERATURE TRANSMITTER 10MAA10CT011	22/8/2026			MSW			☐		
		LIVE STEAM PRESSURE TRANSMITTER 10LBA10CP001	22/8/2026			JAPA			☐		
		CALIBRATION/FUNCTION TEST CONTROL VALVE	22/8/2026			MSW			☐		
47	WO-100826-0014	OM EIC Y1 UNIT 1 HP BYPASS VALVE	22/8/2026		SCHED-OK	Jhon FM	6	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		CALIBRATION/FUNCTION TEST HP BYPASS CONTROL VALVE 20LBF10AA210	22/8/2026			AMP			☐		
		HP BYPASS TEMPERATURE TRANSMITTER 10LBF10CT001	22/8/2026			MSW			☐		
		BYPASS PRESSURE TRANSMITTER 10MAG10CP001	22/8/2026			JAPA			☐		
		MSW20LBF10CG101 : UNIT 1 STEAM BYPASS REDUCING CONTROL VALVE PRESSURE TRANSMITTER	22/8/2026			JAPA			☐		
		MSW20LBF10CP101 : UNIT 1 STEAM BYPASS REDUCING PRESSURE TRANSMITTER 10LBF10CP001	22/8/2026			JAPA			☐		
		MSW20LBF10CT101 : UNIT 1 STEAM BYPASS REDUCING TEMPERATURE TRANSMITTER	22/8/2026			MSW			☐		
48	WO-100826-0014	OM EIC Y1 UNIT 1 TURBINE DRAINAGE MAIN HEADER LINE TO EXPANSION TUBE	22/8/2026		SCHED-OK	M. Zaini	7	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		DRAIN OF ESV 10MAL10AA210	22/8/2026						☐		
		DRAIN OF CV CHAMBER 10MAL20AA210	22/8/2026						☐		
		TURBINE DRAIN VALVE AFTER FIRST STAGE 10MAL30AA210	22/8/2026						☐		
		TURBINE DRAIN VALVE 10MAL40AA210	22/8/2026						☐		
		TURBINE DRAIN VALVE 10MAL50AA210	22/8/2026						☐		
		TURBINE DRAIN VALVE 10MAL60AA210	22/8/2026						☐		
		TURBINE DRAIN VALVE 10MAL70AA210	22/8/2026						☐		
49	WO-100826-0014	OM EIC Y1 UNIT 1 VACUUM PUMP A	22/8/2026		SCHED-OK	M. Zaini	4	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		MSW20MAJ10-M102 : UNIT 1 VACUUM PUMP A MOTOR (MEGGER, INSPEKSI TERMINAL BLOK, DAN SISTE	22/8/2026			JAPA			☐		
		DISCHARGE, SUCTION & VENTING VALVE VACUUM PUMP-1	22/8/2026			MSW			☐		
		MSW20MAJ10AA101 : UNIT 1 AIR REMOVAL SYSTEM VACUUM BREAKER SOLENOID VALVE	22/8/2026			MSW			☐		
		MSW20MAJ10CG101 : UNIT 1 AIR REMOVAL SYSTEM POSITION TRANSMITTER	22/8/2026						☐		
50	WO-100826-0014	OM EIC Y1 UNIT 1 VACUUM PUMP B	22/8/2026		SCHED-OK	M. Zaini	4	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		MSW20MAJ10-M202 : UNIT 1 VACUUM PUMP B MOTOR (MEGGER, INSPEKSI TERMINAL BLOK, DAN SISTE	22/8/2026			JAPA			☐		
		DISCHARGE, SUCTION & VENTING VALVE VACUUM PUMP-2	22/8/2026			MSW			☐		
		MSW20MAJ10AA201 : UNIT 1 AIR REMOVAL SYSTEM VACUUM BREAKER SOLENOID VALVE	22/8/2026			MSW			☐		
		MSW20MAJ10CG201 : UNIT 1 AIR REMOVAL SYSTEM POSITION TRANSMITTER	22/8/2026						☐		
51	WO-100826-0014	OM EIC Y1 UNIT 1 CONDENSER	22/8/2026		SCHED-OK	M Iqbal	5	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		MSW20MAG10CP103 : UNIT 1 CONDENSER BYPASS PRESSURE TRANSMITTER 10MAG10CP001	22/8/2026			JAPA			☐		
		COOLING WATER SUPPLY TEMPERATURE TRANSMITTER 10PAB11CT001	22/8/2026			JAPA			☐		
		COOLING WATER SUPPLY TEMPERATURE TRANSMITTER 10PAB12CT001	22/8/2026			JAPA			☐		
		COOLING WATER RETURN TEMPERATURE TRANSMITTER 10PAB21CT001	22/8/2026			JAPA			☐		
		COOLING WATER RETURN TEMPERATURE TRANSMITTER 10PAB22CT001	22/8/2026			JAPA			☐		
52	WO-100826-0014	OM EIC Y1 UNIT 1 MAIN CONDENSATE PUMP A	22/8/2026		SCHED-OK	M. Zaini	12	0		SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	22/8/2026			JAPA			☐		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026			JAPA			☐		
		INSPECTION TAHANAN ISOLASI	22/8/2026			JAPA			☐		
		INSPECTION COOLING FAN	22/8/2026			JAPA			☐		
		INSPECTION TAHANAN WINDING	22/8/2026			JAPA			☐		

		INSPECTION TERMINASI	22/8/2026			JAPA		☐		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026			JAPA		☐		
		CALIBRATION LIMIT SWITCH	22/8/2026			JAPA		☐		
		PRESSURE TRANSMITTER CONDENSATE PUMP TO DELIVERY 10LCA30CP001	22/8/2026			JAPA		☐		
		ACTUATOR CONDENSATE PUMP RECIRCULATION CONTROL VALVE 10LCA31AA210	22/8/2026			MSW		☐		
		ACTUATOR MAIN CONDENSATE CONTROL VALVE 10LCA30AA240	22/8/2026			MSW		☐		
		CEP DISCHARGE ISOLATION VALVE	22/8/2026			MSW		☐		
53	WO-100826-0014	OM EIC Y1 UNIT 1 MAIN CONDENSATE PUMP B	22/8/2026		SCHED-OK	M. Zaini	9	0	SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	22/8/2026			JAPA		☐		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	22/8/2026			JAPA		☐		
		INSPECTION TAHANAN ISOLASI	22/8/2026			JAPA		☐		
		INSPECTION COOLING FAN	22/8/2026			JAPA		☐		
		INSPECTION TAHANAN WINDING	22/8/2026			JAPA		☐		
		INSPECTION TERMINASI	22/8/2026			JAPA		☐		
		INSPECTION KONEKSI GROUNDING SYSTEM	22/8/2026			JAPA		☐		
		CALIBRATION LIMIT SWITCH	22/8/2026			JAPA		☐		
		CEP DISCHARGE ISOLATION VALVE	22/8/2026			MSW		☐		
54	WO-100826-0014	OM EIC Y1 UNIT 1 GENERATOR CONTROL PANEL	22/8/2026		IN PROGRESS	M. Zaini	13	54	SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		PENGUJIAN PROTEKSI FREQUENCY	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI DIFFERENSIAL GENERATOR	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI SHORT CIRCUIT	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI OVERCURRENT	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI OVERVOLTAGE	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI ROTOR EARTH FAULT	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI STATOR EARTH FAULT	22/8/2026			MSW		☒		
		PENGUJIAN PROTEKSI REVERSE POWER	22/8/2026			MSW		☐		
		PENGUJIAN PROTEKSI UNDER EXCITATION	22/8/2026			MSW		☐		
		PENGUJIAN PROTEKSI OVER EXCITATION	22/8/2026			MSW		☐		
		PENGUJIAN PROTEKSI NEGATIVE SEQUENCE	22/8/2026			MSW		☐		
		PENGUJIAN PROTEKSI OVERLOAD	22/8/2026			MSW		☐		
		CLEANING DAN TIGHTNING	22/8/2026			MSW		☐		
55	WO-100826-0014	OM EIC Y1 UNIT 1 GENERATOR EXCITATION PANEL	22/8/2026		FINISH	M. Zaini	5	100	SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE PANEL	22/8/2026			MSW		☒		
		MEMBERSIHKAN FILTER PANEL	22/8/2026			MSW		☒		
		PEMELIHARAAN FAN CONVERTER UNITROL	22/8/2026			MSW		☒		
		MEMBERSIHKAN KOMPARTEMEN DALAM PANEL	22/8/2026			MSW		☒		
		HOUSEKEEPING	22/8/2026			MSW		☒		
56	WO-100826-0014	OM EIC Y1 UNIT 1 SOOT BLOWER	22/8/2026		IN PROGRESS	Yoga	16	75	SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 1	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 2	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 3	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 4	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 5	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 6	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 7	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 8	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 9	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 10	22/8/2026			JAPA		☒		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 11	22/8/2026			JAPA		☒		
		SOOT BLOWER STEAM OUTLET TRANSMITTER 10HCB10CP001	22/8/2026			JAPA		☒		
		SOOT BLOWER STEAM FLOW TRANSMITTER 10HCB10CF001	22/8/2026			JAPA		☐		
		ACTUATOR VALVE DRAIN SOOT BLOWER 10HCB10AA201	22/8/2026			AMP		☐		
		SOOT BLOWER VALVE MOV 10HCB10AA001	22/8/2026			AMP		☐		
		ACTUATOR SOOT BLOWER CONTROL VALVE 10HCB10EX001	22/8/2026			MSW		☐		
57	WO-100826-0014	OM EIC Y1 UNIT 1 TURBINE CONTROL PANEL	22/8/2026		SCHED-OK	Jhon FM	3	0	SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		PM PC OWS	22/8/2026					☐		
		PM PC EWS	22/8/2026					☐		
		PM panel RIO	22/8/2026					☐		
58	WO-100826-0014	OM EIC Y1 UNIT 1 LV DISTRIBUTION	22/8/2026		SCHED-OK	M Iqbal	36	0	SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		INSPEKSI LV TRANSFORMER	22/8/2026			JAPA		☐		
		RDC Test LV TRANSFORMER	22/8/2026			JAPA		☐		
		FUNGSI RACK OUT RACK IN	22/8/2026			JAPA		☐		
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN BUSBAR	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI BUSBAR *) sudah termasuk busbar dan busduct	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK BUSBAR	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN KABEL	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN TRAF0 KONTROL	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN SOOTBLOWER MCC FEEDER	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN TO MCC FEEDER	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN ADAPTER PANEL	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK BUSDUCT BUSTIE	22/8/2026			JAPA		☐		
		PERAWATAN ACB INCOMMMING	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI ACB INCOMMMING	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK ACB INCOMMMING	22/8/2026			JAPA		☐		
		PENGUJIAN ANALISA CB	22/8/2026			JAPA		☐		
		PERAWATAN ACB ESP FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI ACB ESP FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK ACB ESP FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN ANALISA CB ESP FEEDER	22/8/2026			JAPA		☐		
		PERAWATAN ACB BOILER FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK ACB BOILER FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN ANALISA CB BOILER FEEDER	22/8/2026			JAPA		☐		
		PERAWATAN ACB COOLING TOWER MCC FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI ACB COOLING TOWER FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK ACB COOLING TOWER FEEDER	22/8/2026			JAPA		☐		
		PENGUJIAN ANALISA CB COOLING TOWER FEEDER	22/8/2026			JAPA		☐		
		INSPECTION HEATER BUSDUCT	22/8/2026			JAPA		☐		
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	22/8/2026			JAPA		☐		
		INSPECTION SILICA BUSDUCT	22/8/2026			JAPA		☐		
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	22/8/2026			JAPA		☐		

		INSPECTION CONTACT RESISTANCE BUSDUCT	22/8/2026			JAPA		☐		
		INSPECTION ISOLATION RESISTANCE BUSDUCT	22/8/2026			JAPA		☐		
		HOUSEKEEPING	22/8/2026			JAPA		☐		
59	WO-100826-0014	OM EIC Y1 UNIT 1 380V MCC SWITCHGEAR BOILER	22/8/2026		SCHED-OK	Yoga	12	0	SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN BUSBAR	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI BUSBAR	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK BUSBAR	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN KABEL	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	22/8/2026			JAPA		☐		
		PERAWATAN MODULE WITHDRAWABLE	22/8/2026			JAPA		☐		
		PERAWATAN ACB INCOMMING	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI ACB INCOMING	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK ACB	22/8/2026			JAPA		☐		
		PENGUJIAN ANALISA CB	22/8/2026			JAPA		☐		
		HOUSEKEEPING	22/8/2026			JAPA		☐		
60	WO-100826-0014	OM EIC Y1 UNIT 1 380V MCC SWITCHGEAR TG	22/8/2026		SCHED-OK	M Iqbal	8	0	SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN BUSBAR	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN ISOLASI BUSBAR	22/8/2026			JAPA		☐		
		PENGUJIAN TAHANAN KONTAK BUSBAR	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN KABEL	22/8/2026			JAPA		☐		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	22/8/2026			JAPA		☐		
		PERAWATAN MODULE WITHDRAWABLE	22/8/2026			JAPA		☐		
		HOUSEKEEPING	22/8/2026			JAPA		☐		
61	WO-100826-0014	OM EIC Y1 UNIT 1 380V MCC SWITCHGEAR ESP	22/8/2026		IN PROGRESS	M Iqbal	12	92	SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	22/8/2026			JAPA		☒		
		PERAWATAN KOMPARTEMEN BUSBAR	22/8/2026			JAPA		☒		
		PENGUJIAN TAHANAN ISOLASI BUSBAR	22/8/2026			JAPA		☒		
		PENGUJIAN TAHANAN KONTAK BUSBAR	22/8/2026			JAPA		☒		
		PERAWATAN KOMPARTEMEN KABEL	22/8/2026			JAPA		☒		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	22/8/2026			JAPA		☒		
		PERAWATAN MODULE WITHDRAWABLE	22/8/2026			JAPA		☒		
		PERAWATAN ACB INCOMMING	22/8/2026			JAPA		☒		
		PENGUJIAN TAHANAN ISOLASI ACB INCOMMING	22/8/2026			JAPA		☒		
		PENGUJIAN TAHANAN KONTAK ACB INCOMMING	22/8/2026			JAPA		☒		
		PENGUJIAN ANALISA CB	22/8/2026			JAPA		☒		
		HOUSEKEEPING	22/8/2026			JAPA		☐		
62	WO-100826-0014	OM Y1 EIC UNIT 1 GLAND STEAM SEALING CONDENSER	22/8/2026		SCHED-OK	Aldhly	5	0	SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		GLAND STEAM CONDENSER VENTING MOTOR	22/8/2026					☐		
		GLAND STEAM PRESSURE TRANSMITTER 10MAW11CP001	22/8/2026					☐		
		ACTUATOR GLAND STEAM PRESSURE CONTROL VALVE 10MAW10AA210	22/8/2026					☐		
		ACTUATOR GLAND STEAM TEMPERATURE CONTROL VALVE 10LCE10AA210	22/8/2026					☐		
		GENERAL CLEANING	22/8/2026					☐		
63	WO-100826-0014	OM Y1 EIC UNIT 2 CONVECTIVE PASS	22/8/2026		IN PROGRESS	Ferryus	6	83	SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		INSPECTION AND CALIBRATION OXYGEN ANALYZER	22/8/2026					☐		
		INLET BACKPASS PRESSURE TRANSMITTER	22/8/2026					☒		
		INLET BACKPASS PRESSURE TRANSMITTER	22/8/2026					☒		
		INLET BACKPASS PRESSURE TRANSMITTER	22/8/2026					☒		
		BACKPASS PRESSURE AFTER LT SH TRANSMITTER	22/8/2026					☒		
		BACKPASS PRESSURE AFTER ECO TRANSMITTER	22/8/2026					☒		
64	WO-100826-0014	OM Y1 EIC UNIT 2 FLY ASH HANDLING	22/8/2026		IN PROGRESS	M Iqbal	6	33	SUPERVISE, QC, OTHER TASK AS PER EIC/IP	
		Panel Bapcon - Rapcon Field 1	22/8/2026					☒		
		Panel Bapcon - Rapcon Field 2	22/8/2026					☒		
		Panel Bapcon - Rapcon Field 3	22/8/2026					☐		
		Panel Bapcon - Rapcon Field 4	22/8/2026					☐		
		Panel Bapcon - Rapcon Field 5	21/07/2025					☐		
		Panel Bapcon - Rapcon Field 6	21/07/2025					☐		