

PROGRESS JOBS OUTAGE UNIT 2



SECTION ELECTRIC, INSTRUMENT, CONTROL (EIC)

SCHED-OK	FINISH	IN PROGRESS	TOTAL	% FINISH	PROGRES
0	63	0	63	100.0%	6300.0

NO	NO WO	JOB DESCRIPTION	DATED			STATUS	PIC	N Task	%Estimation	SCOPE	REMARKS
			SCHEDULE	ACTUAL START	FINISH						
1	WO-180726-0003	OM EIC Y1 UNIT COMMON COOLING TOWER FAN 3	21/07/2026	25/07/2026	25/07/2026	FINISH	Aldhly	9	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR							✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)							✓		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)							✓		
		INSPECTION TAHANAN ISOLASI							✓		
		INSPECTION TAHANAN WINDING							✓		
		INSPECTION COOLING FAN							✓		
		INSPECTION TERMINASI							✓		
		INSPECTION KONEKSI GROUNDING SYSTEM							✓		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE							✓		
2	WO-180726-0004	OM EIC Y1 UNIT COMMON COOLING TOWER FAN 4	21/07/2026	25/07/2026	25/07/2026	FINISH	Aldhly	9	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026						✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						✓		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)	21/07/2026						✓		
		INSPECTION TAHANAN ISOLASI	21/07/2026						✓		
		INSPECTION TAHANAN WINDING	21/07/2026						✓		
		INSPECTION COOLING FAN	21/07/2026						✓		
		INSPECTION TERMINASI	21/07/2026						✓		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						✓		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	21/07/2026						✓		
3	WO-180726-0002	OM EIC Y1 UNIT COMMON MAIN COOLING WATER PUMP 4	21/07/2026	23/07/2026	23/07/2026	FINISH	Aldhly	7	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026	22/07/2026					✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026	22/07/2026					✓		
		INSPECTION TAHANAN ISOLASI	21/07/2026	22/07/2026					✓		
		INSPECTION COOLING FAN	21/07/2026	22/07/2026					✓		
		INSPECTION TERMINASI	21/07/2026	22/07/2026					✓		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026	22/07/2026					✓		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	21/07/2026	22/07/2026					✓		
4	WO-180726-0005	OM EIC Y1 UNIT COMMON MAIN COOLING WATER PUMP 5	21/07/2026	24/07/2026	24/07/2026	FINISH	Aldhly	8	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026	22/07/2026					✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026	22/07/2026					✓		
		INSPECTION TAHANAN ISOLASI	21/07/2026	22/07/2026					✓		
		INSPECTION TAHANAN WINDING	21/07/2026	22/07/2026					✓		
		INSPECTION COOLING FAN	21/07/2026	22/07/2026					✓		
		INSPECTION TERMINASI	21/07/2026	22/07/2026					✓		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026	22/07/2026					✓		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	21/07/2026	22/07/2026					✓		
5	WO-180726-0006	OM EIC Y1 UNIT COMMON AUXILIARY COOLING WATER PUMP 3	21/07/2026	26/07/2026	27/07/2026	FINISH	Aldhly	9	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026						✓		
		INSPECTION BEARING & REPLACEMENT	21/07/2026						✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						✓		
		INSPECTION TAHANAN ISOLASI	21/07/2026						✓		
		INSPECTION TAHANAN WINDING	21/07/2026						✓		
		INSPECTION COOLING FAN	21/07/2026						✓		
		INSPECTION TERMINASI	21/07/2026						✓		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						✓		
		INSPECTION AND CALIBRATION MEASUREMENT DEVICE	21/07/2026						✓		
6	WO-180726-0007	OM EIC Y1 UNIT 2 INDUCED DRAUGHT FAN 1	21/07/2026			FINISH	M. Toher	13	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		UNIT 2 INDUCED DRAUGHT FAN 1 INLET GATE ACTUATOR MOV 20HNA61AA001	21/07/2026				AMP		✓		
		UNIT 2 INDUCED DRAUGHT FAN 1 OUTLET GATE ACTUATOR MOV 20HNA71AA001	21/07/2026				AMP		✓		
		MSW20HNC10-M103:UNIT 2 INDUCED DRAUGHT FAN 1 MOTOR	21/07/2026				JAPA		✓		
		REPOSISI MOTOR	21/07/2026				JAPA		✓		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	21/07/2026				JAPA		✓		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE (REPLACE BEARING IF NEEDED)	21/07/2026				JAPA		✓		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	21/07/2026				JAPA		✓		
		PENGUKURAN TAHANAN BELITAN	21/07/2026				JAPA		✓		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	21/07/2026				JAPA		✓		
		UNIT 2 INDUCED DRAUGHT FAN 1 IGW 20HNC01EX001	21/07/2026				AMP		✓		
		INLET ID FAN 1 PRESSURE TRANSMITTER 20HNA61CP001	21/07/2026				JAPA		✓		
		INLET PRESSURE ESP PRESSURE TRANSMITTER 20HNA41CP001	21/07/2026				JAPA		✓		
		OUTLET PRESSURE ESP PRESSURE TRANSMITTER 20HNA41CP002	21/07/2026				JAPA		✓		
7	WO-180726-0008	OM EIC Y1 UNIT 2 INDUCED DRAUGHT FAN 2	21/07/2026	23/07/2026		FINISH	M. Toher	11	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		UNIT 2 INDUCED DRAUGHT FAN 2 INLET ACTUATOR MOV 20HNA62AA001	21/07/2026	21/07/2026			AMP		✓		
		UNIT 2 INDUCED DRAUGHT FAN 2 OUTLET ACTUATOR MOV 20HNA72AA001	21/07/2026	21/07/2026			AMP		✓		
		MSW20HNC10-M203:UNIT 2 INDUCED DRAUGHT FAN 2 MOTOR	21/07/2026	21/07/2026			JAPA		✓		
		REPOSISI MOTOR	21/07/2026	21/07/2026			JAPA		✓		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	21/07/2026	21/07/2026			JAPA		✓		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE (REPLACE BEARING IF NEEDED)	21/07/2026				JAPA		✓		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	21/07/2026	21/07/2026			JAPA		✓		
		PENGUKURAN TAHANAN BELITAN	21/07/2026	21/07/2026			JAPA		✓		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	21/07/2026				JAPA		✓		
		UNIT 2 INDUCED DRAUGHT FAN 2 IGW 20HNC01EX002	21/07/2026	21/07/2026			AMP		✓		
		INLET ID FAN 2 PRESSURE TRANSMITTER 20HNA62CP001	21/07/2026				JAPA		✓		
8	WO-180726-0009	OM EIC Y1 UNIT 2 PRIMARY AIR FAN 1	21/07/2026	22/07/2026	22/07/2026	FINISH	M. Zaini	11	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLB20-M101:UNIT 2 PRIMARY AIR FAN 1 MOTOR	21/07/2026				JAPA		✓		
		REPOSISI MOTOR	21/07/2026				JAPA		✓		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	21/07/2026				JAPA		✓		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	21/07/2026				JAPA		✓		
		REPLACE BEARING IF NEEDED	21/07/2026				JAPA		✓		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	21/07/2026				JAPA		✓		
		PENGUKURAN TAHANAN BELITAN	21/07/2026				JAPA		✓		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	21/07/2026				JAPA		✓		
		UNIT 2 PRIMARY AIR FAN 1 IGW	21/07/2026				MSW		✓		

		UNIT 2 PRIMARY AIR FAN 1 OUTLET MOV	21/07/2026				MSW		☒		
		PA FAN 1 OUTLET PRESSURE TRANSMITTER 20HLB03CP001	21/07/2026				JAPA		☒		
9	WO-180726-0010	OM EIC Y1 UNIT 2 PRIMARY AIR FAN 1 LUBE OIL SYSTEM	21/07/2026	24/07/2026	24/07/2026	FINISH	Aldhy	6	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN20-M101:UNIT 2 PRIMARY AIR FAN 1 LUBE OIL PUMP 1 MOTOR (STAND BY)	21/07/2026						☒		
		MSW20HLN20-M102:UNIT 2 PRIMARY AIR FAN 1 LUBE OIL PUMP 2 MOTOR (MAIN)	21/07/2026						☒		
		20HLB01CP104: LO HEADER PRESSURE LOW ALARM FOR PA FAN-1	21/07/2026						☒		
		20HLB01CP103: PRESSURE SWITCH TO START PERMISSIVE FOR PA FAN-1 START	21/07/2026						☒		
		20HLB01CP102: PRESSURE SWITCH TO START LO PA FAN-1 STANDBY PUMP	21/07/2026						☒		
		20HLB01CP101: DP SWITCH ACROSS LO TANK FOR PA FAN-1	21/07/2026						☒		
10	WO-180726-0011	OM EIC Y1 UNIT 2 PRIMARY AIR FAN 2	21/07/2026	22/07/2026	22/07/2026	FINISH	M. Zaini	10	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	21/07/2026						☒		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	21/07/2026						☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	21/07/2026						☒		
		REPLACE BEARING IF NEEDED	21/07/2026						☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	21/07/2026						☒		
		PENGUKURAN TAHANAN BELITAN	21/07/2026						☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	21/07/2026						☒		
		UNIT 2 PRIMARY AIR FAN 2 IDV	21/07/2026						☒		
		MSW20HLB20AA02:UNIT 2 PRIMARY AIR FAN 2 OUTLET MOV	21/07/2026						☒		
		PA FAN 2 OUTLET PRESSURE TRANSMITTER 20HLB04CP001	21/07/2026						☒		
11	WO-180726-0012	OM EIC Y1 UNIT 2 PRIMARY AIR FAN 2 LUBE OIL SYSTEM	21/07/2026	24/07/2026	24/07/2026	FINISH	Aldhy	6	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN20-M201:UNIT 2 PRIMARY AIR FAN 2 LUBE OIL PUMP 1 MOTOR (STAND BY)	21/07/2026						☒		
		MSW20HLN20-M202:UNIT 2 PRIMARY AIR FAN 2 LUBE OIL PUMP 2 MOTOR (MAIN)	21/07/2026						☒		
		20HLB02CP104: LO HEADER PRESSURE LOW ALARM FOR PA FAN-2	21/07/2026						☒		
		20HLB02CP103: PRESSURE SWITCH TO START PERMISSIVE FOR PA FAN-2 START	21/07/2026						☒		
		20HLB02CP102: PRESSURE SWITCH TO START LO PA FAN-2 STANDBY PUMP	21/07/2026						☒		
		MSW20HLN20CL201:UNIT 2 PRIMARY AIR FAN 2 LUBE OIL TANK LEVEL SWITCH	21/07/2026						☒		
12	WO-180726-0013	OM EIC Y1 UNIT 2 SECONDARY AIR FAN 1	21/07/2026	23/07/2026	23/07/2026	FINISH	M. Zaini	10	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	21/07/2026						☒		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	21/07/2026						☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	21/07/2026						☒		
		REPLACE BEARING IF NEEDED	21/07/2026						☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	21/07/2026						☒		
		PENGUKURAN TAHANAN BELITAN	21/07/2026						☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	21/07/2026						☒		
		UNIT 2 SECONDARY AIR FAN 1 OUTLET MOV	21/07/2026						☒		
		SA FAN 1 OUTLET PRESSURE TRANSMITTER 20HLB01CP001	21/07/2026						☒		
		UNIT 2 SECONDARY AIR FAN 1 IDV SA FAN 1 20HLB01EX001	21/07/2026						☒		
13	WO-180726-0014	OM EIC Y1 UNIT 2 SECONDARY AIR FAN 1 LUBE OIL SYSTEM	21/07/2026	24/07/2026	24/07/2026	FINISH	Aldhy	7	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN10-M101:UNIT 2 SECONDARY AIR FAN 1 LUBE OIL PUMP 1 MOTOR (STAND BY)	21/07/2026						☒		
		MSW20HLN10-M102:UNIT 2 SECONDARY AIR FAN 1 LUBE OIL PUMP 2 MOTOR (MAIN)	21/07/2026						☒		
		20HLB02CP101: DP SWITCH ACROSS LO TANK FOR SA FAN-1	21/07/2026						☒		
		20HLB05CP104: LO HEADER PRESSURE LOW ALARM FOR SA FAN-1	21/07/2026						☒		
		20HLB05CP103: PRESSURE SWITCH TO START PERMISSIVE FOR SA FAN-1 START	21/07/2026						☒		
		20HLB05CP102: PRESSURE SWITCH TO START LO SA FAN-1 STANDBY PUMP	21/07/2026						☒		
		20HLB05CP101: DP SWITCH ACROSS LO TANK FOR SA FAN-1	21/07/2026						☒		
14	WO-180726-0015	OM EIC Y1 UNIT 2 SECONDARY AIR FAN 2	21/07/2026	23/07/2026	23/07/2026	FINISH	M. Zaini	10	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		REPOSISI MOTOR	21/07/2026						☒		
		DISASSEMBLY COVER FAN DAN COVER BEARING SISI DE DAN NDE	21/07/2026						☒		
		INSPEKSI DAN CLEANING BALL BEARING DE DAN NDE	21/07/2026						☒		
		REPLACE BEARING IF NEEDED	21/07/2026						☒		
		REGREASING BEARING DAN PENGUKURAN TAHANAN ISOLASI	21/07/2026						☒		
		PENGUKURAN TAHANAN BELITAN	21/07/2026						☒		
		ASSEMBLY ALL PART AND REPOSISI MOTOR	21/07/2026						☒		
		UNIT 2 SECONDARY AIR FAN 1 OUTLET MOV	21/07/2026						☒		
		UNIT 2 SECONDARY AIR FAN 1 IDV SA FAN 2 20HLB01EX001	21/07/2026						☒		
		SA FAN 2 OUTLET PRESSURE TRANSMITTER 20HLB02CP001	21/07/2026						☒		
15	WO-180726-0016	OM EIC Y1 UNIT 2 SECONDARY AIR FAN 2 LUBE OIL SYSTEM	21/07/2026	24/07/2026	24/07/2026	FINISH	Jhon FM	6	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20HLN10-M201:UNIT 2 SECONDARY AIR FAN 2 LUBE OIL PUMP 1 MOTOR (STAND BY)	21/07/2026						☒		
		MSW20HLN10-M202:UNIT 2 SECONDARY AIR FAN 2 LUBE OIL PUMP 2 MOTOR (MAIN)	21/07/2026						☒		
		20HLB06CP104: LO HEADER PRESSURE LOW ALARM FOR SA FAN-2	21/07/2026						☒		
		20HLB06CP103: PRESSURE SWITCH TO START PERMISSIVE FOR SA FAN-2 START	21/07/2026						☒		
		20HLB06CP102: PRESSURE SWITCH TO START LO SA FAN-2 STANDBY PUMP	21/07/2026						☒		
		20HLB06CP101: DP SWITCH ACROSS LO TANK FOR SA FAN-2	21/07/2026						☒		
16	WO-180726-0017	OM EIC Y1 UNIT 2 COAL FEEDER NO 1	21/07/2026	24/07/2026	28/07/2026	FINISH	Aldhy	13	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR DRAG CHAIN	21/07/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						☒		
		INSPECTION TAHANAN ISOLASI	21/07/2026						☒		
		INSPECTION COOLING FAN	21/07/2026						☒		
		INSPECTION TERMINASI	21/07/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						☒		
		INSPECTION FRAME MOTOR ROTARY AIR LOCK	21/07/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						☒		
		INSPECTION TAHANAN ISOLASI	21/07/2026						☒		
		INSPECTION COOLING FAN	21/07/2026						☒		
		INSPECTION TERMINASI	21/07/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						☒		
		INSPECTION OF MFT ACTUATOR 20HHE11AA01	21/07/2026						☒		
17	WO-180726-0018	OM EIC Y1 UNIT 2 COAL FEEDER NO 2	21/07/2026	24/07/2026	28/07/2026	FINISH	Aldhy	13	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR DRAG CHAIN	21/07/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						☒		
		INSPECTION TAHANAN ISOLASI	21/07/2026						☒		
		INSPECTION COOLING FAN	21/07/2026						☒		
		INSPECTION TERMINASI	21/07/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						☒		
		INSPECTION FRAME MOTOR ROTARY AIR LOCK	21/07/2026						☒		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						☒		
		INSPECTION TAHANAN ISOLASI	21/07/2026						☒		
		INSPECTION COOLING FAN	21/07/2026						☒		
		INSPECTION TERMINASI	21/07/2026						☒		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						☒		
		INSPECTION OF MFT ACTUATOR 20HHE12AA01	21/07/2026				AMP		☒		

18	WO-180726-0019	OM EIC Y1 UNIT 2 LDO START-UP BURNER 1	21/07/2026			FINISH	M. Toher	18	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION OF 'IGNITER GUN	21/07/2026			MSW			☑		
		INSPECTION OF START UP BURNER SKID DEVICE	21/07/2026			MSW			☑		
		LDO PRESSURE BEFORE MTV SWITCH 20HF11CP301	21/07/2026			MSW			☑		
		ATOM AIR INLET PRESSURE LOW SWITCH 20HN11CP301	21/07/2026			MSW			☑		
		LDO PRESSURE LOW TRIP FOR SUB 1 SWITCH 20HF11CP302	21/07/2026			MSW			☑		
		ATOM AIR PRESSURE LOW TRIP FOR SUB 1 SWITCH 20HN11CP302	21/07/2026			MSW			☑		
		LDO PRESSURE HIGH TRIP FOR SUB 1 SWITCH 20HF11CP303	21/07/2026			MSW			☑		
		SCANNER AIR PRESSURE OK 1 SWITCH 20HG69CP301	21/07/2026			MSW			☑		
		SCANNER AIR PRESSURE OK 2 SWITCH 20HG69CP302	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER MAIN LDO LINE CONTROL VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 1 LDO LINE CONTROL VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 1 ATOMISING AIR LINE CONTROL VALVE	21/07/2026			MSW			☑		
		ACTUATOR SUB BURNER 1 VALVE 20HN11AA003	21/07/2026			AMP			☑		
		ACTUATOR SKID BURNER 1 ATOM AIR ISOLATION VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 1 LDO ISOLATION VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 1 SCAVENGING VALVE	21/07/2026			MSW			☑		
		ATOM AIR PRESSURE AFTER SUB 1 TRANSMITTER 20HN11CP001	21/07/2026			JAPA			☑		
		LDO PRESS AFTER SUB1 FV2 TRANSMITTER 20HF11CP001	21/07/2026			JAPA			☑		
19	WO-180726-0020	OM EIC Y1 UNIT 2 LDO START-UP BURNER 2	21/07/2026			FINISH	M. Toher	13	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION OF 'IGNITER GUN	21/07/2026			MSW			☑		
		INSPECTION OF START UP BURNER SKID DEVICE	21/07/2026			MSW			☑		
		LDO PRESSURE LOW TRIP FOR SUB 2 SWITCH 20HF12CP302	21/07/2026			MSW			☑		
		ATOM AIR PRESSURE LOW TRIP FOR SUB 2 SWITCH 20HN12CP302	21/07/2026			MSW			☑		
		LDO PRESSURE HIGH TRIP FOR SUB 2 SWITCH 20HF12CP303	21/07/2026			MSW			☑		
		ATOM AIR PRESSURE AFTER SUB 2 TRANSMITTER 20HN12CP001	21/07/2026			JAPA			☑		
		LDO PRESS AFTER SUB2 FV2 TRANSMITTER 20HF12CP001	21/07/2026			JAPA			☑		
		ACTUATOR SKID BURNER 2 LDO LINE CONTROL VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 2 ATOMISING AIR LINE CONTROL VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 2 ATOM AIR ISOLATION VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 2 LDO ISOLATION VALVE	21/07/2026			MSW			☑		
		ACTUATOR SKID BURNER 2 SCAVENGING VALVE	21/07/2026			MSW			☑		
		ACTUATOR SUB BURNER 2 VALVE 20HN12AA003	21/07/2026			AMP			☑		
20	WO-180726-0021	OM EIC Y1 UNIT 2 SEALPOT BLOWER NO 1	21/07/2026	24/07/2026	24/07/2026	FINISH	Ferryus	9	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	21/07/2026						☑		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						☑		
		PENGANTIAN BEARING (JIKA DIPERLUKAN)	21/07/2026						☑	Tidak diganti	
		INSPECTION TAHANAN ISOLASI	21/07/2026						☑		
		INSPECTION COOLING FAN	21/07/2026						☑		
		INSPECTION TERMINASI	21/07/2026						☑		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						☑		
		SEALPOT BLOWER PRESS OUTLET TRANSMITTER 20HLB41CP001	21/07/2026			JAPA			☑		
		P&S BLOWER PRESS OUTLET TRANSMITTER 20QEB20CP001	21/07/2026			JAPA			☑		
21	WO-180726-0022	OM EIC Y1 UNIT 2 SEALPOT BLOWER NO 2	21/07/2026	24/07/2026	24/07/2026	FINISH	Ferryus	7	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	21/07/2026						☑		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026						☑		
		PENGANTIAN BEARING	21/07/2026						☑		
		INSPECTION TAHANAN ISOLASI	21/07/2026						☑		
		INSPECTION COOLING FAN	21/07/2026						☑		
		INSPECTION TERMINASI	21/07/2026						☑		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026						☑		
22	WO-180726-0023	OM EIC Y1 UNIT 2 ELECTROSTATIC PRECIPITATOR 1-6	21/07/2026			FINISH	M. Iqbal	19	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		MSW20HDE10-M101:UNIT 2 ESP RAPPING MOTOR (GDRM)	21/07/2026			JAPA			☑		
		MSW20HDE10-M102:UNIT 2 ESP RAPPING MOTOR (CERM-1)	21/07/2026			JAPA			☑		
		MSW20HDE10-M103:UNIT 2 ESP RAPPING MOTOR (CERM-2)	21/07/2026			JAPA			☑		
		MSW20HDE10-M104:UNIT 2 ESP RAPPING MOTOR (CERM-3)	21/07/2026			JAPA			☑		
		MSW20HDE10-M105:UNIT 2 ESP RAPPING MOTOR (CERM-4)	21/07/2026			JAPA			☑		
		MSW20HDE10-M106:UNIT 2 ESP RAPPING MOTOR (CERM-5)	21/07/2026			JAPA			☑		
		MSW20HDE10-M107:UNIT 2 ESP RAPPING MOTOR (CERM-6)	21/07/2026			JAPA			☑		
		MSW20HDE10-M108:UNIT 2 ESP RAPPING MOTOR (EERM-1)	21/07/2026			JAPA			☑		
		MSW20HDE10-M109:UNIT 2 ESP RAPPING MOTOR (EERM-2)	21/07/2026			JAPA			☑		
		MSW20HDE10-M110:UNIT 2 ESP RAPPING MOTOR (EERM-3)	21/07/2026			JAPA			☑		
		MSW20HDE10-M120:UNIT 2 ESP RAPPING MOTOR (EERM-4)	21/07/2026			JAPA			☑		
		MSW20HDE10-M130:UNIT 2 ESP RAPPING MOTOR (EERM-5)	21/07/2026			JAPA			☑		
		MSW20HDE10-M140:UNIT 2 ESP RAPPING MOTOR (EERM-6)	21/07/2026			JAPA			☑		
		UNIT 2 ESP TRAF0 1 (GENERAL CLEANING, INSPEKSI, IR TEST)	21/07/2026	21/07/2026		JAPA			☑		
		UNIT 2 ESP TRAF0 2 (GENERAL CLEANING, INSPEKSI, IR TEST)	21/07/2026	21/07/2026		JAPA			☑		
		UNIT 2 ESP TRAF0 3 (GENERAL CLEANING, INSPEKSI, IR TEST)	21/07/2026	21/07/2026		JAPA			☑		
		UNIT 2 ESP TRAF0 4 (GENERAL CLEANING, INSPEKSI, IR TEST)	21/07/2026	21/07/2026		JAPA			☑		
		UNIT 2 ESP TRAF0 5 (GENERAL CLEANING, INSPEKSI, IR TEST)	21/07/2026	21/07/2026		JAPA			☑		
		UNIT 2 ESP TRAF0 6 (GENERAL CLEANING, INSPEKSI, IR TEST)	21/07/2026	21/07/2026		JAPA			☑		
23	WO-180726-0024	OM EIC Y1 UNIT 2 BOILER FEED PUMP 1	21/07/2026	25/07/2026	25/07/2026	FINISH	Yoga	21	100	SUPERVISE_QC, OTHER TASK AS PER EIC/IP	
		INSPECTION FRAME MOTOR	21/07/2026			JAPA			☑		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026			JAPA			☑		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)	21/07/2026			JAPA			☑		
		INSPECTION TAHANAN ISOLASI	21/07/2026			JAPA			☑		
		INSPECTION TAHANAN WINDING	21/07/2026			JAPA			☑		
		INSPECTION COOLING FAN	21/07/2026			JAPA			☑		
		INSPECTION TERMINASI	21/07/2026			JAPA			☑		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026			JAPA			☑		
		MSW20LAC10-M101:MOV DISCHARGE BFP-1	21/07/2026			MSW			☑		
		MSW20LAC10AA104:UNIT 2 BOILER FEED PUMP 1 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	21/07/2026			MSW			☑		
		MSW20LAC10AA105:UNIT 2 BOILER FEED PUMP 1 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	21/07/2026			MSW			☑		
		MSW20LAC10CG101:UNIT 2 BOILER FEED PUMP 1 LIMIT SWITCH	21/07/2026			MSW			☑		
		20LAC10CP101:UNIT 2 BOILER FEED PUMP 1 PRESSURE DIFFERENTIAL SWITCH	21/07/2026			MSW			☑		
		MSW20LAC10CT101:UNIT 2 BOILER FEED PUMP 1 R PHASE WDG TEMPERATURE	21/07/2026			MSW			☑		
		MSW20LAC10CT102:UNIT 2 BOILER FEED PUMP 1 B PHASE WDG TEMPERATURE	21/07/2026			MSW			☑		
		MSW20LAC10CT103:UNIT 2 BOILER FEED PUMP 1 B PHASE WDG TEMPERATURE	21/07/2026			MSW			☑		
		MSW20LAC10CT104:UNIT 2 BOILER FEED PUMP 1 B NDE MOTOR BEARING TEMPERATURE	21/07/2026			MSW			☑		
		MSW20LAC10CT105:UNIT 2 BOILER FEED PUMP 1 B NDE MOTOR BEARING TEMPERATURE	21/07/2026			MSW			☑		
		MSW20LAC10CT106:UNIT 2 BOILER FEED PUMP 1 B NDE PUMP BEARING TEMPERATURE	21/07/2026			MSW			☑		
		MSW20LAC10CT107:UNIT 2 BOILER FEED PUMP 1 B NDE PUMP BEARING TEMPERATURE	21/07/2026			MSW			☑		

		MSW20LAC10GH101:UNIT 2 BOILER FEED PUMP 1 FCMA PANEL	21/07/2026					MSW			☑		
24	WO-180726-0025	OM EIC Y1 UNIT 2 BOILER FEED PUMP 2	21/07/2026	25/07/2026	25/07/2026	FINISH		Yoga	21	100		SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026					JAPA			☑		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026					JAPA			☑		
		INSPECTION BEARING DAN REPLACEMENT (JIKA DIPERLUKAN)	21/07/2026					JAPA			☑		
		INSPECTION TAHANAN ISOLASI	21/07/2026					JAPA			☑		
		INSPECTION TAHANAN WINDING	21/07/2026					JAPA			☑		
		INSPECTION COOLING FAN	21/07/2026					JAPA			☑		
		INSPECTION TERMINASI	21/07/2026					JAPA			☑		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026					MSW			☑		
		MSW20LAC10-M201:MOV DISCHARGE BFP-2	21/07/2026					MSW			☑		
		MSW20LAC10AA204:UNIT 2 BOILER FEED PUMP 2 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	21/07/2026					MSW			☑		
		MSW20LAC10AA205:UNIT 2 BOILER FEED PUMP 2 VALVE FOR PRESSURE DIFFERENTIAL SWITCH	21/07/2026					MSW			☑		
		MSW20LAC10CG201:UNIT 2 BOILER FEED PUMP 2 UNIT SWITCH	21/07/2026					MSW			☑		
		MSW20LAC10CP201:UNIT 2 BOILER FEED PUMP 2 PRESSURE DIFFERENTIAL SWITCH	21/07/2026					MSW			☑		
		MSW20LAC10CT201:UNIT 2 BOILER FEED PUMP 2 R PHASE WDG TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10CT202:UNIT 2 BOILER FEED PUMP 2 B PHASE WDG TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10CT203:UNIT 2 BOILER FEED PUMP 2 B PHASE WDG TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10CT204:UNIT 2 BOILER FEED PUMP 2 B NDE MOTOR BEARING TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10CT205:UNIT 2 BOILER FEED PUMP 2 B NDE MOTOR BEARING TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10CT206:UNIT 2 BOILER FEED PUMP 2 B NDE PUMP BEARING TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10CT207:UNIT 2 BOILER FEED PUMP 2 B NDE PUMP BEARING TEMPERATURE	21/07/2026					MSW			☑		
		MSW20LAC10GH201:UNIT 2 BOILER FEED PUMP 2 FCMA PANEL	21/07/2026					MSW			☑		
25	WO-180726-0026	OM EIC Y1 UNIT 2 FEED WATER LINE	21/07/2026			FINISH		M. Toher	10	100		SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		UNIT 2 FEED WATER INLET ECONOMIZER MOTORIZED VALVE MOTOR 100% 20LAB30AA220	21/07/2026					AMP			☑		
		UNIT 2 FEED WATER INLET ECONOMIZER MOTORIZED VALVE ISOLATION VALVE	21/07/2026					AMP			☑		
		UNIT 2 FEED WATER INLET ECONOMIZER MOTORIZED VALVE MOTOR 30% 20LAB30AA210	21/07/2026					AMP			☑		
		UNIT 2 FEED WATER INLET ECONOMIZER MOTORIZED VALVE ISOLATION VALVE	21/07/2026					AMP			☑		
		ACTUATOR BFP SPRAY LINE (FEED WATER) TO DEAEATOR PRDS VL CV 20LAE10AA210	21/07/2026					AMP			☑		
		BFP SPRAY LINE (FEED WATER) TO DEAEATOR PRDS VL MOV 20LAE10AA110	21/07/2026					AMP			☑		
		DISTRIBUTOR LINE TO FEEDWATER TRANSMITTER 20LAB30CP001	21/07/2026					JAPA			☑		
		INLET FEEDWATER PRESSURE TRANSMITTER 20HAC90CP001	21/07/2026					JAPA			☑		
		INLET FEEDWATER FLOW TRANSMITTER 20HAC90CF001	21/07/2026					JAPA			☑		
		INLET FEEDWATER FLOW TRANSMITTER 20HAC90CF002	21/07/2026					JAPA			☑		
26	WO-180726-0027	OM EIC Y1 UNIT 2 DESH SUPERHEATER LINE 1	21/07/2026			FINISH		M. Toher	4	100		SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		CALIBRATION PRESSURE GAUGE	21/07/2026								☑		
		CALIBRATION/FUNCTION TEST SPRAY CONTROL VALVE 20LAE10EX001	21/07/2026								☑		
		CALIBRATION/FUNCTION ISOLATION (ON/OFF) VALVE	21/07/2026								☑		
		DESH 1 SPRAY WATER FLOW TRANSMITTER 20LAE20CF001	21/07/2026								☑		
27	WO-180726-0028	OM EIC Y1 UNIT 2 DESH SUPERHEATER LINE 2	21/07/2026			FINISH		M. Toher	4	100		SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		DESH 2 SPRAY WATER FLOW TRANSMITTER 20LAE30CF001	21/07/2026					JAPA			☑		
		CALIBRATION/FUNCTION TEST SPRAY CONTROL VALVE 20LAE12EX001	21/07/2026					AMP			☑		
		BEFORE DESH 2 TEMP TRANSMITTER CALIBRATION (20HAH46CT001, 20HAH36CT009, 20HAH36CT009)	21/07/2026					MSW			☑		
		CALIBRATION/FUNCTION ISOLATION (ON/OFF) VALVE	21/07/2026					AMP			☑		
28	WO-180726-0029	OM EIC Y1 UNIT 2 GENERATOR CIRCUIT BREAKER	21/07/2026			FINISH		M. Zaini	30	100		SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		INSPECTION MEKANIK PENGGERAK	21/07/2026								☑		
		INSPECTION MOTOR CHARGING	21/07/2026								☑		
		INSPECTION BEARING DRIVE RACK OUT/IN	21/07/2026								☑		
		REGREASING SOCKET MAIN KONTAK	21/07/2026								☑		
		INSPECTION SYSTEM KONTROL	21/07/2026								☑		
		TEST TAHANAN KONTAK	21/07/2026								☑		
		TEST KESEREMPAKAN	21/07/2026								☑		
		INSPECTION TAHANAN ISOLASI KONTAK	21/07/2026								☑		
		INSPECTION TAHANAN ISOLASI BUS BAR	21/07/2026								☑		
		FUNCTION TEST	21/07/2026								☑		
		PENGUKURAN TAHANAN MOTOR CHARGING, CLOSING DAN TRIPPING COIL	21/07/2026								☑		
		INSPECTION MODUL CONTROL BREAKER	21/07/2026								☑		
		INSPECTION LAMPU SWITCH GEAR GCB	21/07/2026								☑		
		INDIKATOR DAN LAMPU PANEL SWITCH GEAR GCB	21/07/2026								☑		
		PENGOTESAN POWER DC UNTUK SUPPLY CONTROL 6,3 KV SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION HEATER CUBICLE SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION DAN CLEANING TERMINASI SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION DAN PENGUJIAN RELAY PROTEKSI SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION GROUNDING SYSTEM SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION TAHANAN ISOLASI BUS BAR SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION CT & PT SWITCH GEAR GCB	21/07/2026								☑		
		FUNCTION TEST SWITCH GEAR GCB	21/07/2026								☑		
		INSPECTION HEATER SYSTEM	21/07/2026								☑		
		INSPECTION DISPLAY BREAKER	21/07/2026								☑		
		INSPECTION HEATER BUSDUCT	21/07/2026								☑		
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	21/07/2026								☑		
		INSPECTION SILICA BUSDUCT	21/07/2026								☑		
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	21/07/2026								☑		
		INSPECTION CONTACT RESISTANCE BUSDUCT	21/07/2026								☑		
		INSPECTION ISOLATION RESISTANCE BUSDUCT	21/07/2026								☑		
29	WO-180726-0030	OM EIC Y1 UNIT 2 GENERATOR	21/07/2026			FINISH		M. Zaini	40	100		SUPERVISE_QC, OTHER TASK AS PER EIC JP	
		DISASSEMBLY BRACKET GENERATOR SISI FRONT	21/07/2026					JAPA			☑		
		DISASSEMBLY BRACKET GENERATOR SISI REAR	21/07/2026					JAPA			☑		
		DISASSEMBLY OIL DEFLECTOR BEARING	21/07/2026					JAPA			☑		
		CLEANING BODY GENERATOR	21/07/2026					JAPA			☑		
		CLEANING OIL DEFLECTOR BEARING	21/07/2026					JAPA			☑		
		CLEANING BOLT & NUT	21/07/2026					JAPA			☑		
		INSPECTION OIL DEFLECTOR BEARING 3 & 4	21/07/2026					JAPA			☑		
		INSPECTION SHROUD & FAN BLADE	21/07/2026					JAPA			☑		
		INSPECTION STATOR GENERATOR (R, P1)	21/07/2026					JAPA			☑		
		INSPECTION ROTOR GENERATOR (R, PL, RSO)	21/07/2026					JAPA			☑		
		INSPECTION VISUAL ISOLATOR	21/07/2026					JAPA			☑		
		INSPECTION ROTOR GROUNDING	21/07/2026					JAPA			☑		
		INSPECTION VISUAL FLEXIBLE ISOLATOR	21/07/2026					JAPA			☑		
		INSPECTION BRUSH GROUNDING	21/07/2026					JAPA			☑		
		INSPECTION TAHANAN ISOLASI GENERATOR	21/07/2026					JAPA			☑		
		INSPECTION HEATER NEUTRAL SIDE CUBICLE	21/07/2026					JAPA			☑		

		INSPECTION HEATER LINE SIDE CUBICLE	21/07/2026				JAPA		☑		
		ASSEMBLY OIL DEFLECTOR BEARING	21/07/2026				JAPA		☑		
		ASSEMBLY BRACKET SISI FRONT	21/07/2026				JAPA		☑		
		ASSEMBLY BRACKET SISI REAR	21/07/2026				JAPA		☑		
		PENGUKURAN TAHANAN RESISTOR	21/07/2026				JAPA		☑		
		INSPECTION & CLEANING PT	21/07/2026				JAPA		☑		
		INSPECTION & CLEANING CT	21/07/2026				JAPA		☑		
		PENGUKURAN TAHANAN ISOLASI PERMANEN MAGNET GENERATOR (PMG)	21/07/2026				JAPA		☑		
		INSPECTION DIODA EXCITER PERMANEN MAGNET GENERATOR (PMG)	21/07/2026				JAPA		☑		
		INSPECTION TERMINASI PERMANEN MAGNET GENERATOR (PMG)	21/07/2026				JAPA		☑		
		INSPECTION GROUNDING SYSTEM PERMANEN MAGNET GENERATOR (PMG)	21/07/2026				JAPA		☑		
		INSPECTION FUSE PANEL PERMANEN MAGNET GENERATOR (PMG)	21/07/2026				JAPA		☑		
		INSPECTION DISCONNECTING SWITCH NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION TRAF0 NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION ISOLATOR BUSHING NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION TERMINASI NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		TEST TAHANAN ISOLASI NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION HEATER BUSDUCT NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION SILICA BUSDUCT	21/07/2026				JAPA		☑		
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION CONTACT RESISTANCE BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION ISOLATION RESISTANCE BUSDUCT	21/07/2026				JAPA		☑		
		CLEANING	21/07/2026				JAPA		☑		
30	WO-180726-0031	OM EIC Y1 UNIT 2 AUXILIARY TRANSFORMER 2	21/07/2026	25/07/2026	27/07/2026	FINISH	M. Zaini	24	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION ISOLATOR BUSHING	21/07/2026				JAPA		☑		
		INSPECTION TERMINASI	21/07/2026				JAPA		☑		
		CLEANING BUSHING CONNECTION HV & LV	21/07/2026				JAPA		☑		
		INSPECTION DAN CLEANING PANEL	21/07/2026				JAPA		☑		
		INSPECTION SILICAGEL	21/07/2026				JAPA		☑		
		INSPECTION GROUNDING SYSTEM	21/07/2026				JAPA		☑		
		INSPECTION KEBOCORAN MINYAK TRAF0	21/07/2026				JAPA		☑		
		PROTECTIVE DEVICE TEST DAN RESET TRAF0	21/07/2026				JAPA		☑		
		INSPECTION PANEL TAP CHANGER	21/07/2026				JAPA		☑		
		INSPECTION TAHANAN ISOLASI WINDING TRAF0	21/07/2026				JAPA		☑		
		RDS TEST	21/07/2026				JAPA		☑		
		MECHANICAL RELAY TEST	21/07/2026				JAPA		☑		
		INSPECTION DISCONNECTING SWITCH NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION TRAF0 NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION ISOLATOR BUSHING NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION TERMINASI NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION GROUNDING SYSTEM NETRAL GROUNDING RESISTANCE (NGR)	21/07/2026				JAPA		☑		
		INSPECTION HEATER BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION SILICA BUSDUCT	21/07/2026				JAPA		☑		
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION CONTACT RESISTANCE BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION ISOLATION RESISTANCE BUSDUCT	21/07/2026				JAPA		☑		
		CLEANING	21/07/2026				JAPA		☑		
31	WO-180726-0032	OM EIC Y1 UNIT 2 6.6KV MEDIUM VOLTAGE STATION BOARDS PANEL	21/07/2026	23/07/2026		FINISH	M. Zaini	15	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20BBA10GS101:UNIT 2 SWITCHGEAR 6.6KV INCOMING PANEL (MV UAT 2 CB9)	21/07/2026				JAPA		☑		
		MSW20BBA10GS102:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 1 PA FAN 1	21/07/2026				JAPA		☑		
		MSW20BBA10GS103:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 2 PA FAN 2	21/07/2026				JAPA		☑		
		MSW20BBA10GS104:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 3 SA FAN 1	21/07/2026				JAPA		☑		
		MSW20BBA10GS105:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 4 SA FAN 2	21/07/2026				JAPA		☑		
		MSW20BBA10GS106:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 5 ID FAN 1	21/07/2026				JAPA		☑		
		MSW20BBA10GS107:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 6 ID FAN 2	21/07/2026				JAPA		☑		
		MSW20BBA10GS108:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 8 BF PUMP 1	21/07/2026				JAPA		☑		
		MSW20BBA10GS109:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 9 BF PUMP 2	21/07/2026				JAPA		☑		
		MSW20BBA10GS110:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 7 CW PUMP 3	21/07/2026				JAPA		☑		
		MSW20BBA10GS111:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 11 CW PUMP 4	21/07/2026				JAPA		☑		
		MSW20BBA10GS112:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 OUTGOING FEEDER 12 CW PUMP 5	21/07/2026				JAPA		☑		
		MSW20BBA10GS113:UNIT 2 SWITCHGEAR 6.6KV UNIT 2 TRAF0 FEEDER	21/07/2026				JAPA		☑		
		UNIT 2 SWITCHGEAR 6.6KV UNIT 2 ADAPTER	21/07/2026				JAPA		☑		
		MSW20BBA10GS114:UNIT 2 SWITCHGEAR 6.6KV METERING (L10)	21/07/2026				JAPA		☑		
32	WO-180726-0001	OM EIC Y1 UNIT 2 MEDIUM VOLTAGE STATION BOARDS COMMON	21/07/2026			FINISH	Aldhly	10	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		SWITCHGEAR 6.6KV UNIT 2 INCOMING GENERATOR 1	21/07/2026						☑		
		SWITCHGEAR 6.6KV UNIT 2 INCOMING GENERATOR 2	21/07/2026						☑		
		SWITCHGEAR 6.6KV UNIT 2 INCOMING GENERATOR 3	21/07/2026						☑		
		SWITCHGEAR 6.6KV UNIT 2 INCOMING GENERATOR 4	21/07/2026						☑		
		SWITCHGEAR 6.6KV UNIT 2 OUTGOING TRAF0 1	21/07/2026						☑		
		SWITCHGEAR 6.6KV UNIT 2 OUTGOING TRAF0 2	21/07/2026						☑		
		MSW00BBA10CE201:MV COMMON METERING	21/07/2026						☑		
		MSW00BBA10GH201:SWITCHGEAR 6.6KV COMMON BUSTIE RIGHT	21/07/2026						☑		
		MSW00BBA10GH202:SWITCHGEAR 6.6KV COMMON BUSTIE LEFT	21/07/2026						☑		
		MSW00BBA10GH203:SWITCHGEAR 6.6KV COMMON TRAF0 FEEDER	21/07/2026						☑		
33	WO-180726-0033	OM EIC Y1 UNIT 2 MAIN TURBINE	21/07/2026			FINISH	M. Toher	42	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		CONDENSATE PRESSURE TO BYPASS SPRAY PRESSURE TRANSMITTER (20LCE40CP001)	21/07/2026						☑		
		CONDENSATE PRESSURE TO BYPASS SPRAY PRESSURE TRANSMITTER (20LCE40CP002)	21/07/2026						☑		
		CONDENSATE PRESSURE TO BYPASS SPRAY PRESSURE TRANSMITTER (20LCE40CP003)	21/07/2026						☑		
		ACTUATOR TURBINE EXTRACTION III TO DEAERATOR CV 20LBD20AAZ10	21/07/2026						☑		
		ACTUATOR MOV TURBINE STOP VALVE UNIT 2	21/07/2026						☑		
		ACTUATOR MOV PREHEATING 1 TURBINE	21/07/2026						☑		
		ACTUATOR MOV PREHEATING 2 TURBINE	21/07/2026						☑		
		TURBINE EXTRACTION II TO LPH2 TEMPERATURE TRANSMITTER (20LBD30CT001)	21/07/2026						☑		
		TURBINE EXTRACTION III TO DEAERATOR TEMPERATURE TRANSMITTER (20LBD20CT001)	21/07/2026						☑		
		TURBINE EXTRACTION I TO LPH1 TEMPERATURE TRANSMITTER (20LBD10CT001)	21/07/2026						☑		
		MSW20MAA10CP302 : UNIT 2 TURBINE BEHIND CONTROL STAGE PRESSURE TRANSMITTER (20MAA10C	21/07/2026						☑		
		MSW20MAA10CP303 : UNIT 2 TURBINE EXHAUST PRESSURE TRANSMITTER (20MAA10CP002)	21/07/2026						☑		
		MSW20MAA10CP304 : UNIT 2 TURBINE EXHAUST PRESSURE TRANSMITTER (20MAA10CP003)	21/07/2026						☑		
		MSW20MAA10CP305 : UNIT 2 TURBINE EXHAUST PRESSURE TRANSMITTER (20MAA10CP004)	21/07/2026						☑		
		MSW20MAA10CP306 : UNIT 2 TURBINE BEHIND CONTROL STAGE PRESSURE TRANSMITTER (20MAA10C	21/07/2026						☑		

		MOV TURBINE STEAM EXTRACTION-1	21/07/2026							✓		
		MOV TURBINE STEAM EXTRACTION-2	21/07/2026							✓		
		MOV MAIN STEAM DRAIN STG-2	21/07/2026							✓		
		TURBINE CASING TEMPERATURE - INSIDE TRANSMITTER 20MAA10CT012	21/07/2026							✓		
		TURBINE CASING TEMPERATURE - CENTER TRANSMITTER 20MAA10CT013	21/07/2026							✓		
		DEAERATOR PRDS OUTLET TO EXTRACTION I - DEAERATOR VL TEMP TRANSMITTER 20LBD11CT002	21/07/2026							✓		
		DEAERATOR PRDS OUTLET TO EXTRACTION I - DEAERATOR VL TEMP TRANSMITTER 20LBD11CT001	21/07/2026							✓		
		DEAERATOR PRDS TO OUTLET EXTRACTION TRANSMITTER 20LBD11CP001	21/07/2026							✓		
		DEAERATOR PRDS TO OUTLET EXTRACTION II TRANSMITTER 20LBD11CP002	21/07/2026							✓		
		FEEDWATER STORAGE TANK PRESSURE TRANSMITTER 20LAA20CP001	21/07/2026							✓		
		CONTROL VALVE LPH-1	21/07/2026							✓		
		CONTROL VALVE LPH-2	21/07/2026							✓		
		LP HEATER 2 TRANSMITTER 20LCC40CL001	21/07/2026							✓		
		LP HEATER 2 TRANSMITTER 20LCC40CL002	21/07/2026							✓		
		LPH II - TUBE SIDE OUTLET TO DEAERATOR TEMP TRANSMITTER 20LCC20CT001	21/07/2026							✓		
		FEEDWATER STORAGE TANK TRANSMITTER 20LAA20CT001	21/07/2026							✓		
		CYCLE MAKE UP PUMP DEAERATOR TRANSMITTER 20HGC20CF001	21/07/2026							✓		
		DEAERATOR TANK LEVEL 1 TRANSMITTER 20LAA20CL001	21/07/2026							✓		
		DEAERATOR TANK LEVEL 2 TRANSMITTER 20LAA20CL002	21/07/2026							✓		
		DEAERATOR TANK LEVEL 3 TRANSMITTER 20LAA20CL003	21/07/2026							✓		
		TURBINE EXTRACTION III TO DEAERATOR PRESSURE TRANSMITTER 20LBD20CP001	21/07/2026							✓		
		TURBINE EXTRACTION III TO LPH PRESSURE TRANSMITTER 20LBD30CP001	21/07/2026							✓		
		TURBINE EXTRACTION I TO PNEUMATIC OPERATED VALVE PRESSURE TRANSMITTER 20LBS10CP001	21/07/2026							✓		
		LP HEATER 1 TRANSMITTER 20LCC30CL001	21/07/2026							✓		
		LP HEATER 1 TRANSMITTER 20LCC30CL002	21/07/2026							✓		
		FLOW CONDESATE TO LP HEATER 1 TRANSMITTER 20LCA40CF001	21/07/2026							✓		
		CONDENSATE TO LP HEATER TRANSMITTER 20LCA40CF001	21/07/2026							✓		
34	WO-180726-0034	OM EIC 1Y FIRE ALARM LOCAL PANEL (UNIT 2)	21/07/2026	21/07/2026	FINISH	Jhon FM	13	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW00CYE10GH101 : ALARM SYSTEM ADMIN BUILDING	21/07/2026							✓		
		MSW00CYE10GH102 : ALARM SYSTEM DG SHEET	21/07/2026							✓		
		MSW00CYE10GH103 : PANEL MAIN FIRE ALARM SYSTEM	21/07/2026							✓		
		MSW00CYE10GH104 : ALARM SYSTEM DM MCC ROOM	21/07/2026							✓		
		MSW00CYE10GH105 : ALARM SYSTEM CHP MCC	21/07/2026							✓		
		MSW00CYE10GH106 : ALARM SYSTEM AHP MCC	21/07/2026							✓		
		MSW00CYE10GH107 : ALARM SYSTEM COOLING WATER	21/07/2026							✓		
		MSW00CYE10GH108 : ALARM SYSTEM DM/RW.FW.TW PUMP	21/07/2026							✓		
		MSW00CYE10GH109 : ALARM SYSTEM WORKSHOP OFFICE ROOM	21/07/2026							✓		
		MSW00CYE10GH110 : ALARM SYSTEM SWAS ROOM	21/07/2026							✓		
		MSW00CYE10GH111 : ALARM SYSTEM STG BUILDING	21/07/2026							✓		
		MSW00CYE10GH113 : ALARM SYSTEM SWITCHYARD BUILDING	21/07/2026							✓		
		MSW00CYE10GH114 : ALARM SYSTEM REMOTE SUBSTATION BUILDING	21/07/2026							✓		
35	WO-180726-0033	OM EIC 1Y UNIT 2 PRIMARY AIR FAN LINE	21/07/2026		FINISH	Ferryus	4	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION AND CALIBRATION OXYGEN ANALYZER	21/07/2026							✓		
		P.A APH OUTLET FLOW DP TRANSMITTER 20HLA15CF001	21/07/2026							✓		
		P.A APH OUTLET FLOW DP TRANSMITTER 20HLA15CF002	21/07/2026							✓		
		P.A APH OUTLET PRESSURE TRANSMITTER 20HLA15CP001	21/07/2026							✓		
36	WO-180726-0033	OM EIC 1Y UNIT 2 SECONDARY AIR FAN LINE	21/07/2026		FINISH	Ferryus	8	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		AIR SUB1 FLOW DP TRANSMITTER 20HIL10CF010	21/07/2026							✓		
		AIR SUB2 FLOW DP TRANSMITTER 20HIL11CF010	21/07/2026							✓		
		SA APH OUTLET FLOW TRANSMITTER 20HLA25CF001	21/07/2026							✓		
		SA APH OUTLET FLOW TRANSMITTER 20HLA25CF002	21/07/2026							✓		
		SA APH OUTLET PRESSURE TRANSMITTER 20HLA25CP001	21/07/2026							✓		
		UNIT 2 SECONDARY AIR FAN IGV SUB 1 20HIL10AA010	21/07/2026							✓		
		UNIT 2 SECONDARY AIR FAN IGV SUB 2 20HIL11AA010	21/07/2026							✓		
		UNIT 2 SECONDARY AIR FAN IGV SA CONTROL DAMPER 20HLA25AA010	21/07/2026							✓		
37	WO-180726-0033	OM EIC Y1 UNIT 2 BOILER DISTRIBUTED CONTROL PANEL	21/07/2026		FINISH	Jhon FM	3	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		PM PC OWS	21/07/2026							✓		
		PM PC EWS	21/07/2026							✓		
		PM panel RIO	21/07/2026							✓		
38	WO-180726-0033	OM EIC Y1 UNIT 2 BOILER DRUM	21/07/2026		FINISH	Jhon FM	12	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION & CALIBRATION STEAM DRUM VENTING ISOLATION VALVE	21/07/2026							✓		
		INSPECTION & CALIBRATION STEAM DRUM MOV VENTING REGULATING VALVE	21/07/2026							✓		
		INSPECTION & CALIBRATION STEAM DRUM CBD ISOLATION VALVE	21/07/2026							✓		
		INSPECTION & CALIBRATION STEAM DRUM MOV CBD REGULATING VALVE	21/07/2026							✓		
		INSPECTION & CALIBRATION STEAM DRUM ISD ISOLATION VALVE	21/07/2026							✓		
		INSPECTION & CALIBRATION STEAM DRUM MOV ISD REGULATING VALVE	21/07/2026							✓		
		DRUM LEVEL TRANSMITTER 20HAD10CL001	21/07/2026							✓		
		DRUM LEVEL TRANSMITTER 20HAD10CL002	21/07/2026							✓		
		DRUM LEVEL TRANSMITTER 20HAD10CL003	21/07/2026							✓		
		DRUM PRESSURE TRANSMITTER 20HAD10CP002	21/07/2026							✓		
		DRUM PRESSURE TRANSMITTER 20HAD10CP003	21/07/2026							✓		
		DRUM PRESSURE TRANSMITTER 20HAD10CP001	21/07/2026							✓		
39	WO-180726-0039	OM EIC Y1 UNIT 2 COMBUSTOR	21/07/2026		FINISH	M. Toher	18	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		COMBUSTER ASH DRAIN 1 (BED ASH COOLER DRAIN) MOV 20HHC01AA001	21/07/2026							✓		
		COMBUSTER ASH DRAIN 2 (EMERGENCY ASH DRAIN) MOV 20HHC01AA002	21/07/2026							✓		
		ACTUATOR BED MATERIAL DISCHARGE GATE VALVE 20EYG31AA01	21/07/2026							✓		
		COMBUSTOR LOWER PRESSURE TRANSMITTER 20HHC01CP001	21/07/2026							✓		
		MSW20HHC10CP102 : UNIT 2 COMBUSTOR DP WITH GRATE 20HHC01CP011	21/07/2026							✓		
		MSW20HHC10CP103 : UNIT 2 COMBUSTOR UPPER DP 20HHC01CT012	21/07/2026							✓		
		AIR COMBUSTOR AT LEVEL PRES TRANSMITTER 20HHC01CP060	21/07/2026							✓		
		MSW20HHC10CT101 : UNIT 2 COMBUSTOR LOWER TEMP 20HHC01CT011	21/07/2026							✓		
		MSW20HHC10CT102 : UNIT 2 COMBUSTOR LOWER TEMP 20HHC01CT012	21/07/2026							✓		
		MSW20HHC10CT103 : UNIT 2 COMBUSTOR LOWER TEMP 20HHC01CT013	21/07/2026							✓		
		MSW20HHC10CT104 : UNIT 2 COMBUSTOR MIDDLE TEMP 20HHC01CT041	21/07/2026							✓		
		MSW20HHC10CT105 : UNIT 2 COMBUSTOR MIDDLE TEMP 20HHC01CT042	21/07/2026							✓		
		MSW20HHC10CT106 : UNIT 2 COMBUSTOR MIDDLE TEMP 20HHC01CT043	21/07/2026							✓		
		INLET BACKPASS PRESSURE TRANSMITTER 20HBK01CP003	21/07/2026							✓		
		INLET BACKPASS PRESSURE TRANSMITTER 20HBK01CP002	21/07/2026							✓		
		INLET BACKPASS PRESSURE TRANSMITTER 20HBK01CP001	21/07/2026							✓		
		BACKPASS PRESSURE AFTER LT 5H TRANSMITTER 20HBK01CP030	21/07/2026							✓		
		BACKPASS PRESSURE AFTER ECO TRANSMITTER 20HBK01CP050	21/07/2026							✓		
40	WO-180726-0040	OM EIC Y1 UNIT 2 CYCLONE	21/07/2026		FINISH	M. Toher	6	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	

		MSW20HDF10CP102 : UNIT 2 BACKPASS INLET PRESSURE	21/07/2026							✓		
		CYCLONE TO SEALPOT PRESSURE TRANSMITTER 20HDF01CP001	21/07/2026							✓		
		MSW20HDF10CT101 : UNIT 2 BACKPASS INLET TEMPERATURE	21/07/2026							✓		
		MSW20HDF10CT102 : UNIT 2 CYCLONE OUTLET TEMP 20HNA01CT001	21/07/2026							✓		
		MSW20HDF10CT103 : UNIT 2 BACKPASS INLET TEMPERATURE	21/07/2026							✓		
		MSW20HDF10CT104 : UNIT 2 CYCLONE INLET TEMPERATURE	21/07/2026							✓		
41	WO-180726-0041	OM EIC Y1 UNIT 2 SEALPOT	21/07/2026		FINISH	M. Zaini	4	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		ACTUATOR DAMPER SEALPOT BLOWER 1	21/07/2026							✓		
		ACTUATOR DAMPER SEALPOT BLOWER 2	21/07/2026							✓		
		CALIBRATION PRESSURE TRANSMITTER	21/07/2026							✓		
		CALIBRATION TEMPERATURE TRANSMITTER	21/07/2026							✓		
42	WO-180726-0042	OM EIC Y1 UNIT 2 SUPERHEATER SYSTEM LINE	21/07/2026		FINISH	M. Zaini	12	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		ERV PRESSURE SWITCH 20LBA20CF502	21/07/2026							✓		
		INSPECTION AND CALIBRATION TEMP TRANSMITTER 20LBA10CT001	21/07/2026							✓		
		INSPECTION AND CALIBRATION TEMP TRANSMITTER 20LBA10CT002	21/07/2026							✓		
		INSPECTION AND CALIBRATION TEMP TRANSMITTER 20LBA10CT003	21/07/2026							✓		
		ACTUATOR MAIN STEAM LINE (START UP BYPASS) TO DEAERATOR PRDS I/L CV 20LBH10AA210	21/07/2026							✓		
		MS START-UP VENT VALVE (REGULATING) MOV 20LBA21AA011	21/07/2026							✓		
		MS START-UP VENT VALVE (ISOLATION) MOV 20LBA21AA001	21/07/2026							✓		
		MAIN STEAM LIVE PRESSURE TRANSMITTER 20LAB10CP001	21/07/2026							✓		
		MAIN STEAM LIVE PRESSURE TRANSMITTER 20LAB10CP002	21/07/2026							✓		
		MAIN STEAM LIVE PRESSURE TRANSMITTER 20LAB10CP003	21/07/2026							✓		
		INSPECTION AND CALIBRATION FLOW TRANSMITTER 20LBA10CF001	21/07/2026							✓		
		INSPECTION AND CALIBRATION FLOW TRANSMITTER 20LBA10CF002	21/07/2026							✓		
43	WO-180726-0043	OM EIC Y1 UNIT 2 JACKING OIL PUMP	21/07/2026		FINISH	M. Toher	2	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20MAV10-M101 : UNIT 2 JACKING OIL PUMP MOTOR	21/07/2026			MSW				✓		
		MSW20MAV10CP101 : UNIT 2 JACKING OIL PRESSURE TRANSMITTER	21/07/2026			MSW				✓		
44	WO-180726-0044	OM EIC Y1 UNIT 2 MAIN OIL PUMP	21/07/2026		FINISH	Aldhly	4	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPEKSI & PM OIL PUMP MOTOR (AUXILIARY, EMERGENCY, JACKING, BREATHER)	21/07/2026			MSW				✓		
		INSPEKSI DAN KALIBRASI LUB OIL PRESSURE TRANSMITTER 20MAV40CP001	21/07/2026			JAPA				✓		
		INSPEKSI DAN KALIBRASI LUB OIL PRESSURE TRANSMITTER 20MAV40CP002	21/07/2026			JAPA				✓		
		INSPEKSI DAN KALIBRASI LUB OIL PRESSURE TRANSMITTER 20MAV40CP003	21/07/2026			JAPA				✓		
45	WO-180726-0045	OM EIC Y1 UNIT 2 TURBINE CONTROL VALVE	21/07/2026		FINISH	Aldhly	8	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		VALVE POSITION BLOCK LIVE STEAM PT (20MAX45CP001)	21/07/2026			JAPA				✓		
		VALVE POSITION BLOCK LIVE STEAM PT (20MAX45CP002)	21/07/2026			JAPA				✓		
		VALVE POSITION BLOCK LIVE STEAM PT (20MAX45CP003)	21/07/2026			JAPA				✓		
		VALVE BLOCK - OUTLET POSITION LIVE STEAM PT (20MAX45CP004)	21/07/2026			JAPA				✓		
		CONTROL OIL PRESSURE PT (20MAX40CP001)	21/07/2026			JAPA				✓		
		VALVE CHEST TEMPERATURE TRANSMITTER 20MAA10CT011	21/07/2026			MSW				✓		
		LIVE STEAM PRESSURE TRANSMITTER 20LBA10CP001	21/07/2026			JAPA				✓		
		CALIBRATION/FUNCTION TEST CONTROL VALVE	21/07/2026			MSW				✓		
46	WO-180726-0046	OM EIC Y1 UNIT 2 HP BYPASS VALVE	21/07/2026		FINISH	Jhon FM	6	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		CALIBRATION/FUNCTION TEST HP BYPASS CONTROL VALVE 20LBF10AA210	21/07/2026			AMP				✓		
		HP BYPASS TEMPERATURE TRANSMITTER 20LBF10CT001	21/07/2026			MSW				✓		
		BYPASS PRESSURE TRANSMITTER 20MAG10CP001	21/07/2026			JAPA				✓		
		MSW20LBF10CG101 : UNIT 2 STEAM BYPASS REDUCING CONTROL VALVE PRESSURE TRANSMITTER	21/07/2026			JAPA				✓		
		MSW20LBF10CP101 : UNIT 2 STEAM BYPASS REDUCING PRESSURE TRANSMITTER 20LBF10CP001	21/07/2026			JAPA				✓		
		MSW20LBF10CT101 : UNIT 2 STEAM BYPASS REDUCING TEMPERATURE TRANSMITTER	21/07/2026			MSW				✓		
47	WO-180726-0047	OM EIC Y1 UNIT 2 TURBINE DRAINAGE MAIN HEADER LINE TO EXPANSION TUBE	21/07/2026		FINISH	M. Zaini	7	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		DRAIN OF ESV 20MAL10AA210	21/07/2026							✓		
		DRAIN OF CV CHAMBER 20MAL20AA210	21/07/2026							✓		
		TURBINE DRAIN VALVE AFTER FIRST STAGE 20MAL30AA210	21/07/2026							✓		
		TURBINE DRAIN VALVE 20MAL40AA210	21/07/2026							✓		
		TURBINE DRAIN VALVE 20MAL50AA210	21/07/2026							✓		
		TURBINE DRAIN VALVE 20MAL60AA210	21/07/2026							✓		
		TURBINE DRAIN VALVE 20MAL70AA210	21/07/2026							✓		
48	WO-180726-0048	OM EIC Y1 UNIT 2 VACUUM PUMP A	21/07/2026	23/07/2026	FINISH	M. Zaini	4	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20MAJ10-M102 : UNIT 2 VACUUM PUMP A MOTOR (MEGGER, INSPEKSI TERMINAL BLOK, DAN SISTE	21/07/2026			JAPA				✓		
		DISCHARGE, SUCTION & VENTING VALVE VACUUM PUMP-1	21/07/2026			MSW				✓		
		MSW20MAJ10AA101 : UNIT 2 AIR REMOVAL SYSTEM VACUUM BREAKER SOLENOID VALVE	21/07/2026			MSW				✓		
		MSW20MAJ10CG101 : UNIT 2 AIR REMOVAL SYSTEM POSITION TRANSMITTER	21/07/2026							✓		
49	WO-180726-0049	OM EIC Y1 UNIT 2 VACUUM PUMP B	21/07/2026	23/07/2026	FINISH	M. Zaini	4	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20MAJ10-M202 : UNIT 2 VACUUM PUMP B MOTOR (MEGGER, INSPEKSI TERMINAL BLOK, DAN SISTE	21/07/2026			JAPA				✓		
		DISCHARGE, SUCTION & VENTING VALVE VACUUM PUMP-2	21/07/2026			MSW				✓		
		MSW20MAJ10AA201 : UNIT 2 AIR REMOVAL SYSTEM VACUUM BREAKER SOLENOID VALVE	21/07/2026			MSW				✓		
		MSW20MAJ10CG201 : UNIT 2 AIR REMOVAL SYSTEM POSITION TRANSMITTER	21/07/2026							✓		
50	WO-180726-0050	OM EIC Y1 UNIT 2 CONDENSER	21/07/2026		FINISH	M Iqbal	5	100			SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		MSW20MAG10CP103 : UNIT 2 CONDENSER BYPASS PRESSURE TRANSMITTER 20MAG10CP001	21/07/2026			JAPA				✓		
		COOLING WATER SUPPLY TEMPERATURE TRANSMITTER 20PAB11CT001	21/07/2026			JAPA				✓		
		COOLING WATER SUPPLY TEMPERATURE TRANSMITTER 20PAB12CT001	21/07/2026			JAPA				✓		
		COOLING WATER RETURN TEMPERATURE TRANSMITTER 20PAB21CT001	21/07/2026			JAPA				✓		
		COOLING WATER RETURN TEMPERATURE TRANSMITTER 20PAB22CT001	21/07/2026			JAPA				✓		
51	WO-180726-0051	OM EIC Y1 UNIT 2 MAIN CONDENSATE PUMP A	21/07/2026	25/07/2026	25/07/2026	FINISH	M. Zaini	12	100		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026			JAPA				✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026			JAPA				✓		
		INSPECTION TAHANAN ISOLASI	21/07/2026			JAPA				✓		
		INSPECTION COOLING FAN	21/07/2026			JAPA				✓		
		INSPECTION TAHANAN WINDING	21/07/2026			JAPA				✓		
		INSPECTION TERMINASI	21/07/2026			JAPA				✓		
		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026			JAPA				✓		
		CALIBRATION LIMIT SWITCH	21/07/2026			JAPA				✓		
		PRESSURE TRANSMITTER CONDENSATE PUMP TO DELIVERY 20LCA30CP001	21/07/2026			JAPA				✓		
		ACTUATOR CONDENSATE PUMP RECIRCULATION CONTROL VALVE 20LCA31AA210	21/07/2026			MSW				✓		
		ACTUATOR MAIN CONDENSATE CONTROL VALVE 20LCA30AA240	21/07/2026			MSW				✓		
		CEP DISCHARGE ISOLATION VALVE	21/07/2026			MSW				✓		
52	WO-180726-0052	OM EIC Y1 UNIT 2 MAIN CONDENSATE PUMP B	21/07/2026	25/07/2026	25/07/2026	FINISH	M. Zaini	9	100		SUPERVISE, QC, OTHER TASK AS PER EIC JP	
		INSPECTION FRAME MOTOR	21/07/2026			JAPA				✓		
		REGREASING (JIKA DILENGKAPI NIPPLE GREASE)	21/07/2026			JAPA				✓		
		INSPECTION TAHANAN ISOLASI	21/07/2026			JAPA				✓		
		INSPECTION COOLING FAN	21/07/2026			JAPA				✓		
		INSPECTION TAHANAN WINDING	21/07/2026			JAPA				✓		
		INSPECTION TERMINASI	21/07/2026			JAPA				✓		

		INSPECTION KONEKSI GROUNDING SYSTEM	21/07/2026				JAPA		☑		
		CALIBRATION LIMIT SWITCH	21/07/2026				JAPA		☑		
		CEP DISCHARGE ISOLATION VALVE	21/07/2026				MSW		☑		
53	WO-180726-0053	OM EIC Y1 UNIT 2 GENERATOR CONTROL PANEL	21/07/2026	21/07/2026	21/07/2026	FINISH	Jhon FM	13	100	SUPERVISE, QC, OTHER TASK AS PER EIC /P	
		PENGUJIAN PROTEKSI FREQUENCY	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI DIFFERENSIAL GENERATOR	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI SHORT CIRCUIT	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI OVERCURRENT	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI OVERVOLTAGE	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI ROTOR EARTH FAULT	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI STATOR EARTH FAULT	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI REVERSE POWER	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI UNDER EXCITATION	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI OVER EXCITATION	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI NEGATIVE SEQUENCE	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		PENGUJIAN PROTEKSI OVERLOAD	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
		CLEANING DAN TIGHTNING	21/07/2026	21/07/2026	22/07/2026		MSW		☑		
54	WO-180726-0054	OM EIC Y1 UNIT 2 GENERATOR EXCITATION PANEL	21/07/2026	21/07/2026	21/07/2026	FINISH	Jhon FM	5	100	SUPERVISE, QC, OTHER TASK AS PER EIC /P	
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE PANEL	21/07/2026	21/07/2026	21/07/2026		MSW		☑		
		MEMBERSHKAN FILTER PANEL	21/07/2026	21/07/2026	21/07/2026		MSW		☑		
		PEMELIHARAAN FAN CONVERTER UNITROL	21/07/2026	21/07/2026	21/07/2026		MSW		☑		
		MEMBERSHKAN KOMPARTEMEN DALAM PANEL	21/07/2026	21/07/2026	21/07/2026		MSW		☑		
		HOUSEKEEPING	21/07/2026	21/07/2026	21/07/2026		MSW		☑		
55	WO-180726-0055	OM EIC Y1 UNIT 2 SOOT BLOWER	21/07/2026			FINISH	Yoga	16	100	SUPERVISE, QC, OTHER TASK AS PER EIC /P	
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 1	21/07/2026	21/07/2026	21/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 2	21/07/2026	21/07/2026	21/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 3	21/07/2026	21/07/2026	21/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 4	21/07/2026	21/07/2026	21/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 5	21/07/2026	21/07/2026	21/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 6	21/07/2026	22/07/2026			JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 7	21/07/2026	22/07/2026	22/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 8	21/07/2026	22/07/2026	22/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 9	21/07/2026	22/07/2026	22/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 10	21/07/2026	22/07/2026	22/07/2026		JAPA		☑		
		CLEANING, INSPECTION, & REGREASING ALL SOOT BLOWER MOTOR 11	21/07/2026				JAPA		☑		
		SOOT BLOWER STEAM OUTLET TRANSMITTER 20HCB10CP001	21/07/2026				JAPA		☑		
		SOOT BLOWER STEAM FLOW TRANSMITTER 20HCB10CF001	21/07/2026				JAPA		☑		
		ACTUATOR VALVE DRAIN SOOT BLOWER 20HCB10AA201	21/07/2026				AMP		☑		
		SOOT BLOWER VALVE MOV 20HCB10AA001	21/07/2026	21/07/2026	21/07/2026		AMP		☑		
		ACTUATOR SOOT BLOWER CONTROL VALVE 20HCB10EX001	21/07/2026	22/07/2026	22/07/2026		MSW		☑		
56	WO-180726-0056	OM EIC Y1 UNIT 2 TURBINE CONTROL PANEL	21/07/2026			FINISH	Jhon FM	3	100	SUPERVISE, QC, OTHER TASK AS PER EIC /P	
		PM PC OWS	21/07/2026						☑		
		PM PC EWS	21/07/2026						☑		
		PM panel RIO	21/07/2026						☑		
57	WO-180726-0057	OM EIC Y1 UNIT 2 LV DISTRIBUTION	21/07/2026			FINISH	M Iqbal	36	100	SUPERVISE, QC, OTHER TASK AS PER EIC /P	
		INSPEKSI LV TRANSFORMER	21/07/2026				JAPA		☑		
		RDC Test LV TRANSFORMER	21/07/2026				JAPA		☑		
		FUNGSI RACK OUT RACK IN	21/07/2026				JAPA		☑		
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN BUSBAR	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI BUSBAR * Jaudah termasuk busbar dan busduct	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK BUSBAR	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN KABEL	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN TRAF0 KONTROL	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN SOOTBLOWER MCC FEEDER	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN TG MCC FEEDER	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN ADAPTER PANEL	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK BUSDUCT BUSTIE	21/07/2026				JAPA		☑		
		PERAWATAN ACB INCOMMMING	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI ACB INCOMMMING	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK ACB INCOMMMING	21/07/2026				JAPA		☑		
		PENGUJIAN ANALISA CB	21/07/2026				JAPA		☑		
		PERAWATAN ACB ESP FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI ACB ESP FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK ACB ESP FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN ANALISA CB ESP FEEDER	21/07/2026				JAPA		☑		
		PERAWATAN ACB BOILER FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK ACB BOILER FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN ANALISA CB BOILER FEEDER	21/07/2026				JAPA		☑		
		PERAWATAN ACB COOLING TOWER MCC FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI ACB COOLING TOWER FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK ACB COOLING TOWER FEEDER	21/07/2026				JAPA		☑		
		PENGUJIAN ANALISA CB COOLING TOWER FEEDER	21/07/2026				JAPA		☑		
		INSPECTION HEATER BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION BOLT BUSBAR, FLANGE & INSPECTION HOLE BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION SILICA BUSDUCT	21/07/2026				JAPA		☑		
		CEK KEBOCORAN DAN KELEMBAPAN BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION CONTACT RESISTANCE BUSDUCT	21/07/2026				JAPA		☑		
		INSPECTION ISOLATION RESISTANCE BUSDUCT	21/07/2026				JAPA		☑		
		HOUSEKEEPING	21/07/2026				JAPA		☑		
58	WO-180726-0058	OM EIC Y1 UNIT 2 380V MCC SWITCHGEAR BOILER	21/07/2026	22/07/2026	24/07/2026	FINISH	Yoga	12	100	SUPERVISE, QC, OTHER TASK AS PER EIC /P	
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN BUSBAR	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI BUSBAR	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK BUSBAR	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN KABEL	21/07/2026				JAPA		☑		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	21/07/2026				JAPA		☑		
		PERAWATAN MODULE WITHDRAWABLE	21/07/2026				JAPA		☑		
		PERAWATAN ACB INCOMMMING	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI ACB INCOMING	21/07/2026				JAPA		☑		
		PENGUJIAN TAHANAN KONTAK ACB	21/07/2026				JAPA		☑		

		PENGUJIAN ANALISA CB	21/07/2026			JAPA		☑		
		HOUSEKEEPING	21/07/2026			JAPA		☑		
59	WO-180726-0059	OM EIC Y1 UNIT 2 380V MCC SWITCHGEAR TG	21/07/2026			FINISH	M Iqbal	8	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	21/07/2026			JAPA		☑		
		PERAWATAN KOMPARTEMEN BUSBAR	21/07/2026			JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI BUSBAR	21/07/2026			JAPA		☑		
		PENGUJIAN TAHANAN KONTAK BUSBAR	21/07/2026			JAPA		☑		
		PERAWATAN KOMPARTEMEN KABEL	21/07/2026			JAPA		☑		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	21/07/2026			JAPA		☑		
		PERAWATAN MODULE WITHDRAWABLE	21/07/2026			JAPA		☑		
		HOUSEKEEPING	21/07/2026			JAPA		☑		
60	WO-180726-0060	OM EIC Y1 UNIT 2 380V MCC SWITCHGEAR ESP	21/07/2026			FINISH	M Iqbal	12	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP
		PERAWATAN BAGIAN EXTERNAL ENCLOSURE MCC	21/07/2026			JAPA		☑		
		PERAWATAN KOMPARTEMEN BUSBAR	21/07/2026			JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI BUSBAR	21/07/2026			JAPA		☑		
		PENGUJIAN TAHANAN KONTAK BUSBAR	21/07/2026			JAPA		☑		
		PERAWATAN KOMPARTEMEN KABEL	21/07/2026			JAPA		☑		
		PERAWATAN KOMPARTEMEN MARSHALLING PANEL	21/07/2026			JAPA		☑		
		PERAWATAN MODULE WITHDRAWABLE	21/07/2026			JAPA		☑		
		PERAWATAN ACB INCOMMING	21/07/2026			JAPA		☑		
		PENGUJIAN TAHANAN ISOLASI ACB INCOMMING	21/07/2026			JAPA		☑		
		PENGUJIAN TAHANAN KONTAK ACB INCOMMING	21/07/2026			JAPA		☑		
		PENGUJIAN ANALISA CB	21/07/2026			JAPA		☑		
		HOUSEKEEPING	21/07/2026			JAPA		☑		
61	WO-180726-0061	OM Y1 EIC UNIT 2 GLAND STEAM SEALING CONDENSER	21/07/2026	23/07/2026	23/07/2026	FINISH	Aldhly	5	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP
		GLAND STEAM CONDENSER VENTING MOTOR	21/07/2026					☑		
		GLAND STEAM PRESSURE TRANSMITTER 20MAW11CP001	21/07/2026					☑		
		ACTUATOR GLAND STEAM PRESSURE CONTROL VALVE 20MAW10AA210	21/07/2026					☑		
		ACTUATOR GLAND STEAM TEMPERATURE CONTROL VALVE 20LCE10AA210	21/07/2026					☑		
		GENERAL CLEANING	21/07/2026					☑		
62	WO-180726-0142	OM Y1 EIC UNIT 2 CONVECTIVE PASS	21/07/2026			FINISH	Ferryus	6	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP
		INSPECTION AND CALIBRATION OXYGEN ANALYZER	21/07/2026					☑		
		INLET BACKPASS PRESSURE TRANSMITTER	21/07/2026					☑		
		INLET BACKPASS PRESSURE TRANSMITTER	21/07/2026					☑		
		INLET BACKPASS PRESSURE TRANSMITTER	21/07/2026					☑		
		BACKPASS PRESSURE AFTER LT SH TRANSMITTER	21/07/2026					☑		
		BACKPASS PRESSURE AFTER ECO TRANSMITTER	21/07/2026					☑		
63	WO-180726-0062	OM Y1 EIC UNIT 2 FLYASH HANDLING	21/07/2026			FINISH	M Iqbal	6	100	SUPERVISE, QC, OTHER TASK AS PER EIC JP
		Panel Bapcon - Rapcon Field 1	21/07/2025					☑		
		Panel Bapcon - Rapcon Field 2	21/07/2025					☑		
		Panel Bapcon - Rapcon Field 3	21/07/2025					☑		
		Panel Bapcon - Rapcon Field 4	21/07/2025					☑		
		Panel Bapcon - Rapcon Field 5	21/07/2025					☑		
		Panel Bapcon - Rapcon Field 6	21/07/2025					☑		