Knotted Coil Designer

A browser tool for designing MRI receive phased arrays made of **knotted wire loops** (torus knots T(p,q), with 1–8 lobes) on a helmet former. It generates single elements, "blooms" them, and **automatically arranges N elements to reduce coupling between neighbours (geometric decoupling)**. It exports wire paths, coupling matrices and meshes.

> **Status: exploratory research software.** Every electromagnetic output is a *quasi-static geometric estimate*: it assumes low frequency and models the wires as thin current paths. It ignores capacitors, the head/body load and wave effects. Confirm any design with a full electromagnetic (full-wave) simulation or with bench S21, the coupling between two coils measured on a network analyser, before building.

How to run

- **Easiest:** double-click `app/index.html`. It needs no install and no internet; the Three.js 3D library is stored in `vendor/`.
  - *Not yet tested:* opening by double-click. It was tested served from a local web server.
  - If the array solver doesn't respond when opened by double-click, serve the folder instead, for example `npx http-server` (any static file server works) from this folder, and open `/app/index.html`.
- **Validation suite** (needs Node.js; takes about 2 minutes):

```
node tests/run.js
```

This writes `validation/validation_report.html`. The app's header shows the latest verdicts.

What's where

Path	Contents
`Design.md`	Frozen design v1.0 (pre-registers validation criteria V1–V6)
`DECISIONS.md`	Dated decision log, including validation failures and open questions for Reza
`PARAMETERS.md`	Every parameter with its origin tag (LIT / CONV / JUDG / TUNED / DERIVED)
`core/`	Geometry and EM package: `knot.js`, `inductance.js`, `surface.js`, `layout.js`, `optimise.js`
`app/index.html`	Browser UI: Element, Pair explorer, Array on helmet
`tests/run.js`	Pre-registered validation checks plus labelled post-hoc checks
`validation/`	Generated validation reports
`vendor/`	Three.js 0.149.0 (MIT licence, `vendor/three-LICENSE.txt`)

Validation status (run 2, 2026-10-20)

Check	Verdict
V1 Maxwell coaxial mutual inductance	PASS (worst error 0.005%)
V2 Loop self-inductance	PASS (worst error 0.66%)
V3 Coplanar-circle null spacing	NOT EVALUABLE (reference unverified; computed 0.760 × diameter)
V4 Convergence	PASS
V5 Symmetry	PASS
V6 Topology across bloom	**FAIL** at β = 0.02 only (below the physical floor for the placeholder wire; see DECISIONS.md)

References

- **Rosa, E. B. & Grover, F. W. (1912).** Formulas and tables for the calculation of mutual and self-inductance (revised). *Bulletin of the Bureau of Standards* 8(1):1–237, Scientific Paper 169. https://nvlpubs.nist.gov/nistpubs/bulletin/08/nbsbulletinv8n1p1_A2b.pdf
  - p. 6, eq. [1]: Maxwell's coaxial formula, modulus convention. **VERIFIED**.
  - p. 111, eq. [62]: ring self-inductance with surface current. **VERIFIED**.
  - pp. 20–21: Example 1, used for post-hoc check PH1. **VERIFIED**.
- **Roemer, P. B., Edelstein, W. A., Hayes, C. E., Souza, S. P. & Mueller, O. M. (1990).** The NMR phased array. *Magn Reson Med* 16:192–225. doi:10.1002/mrm.1910160203. **UNVERIFIED** (not read).
- **Roemer, P. B. & Edelstein, W. A., US Patent 4,825,162 (1989).** Read via Google Patents OCR text: circular-coil spacing "D approximately equal to 0.75d". **PARAPHRASE-ONLY.**

Provenance and AI-use statement

This software was written with **Claude Code** (Anthropic's AI coding assistant, model Claude Opus 5.5) under the direction of **Reza Farivar** (McGill University), who is accountable for it.

- Every source file carries a provenance header.
- Reference formulas were verified against the primary text listed above.
- Validation criteria were pre-registered in `Design.md` (git 39a4e83) before any code was written.
- Failures are recorded in `DECISIONS.md` and in the git history.
- Any use of results in publications must disclose AI assistance as the venue requires (COPE/ICMJE for journals; current Tri-Agency guidance for grants).

Third-party code: Three.js 0.149.0, © three.js authors, MIT licence.