

	<b>MAJOR TURNAROUND 2025</b> <b>PRESSURE VESSEL INSPECTION REPORT</b>	Report no.: <b>PLANT/01/VR-R-201/TA2025</b> Report date: 19 Nov 2025 Plant/Unit/Area: Plant 1
--	--	---

Equipment tag no: R-201  
Equipment description: Catalytic Reactor

DOSH registration no.: MK PMT 1001

**FINDINGS, NDTs & RECOMMENDATIONS**

**FINDINGS**

Initial/Pre-Inspection - Not applicable

**Post/Final Inspection**

**Internal**

2.1 Updated: Internal of manhole cover noted with evidence of mechanical mark on gasket seat area at 4 o'clock position. Mark dimensions approximately 10mm x 5mm.

2.3 2.3.1 Manhole weldment was found in serviceable condition except for evidence of pitting at 3 o'clock position.

**NON-DESTRUCTIVE TESTINGS**

UTTM: No significant wall loss detected compared to nominal thickness upon testing. Please refer UTTM report for complete documentation.

**RECOMMENDATIONS**

2.1: Monitor on next opportunity

2.3: 2.3.1 To be monitored on next opportunity

Inspected by:

Reviewed by:

Approved by (Client):

Recommendation/Comment by DOSH Officer (if applicable):

Name:

Signature:

Date:

Action taken by Plant 1 on recommendation by DOSH (if applicable):


	<b>MAJOR TURNAROUND 2025 PRESSURE VESSEL INSPECTION REPORT</b>	Report no.: <b>PLANT/01/VR-R-201/TA2025</b>  Report date: 19 Nov 2025 Plant/Unit/Area: Plant 1
--	--	---

Equipment tag no: R-201  
Equipment description: Catalytic Reactor


DOSH registration no.: MK PMT 1001

PHOTOS REPORT


Photo V-101




**Finding:**  
V-101.1 Updated: Internal of manhole cover noted with evidence of mechanical mark on gasket seat area at 4 o'clock position. Mark dimensions approximately 10mm x 5mm.  
**Recommendation:**  
V-101.1 Monitor on next opportunity



**Finding:**  
V-101.2 Updated: Internal of manhole cover noted with evidence of mechanical mark on gasket seat area at 4 o'clock position. Mark dimensions approximately 10mm x 5mm.  
**Recommendation:**  
V-101.2 Monitor on next opportunity



**Finding:**  
V-101.3 Nameplate and PMT number details  
**Recommendation:**  
V-101.3 Nil



**Finding:**  
V-101.4 2.3.1 Manhole weldment was found in serviceable condition except for evidence of pitting at 3 o'clock position.

**Recommendation:**  
V-101.4 2.3.1 To be monitored on next opportunity

---