

SAMPLE - ANTIGUA AND BARBUDA

Environmental and social screening

Crabbs Seawater Reverse-Osmosis Desalination Plant

Category

IFC Category B - limited, site-specific, largely reversible impacts.

Key impacts

Brine discharge salinity plume, intake entrainment, construction noise, coastal access.

Mitigation

Multiport diffuser to reach <2 ppt above ambient within 100 m; velocity-capped intake (<0.15 m/s); construction management plan.

Standards

IFC Performance Standards 1, 3, 4 and 6; EHS Guidelines for Water and Sanitation.

Next step

Full ESIA with marine baseline survey (12 months).